

Subtype HPA-O 7 S Premium, HPA-O 7 CS Premium

Certificate Holder	STIEBEL ELTRON GmbH & Co KG
Address	Dr. Stiebel Straße 33
ZIP	37603
City	Holzminden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	HPA-O 7 S Premium, HPA-O 7 CS Premium
Registration number	011-1W0229
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	4.2 kg
Certification Date	08.01.2018

Model HPA-O 7 S Premium

Model name	HPA-O 7 S Premium
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	151 %	122 %
Prated	8.00 kW	8.00 kW
SCOP	3.84	3.20
Tbiv	-8 °C	-8 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.80 kW	7.10 kW
COP Tj = -7°C	2.49	2.18
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.30 kW	4.20 kW
COP Tj = +2°C	4.04	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.50 kW	4.20 kW
COP Tj = +7°C	5.08	4.07
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.40 kW	4.00 kW
COP Tj = 12°C	6.30	5.14
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.10 kW	7.40 kW
COP Tj = Tbiv	2.42	2.13

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.60 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.97
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.00 kW
Annual energy consumption Qhe	4303 kWh	5300 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	137 %	118 %
Prated	11.00 kW	12.00 kW
SCOP	3.51	3.05
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.80 kW	7.00 kW
COP Tj = -7°C	2.72	2.45
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.30 kW	4.20 kW
COP Tj = +2°C	4.45	3.70
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.30 kW
COP Tj = +7°C	5.44	4.53
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.40 kW	4.10 kW
COP Tj = 12°C	6.30	5.44
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.70 kW	7.90 kW
COP Tj = Tbiv	2.50	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	2.10
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.20 kW	11.61 kW
Annual energy consumption Q _{he}	7727 kWh	9481 kWh
P _{dh} T _j = -15°C (if TOL	9.10	9.70
COP T _j = -15°C (if TOL	2.25	2.10
C _{dh} T _j = -15 °C	0.90	0.90

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	153 %	120 %
Prated	4.00 kW	4.00 kW
SCOP	3.91	2.99
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	4.20 kW	4.00 kW
COP T _j = +2°C	3.48	2.50
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	4.30 kW	3.90 kW
COP T _j = +7°C	4.46	3.16
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	4.30 kW	3.80 kW
COP T _j = 12°C	5.89	4.57
C _{dh} T _j = +12 °C	0.90	0.90
P _{dh} T _j = T _{biv}	4.20 kW	4.00 kW
COP T _j = T _{biv}	3.48	2.50
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.20 kW	9.80 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.15	1.98
WTOL	65 °C	65 °C
P _{off}	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1367 kWh	1750 kWh

Model HPA-O 7 CS Premium

Model name	HPA-O 7 CS Premium
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	50 dB(A)	50 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	159 %	127 %
Prated	8.00 kW	8.00 kW
SCOP	4.04	3.34
Tbiv	-8 °C	-8 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.80 kW	7.10 kW
COP Tj = -7°C	2.49	2.18
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.30 kW	4.20 kW
COP Tj = +2°C	4.04	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.50 kW	4.20 kW
COP Tj = +7°C	5.08	4.07
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.40 kW	4.00 kW
COP Tj = 12°C	6.30	5.14
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.10 kW	7.40 kW
COP Tj = Tbiv	2.42	2.13

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.60 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.97
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.00 kW
Annual energy consumption Qhe	4086 kWh	5084 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	140 %	119 %
Prated	11.00 kW	12.00 kW
SCOP	3.57	3.09
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.80 kW	7.00 kW
COP Tj = -7°C	2.72	2.45
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.30 kW	4.20 kW
COP Tj = +2°C	4.45	3.70
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.50 kW	4.30 kW
COP Tj = +7°C	5.44	4.53
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.40 kW	4.10 kW
COP Tj = 12°C	6.30	5.44
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.70 kW	7.90 kW
COP Tj = Tbiv	2.50	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	2.10
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	11.20 kW	11.61 kW
Annual energy consumption Q _{he}	7597 kWh	9351 kWh
P _{dh} T _j = -15°C (if TOL	9.10	9.70
COP T _j = -15°C (if TOL	2.25	2.10
C _{dh} T _j = -15 °C	0.90	0.90

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	190 %	142 %
Prated	4.00 kW	4.00 kW
SCOP	4.83	3.50
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	4.20 kW	4.00 kW
COP T _j = +2°C	3.48	2.50
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	4.30 kW	3.90 kW
COP T _j = +7°C	4.46	3.16
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	4.30 kW	3.80 kW
COP T _j = 12°C	5.89	4.57
C _{dh} T _j = +12 °C	0.90	0.90
P _{dh} T _j = T _{biv}	4.20 kW	4.00 kW
COP T _j = T _{biv}	3.48	2.50
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.20 kW	9.80 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.15	1.98
WTOL	65 °C	65 °C
P _{off}	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1106 kWh	1489 kWh