

## Subtype WPL 25 AC

Certificate Holder	STIEBEL ELTRON GmbH & Co KG
Address	Dr. Stiebel Straße 33
ZIP	37603
City	Holzminden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	WPL 25 AC
Registration number	011-1W0490
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	5.5 kg
Certification Date	11.08.2016

## Model WPL 25 AC

Model name	WPL 25 AC
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	187 %	144 %
Prated	15.00 kW	15.00 kW
SCOP	4.76	3.67
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.80 kW	13.26 kW
COP Tj = -7°C	2.98	2.48
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.72	3.51
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	8.00 kW	7.80 kW
COP Tj = +7°C	6.16	4.61
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	1.000	1.000
Pdh Tj = Tbiv	11.80 kW	12.50 kW
COP Tj = Tbiv	3.16	2.59

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.60 kW	13.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	2.28
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.40 kW	1.60 kW
Annual energy consumption Qhe	6513 kWh	8444 kWh

#### EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	160 %	131 %
Prated	21.00 kW	22.00 kW
SCOP	4.08	3.35
Tbiv	-10 °C	-10 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	12.60 kW	13.30 kW
COP Tj = -7°C	3.13	2.67
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	8.30 kW	8.30 kW
COP Tj = +2°C	5.15	3.92
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	8.00 kW	7.90 kW
COP Tj = +7°C	6.57	5.12
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	14.10 kW	15.20 kW
COP Tj = Tbiv	2.90	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.70 kW	18.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.66	2.37
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	20.59 kW	22.15 kW
Annual energy consumption Q <sub>he</sub>	12690 kWh	16179 kWh
P <sub>dh</sub> T <sub>j</sub> = -15°C (if TOL	16.70	18.30
COP T <sub>j</sub> = -15°C (if TOL	2.66	2.37
C <sub>dh</sub> T <sub>j</sub> = -15 °C	1.00	1.00

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η <sub>s</sub>	246 %	177 %
Prated	8.00 kW	8.00 kW
SCOP	6.22	4.51
T <sub>biv</sub>	2 °C	2 °C
TOL	2 °C	2 °C
P <sub>dh</sub> T <sub>j</sub> = +2°C	8.30 kW	8.40 kW
COP T <sub>j</sub> = +2°C	4.14	2.74
C <sub>dh</sub> T <sub>j</sub> = +2 °C	1.00	1.00
P <sub>dh</sub> T <sub>j</sub> = +7°C	7.90 kW	7.50 kW
COP T <sub>j</sub> = +7°C	5.47	3.64
C <sub>dh</sub> T <sub>j</sub> = +7 °C	1.00	1.00
P <sub>dh</sub> T <sub>j</sub> = 12°C	9.10 kW	9.00 kW
COP T <sub>j</sub> = 12°C	7.72	6.11
C <sub>dh</sub> T <sub>j</sub> = +12 °C	1.00	1.00
P <sub>dh</sub> T <sub>j</sub> = T <sub>biv</sub>	8.30 kW	8.40 kW
COP T <sub>j</sub> = T <sub>biv</sub>	4.14	2.74
P <sub>dh</sub> T <sub>j</sub> = TOL or P <sub>dh</sub> T <sub>j</sub> = T <sub>designh</sub> if TOL < T <sub>designh</sub>	16.90 kW	18.80 kW
COP T <sub>j</sub> = TOL or COP T <sub>j</sub> = T <sub>designh</sub> if TOL < T <sub>designh</sub>	2.61	2.31
WTOL	65 °C	65 °C
P <sub>off</sub>	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q <sub>he</sub>	1718 kWh	2369 kWh

## Model WPL 25 AC + HSBC 300 cool "Profile M"

Model name	WPL 25 AC + HSBC 300 cool "Profile M"
Application	Heating + DHW + low temp
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	M
Efficiency $\eta_{DHW}$	79 %
COP	1.72
Heating up time	1:53 h:min
Standby power input	79.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	350 l

#### Model WPL 25 AC + HSBC 300 cool "Profile XL"

Model name	WPL 25 AC + HSBC 300 cool "Profile XL"
Application	Heating + DHW + low temp
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

#### General data

Power supply	3x400V 50Hz
Off-peak product	n/a

#### Outdoor Air/Water

##### EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.60
Heating up time	1:49 h:min
Standby power input	79.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	362 l