

Subtype HA 7-5 OS 230V

Certificate Holder	Saunier Duval Brand Group
Address	
ZIP	
City	
Country	DE
Certification Body	VDE Prüf- und Zertifizierungsinstitut GmbH
Subtype title	HA 7-5 OS 230V
Registration number	40049301
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.39 kg
Certification Date	27.04.2021
Testing basis	DIN EN 14511-1:2019-07; EN 14511-1:2018; DIN EN 14511-2:2019-07; EN 14511-2:2018; DIN EN 14511-3:2019-07; EN 14511-3:2018; DIN EN 14511-4:2019-07; EN 14511-4:2018; DIN EN 14825:2019-07; EN 14825:2018; DIN EN 12102-1:2018-02; EN 12102-1:2017

Model HA 7-5 OS 230V + HA 7-5 WSB

Model name	HA 7-5 OS 230V + HA 7-5 WSB
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	173 %	133 %
Prated	7.08 kW	6.36 kW
SCOP	4.40	3.39
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.30 kW	5.62 kW
COP Tj = -7°C	2.58	2.00
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	3.90 kW	3.31 kW
COP Tj = +2°C	4.37	3.29
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	2.72 kW	2.69 kW
COP Tj = +7°C	5.86	4.62
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	3.28 kW	3.21 kW
COP Tj = 12°C	7.54	6.27
Cdh Tj = +12 °C	0.980	0.980
Pdh Tj = Tbiv	6.26 kW	5.62 kW

COP $T_j = T_{biv}$	2.57	2.00
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.66 kW	4.92 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.38	1.84
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.000	1.000
WTOL	55 °C	55 °C
P _{off}	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.42 kW	1.44 kW
Annual energy consumption Q _{he}	3324 kWh	3869 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	156 %	117 %
Prated	6.60 kW	5.36 kW
SCOP	3.96	3.00
T_{biv}	-15 °C	-15 °C
TOL	-20 °C	-15 °C
$P_{dh} T_j = -7^\circ\text{C}$	3.89 kW	3.55 kW
COP $T_j = -7^\circ\text{C}$	3.51	2.53
$C_{dh} T_j = -7^\circ\text{C}$	0.990	0.990
$P_{dh} T_j = +2^\circ\text{C}$	2.31 kW	2.33 kW
COP $T_j = +2^\circ\text{C}$	4.66	3.78
$C_{dh} T_j = +2^\circ\text{C}$	0.980	0.980
$P_{dh} T_j = +7^\circ\text{C}$	2.77 kW	2.77 kW
COP $T_j = +7^\circ\text{C}$	6.19	6.19
$C_{dh} T_j = +7^\circ\text{C}$	0.980	0.980
$P_{dh} T_j = 12^\circ\text{C}$	3.20 kW	3.25 kW
COP $T_j = 12^\circ\text{C}$	7.55	6.81
$C_{dh} T_j = +12^\circ\text{C}$	0.980	0.980
$P_{dh} T_j = T_{biv}$	5.39 kW	4.37 kW
COP $T_j = T_{biv}$	2.48	1.72
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.75 kW	4.37 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.09	1.72

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.60 kW	5.36 kW
Annual energy consumption Qhe	4106 kWh	4401 kWh
Pdh Tj = -15°C (if TOL	3.36	4.37
COP Tj = -15°C (if TOL	1.94	1.72
Cdh Tj = -15 °C	0.990	1.000

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	239 %	159 %
Prated	4.51 kW	3.94 kW
SCOP	6.04	4.05
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.51 kW	3.94 kW
COP Tj = +2°C	3.68	2.30
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	2.81 kW	2.45 kW
COP Tj = +7°C	5.55	3.38
Cdh Tj = +7 °C	0.98	0.99
Pdh Tj = 12°C	3.20 kW	3.15 kW
COP Tj = 12°C	7.35	5.43
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	4.51 kW	3.94 kW
COP Tj = Tbiv	3.68	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.51 kW	3.94 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.68	2.30
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	11 W	11 W

PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	997 kWh	1300 kWh

Model HA 7-5 OS 230V + HA 7-5 STB

Model name	HA 7-5 OS 230V + HA 7-5 STB
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	112 %
COP	2.73
Heating up time	01:45 h:min
Standby power input	80.0 W
Reference hot water temperature	50.7 °C
Mixed water at 40°C	246 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	102 %
COP	2.48
Heating up time	02:03 h:min
Standby power input	90.0 W
Reference hot water temperature	46.9 °C
Mixed water at 40°C	246 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	134 %
COP	3.26
Heating up time	01:28 h:min
Standby power input	70.0 W
Reference hot water temperature	51.2 °C
Mixed water at 40°C	242 l