

Subtype ECOGEO B/C 3 5-22kW

Certificate Holder	Ecoforest Geotermia S.L.
Address	Rúa das Pontes, 25
ZIP	36350
City	Nigrán (Pontevedra)
Country	ES
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	ECOGEO B/C 3 5-22kW
Registration number	011-1W0331
Heat Pump Type	Brine/Water
Refrigerant	R410A
Mass of Refrigerant	1.5 kg
Certification Date	28.05.2019

Model ecoGEO C3T 5-22kW

Model name	ecoGEO C3T 5-22kW
Application	Heating + DHW + low temp
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	Yes

Brine/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

Model ecoGEO C4T 5-22kW

Model name	ecoGEO C4T 5-22kW
Application	Heating + DHW + low temp
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	Yes

Brine/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

Model ecoGEO C3 5-22kW

Model name	ecoGEO C3 5-22kW
Application	Heating + DHW + low temp
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Brine/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

Model ecoGEO C4 5-22kW

Model name	ecoGEO C4 5-22kW
Application	Heating + DHW + low temp
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Brine/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	1.68
Heating up time	0:56:51 h:min
Standby power input	162.8 W
Reference hot water temperature	57.5 °C
Mixed water at 40°C	233 l

Model ecoGEO B3T 5-22kW

Model name	ecoGEO B3T 5-22kW
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	Yes

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	142 %
Prated	23.00 kW	20.00 kW
SCOP	4.71	3.77
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	20.07 kW	17.41 kW
COP Tj = -7°C	3.27	2.67
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	12.97 kW	10.69 kW
COP Tj = +2°C	4.86	3.60
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	8.50 kW	7.08 kW
COP Tj = +7°C	5.52	4.99
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.79 kW	3.76 kW
COP Tj = 12°C	5.19	4.38
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	24.76 kW	19.09 kW
COP Tj = Tbiv	3.77	2.90

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.76 kW	19.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	10085 kWh	10970 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	186 %	161 %
Prated	23.00 kW	20.00 kW
SCOP	4.86	4.22
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	13.83 kW	11.90 kW
COP Tj = -7°C	4.39	3.71
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	8.55 kW	7.38 kW
COP Tj = +2°C	5.18	4.66
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.62 kW	4.80 kW
COP Tj = +7°C	5.38	5.24
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.57 kW	3.55 kW
COP Tj = 12°C	4.94	5.55
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	24.76 kW	19.09 kW
COP Tj = Tbiv	3.77	2.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.76 kW	19.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	11672 kWh	11679 kWh
P _{dh} T _j = -15°C (if TOL	18.78	16.54
COP T _j = -15°C (if TOL	4.06	3.09
C _{dh} T _j = -15 °C	0.99	0.99

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	179 %	140 %
Prated	23.00 kW	20.00 kW
SCOP	4.67	3.70
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	24.76 kW	19.09 kW
COP T _j = +2°C	3.77	2.90
C _{dh} T _j = +2 °C	0.990	0.990
P _{dh} T _j = +7°C	14.91 kW	12.89 kW
COP T _j = +7°C	4.20	3.21
C _{dh} T _j = +7 °C	0.990	0.990
P _{dh} T _j = 12°C	6.56 kW	5.72 kW
COP T _j = 12°C	5.33	4.36
C _{dh} T _j = +12 °C	0.990	0.990
P _{dh} T _j = T _{biv}	24.76 kW	19.09 kW
COP T _j = T _{biv}	3.77	2.90
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	24.76 kW	19.09 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.77	2.90
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}		
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	6574 kWh	7228 kWh

Model ecoGEO B4T 5-22kW

Model name	ecoGEO B4T 5-22kW
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	Yes

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	142 %
Prated	23.00 kW	20.00 kW
SCOP	4.71	3.77
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	20.07 kW	17.41 kW
COP Tj = -7°C	3.27	2.67
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	12.97 kW	10.69 kW
COP Tj = +2°C	4.86	3.60
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	8.50 kW	7.08 kW
COP Tj = +7°C	5.52	4.99
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.79 kW	3.76 kW
COP Tj = 12°C	5.19	4.38
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	24.76 kW	19.09 kW
COP Tj = Tbiv	3.77	2.90

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.76 kW	19.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	10085 kWh	10970 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	186 %	161 %
Prated	23.00 kW	20.00 kW
SCOP	4.86	4.22
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	13.83 kW	11.90 kW
COP Tj = -7°C	4.39	3.71
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	8.55 kW	7.38 kW
COP Tj = +2°C	5.18	4.66
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.62 kW	4.80 kW
COP Tj = +7°C	5.38	5.24
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.57 kW	3.55 kW
COP Tj = 12°C	4.94	5.55
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	24.76 kW	19.09 kW
COP Tj = Tbiv	3.77	2.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.76 kW	19.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	11672 kWh	11679 kWh
P _{dh} T _j = -15°C (if TOL	18.78	16.54
COP T _j = -15°C (if TOL	4.06	3.09
C _{dh} T _j = -15 °C	0.99	0.99

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	179 %	140 %
Prated	23.00 kW	20.00 kW
SCOP	4.67	3.70
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	24.76 kW	19.09 kW
COP T _j = +2°C	3.77	2.90
C _{dh} T _j = +2 °C	0.990	0.990
P _{dh} T _j = +7°C	14.91 kW	12.89 kW
COP T _j = +7°C	4.20	3.21
C _{dh} T _j = +7 °C	0.990	0.990
P _{dh} T _j = 12°C	6.56 kW	5.72 kW
COP T _j = 12°C	5.33	4.36
C _{dh} T _j = +12 °C	0.990	0.990
P _{dh} T _j = T _{biv}	24.76 kW	19.09 kW
COP T _j = T _{biv}	3.77	2.90
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	24.76 kW	19.09 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.77	2.90
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}		
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	6574 kWh	7228 kWh

Model ecoGEO B3 5-22kW

Model name	ecoGEO B3 5-22kW
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	142 %
Prated	23.00 kW	20.00 kW
SCOP	4.71	3.77
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	20.07 kW	17.41 kW
COP Tj = -7°C	3.27	2.67
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	12.97 kW	10.69 kW
COP Tj = +2°C	4.86	3.60
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	8.50 kW	7.08 kW
COP Tj = +7°C	5.52	4.99
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.79 kW	3.76 kW
COP Tj = 12°C	5.19	4.38
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	24.76 kW	19.09 kW
COP Tj = Tbiv	3.77	2.90

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.76 kW	19.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	10085 kWh	10970 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	186 %	161 %
Prated	23.00 kW	20.00 kW
SCOP	4.86	4.22
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	13.83 kW	11.90 kW
COP Tj = -7°C	4.39	3.71
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	8.55 kW	7.38 kW
COP Tj = +2°C	5.18	4.66
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.62 kW	4.80 kW
COP Tj = +7°C	5.38	5.24
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.57 kW	3.55 kW
COP Tj = 12°C	4.94	5.55
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	24.76 kW	19.09 kW
COP Tj = Tbiv	3.77	2.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.76 kW	19.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	11672 kWh	11679 kWh
P _{dh} T _j = -15°C (if TOL	18.78	16.54
COP T _j = -15°C (if TOL	4.06	3.09
C _{dh} T _j = -15 °C	0.99	0.99

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	179 %	140 %
Prated	23.00 kW	20.00 kW
SCOP	4.67	3.70
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	24.76 kW	19.09 kW
COP T _j = +2°C	3.77	2.90
C _{dh} T _j = +2 °C	0.990	0.990
P _{dh} T _j = +7°C	14.91 kW	12.89 kW
COP T _j = +7°C	4.20	3.21
C _{dh} T _j = +7 °C	0.990	0.990
P _{dh} T _j = 12°C	6.56 kW	5.72 kW
COP T _j = 12°C	5.33	4.36
C _{dh} T _j = +12 °C	0.990	0.990
P _{dh} T _j = T _{biv}	24.76 kW	19.09 kW
COP T _j = T _{biv}	3.77	2.90
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	24.76 kW	19.09 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.77	2.90
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}		
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	6574 kWh	7228 kWh

Model ecoGEO B4 5-22kW

Model name	ecoGEO B4 5-22kW
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	142 %
Prated	23.00 kW	20.00 kW
SCOP	4.71	3.77
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	20.07 kW	17.41 kW
COP Tj = -7°C	3.27	2.67
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	12.97 kW	10.69 kW
COP Tj = +2°C	4.86	3.60
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	8.50 kW	7.08 kW
COP Tj = +7°C	5.52	4.99
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.79 kW	3.76 kW
COP Tj = 12°C	5.19	4.38
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	24.76 kW	19.09 kW
COP Tj = Tbiv	3.77	2.90

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.76 kW	19.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	10085 kWh	10970 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	186 %	161 %
Prated	23.00 kW	20.00 kW
SCOP	4.86	4.22
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	13.83 kW	11.90 kW
COP Tj = -7°C	4.39	3.71
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	8.55 kW	7.38 kW
COP Tj = +2°C	5.18	4.66
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.62 kW	4.80 kW
COP Tj = +7°C	5.38	5.24
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	3.57 kW	3.55 kW
COP Tj = 12°C	4.94	5.55
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	24.76 kW	19.09 kW
COP Tj = Tbiv	3.77	2.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	24.76 kW	19.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.77	2.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	11672 kWh	11679 kWh
P _{dh} T _j = -15°C (if TOL	18.78	16.54
COP T _j = -15°C (if TOL	4.06	3.09
C _{dh} T _j = -15 °C	0.99	0.99

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	179 %	140 %
Prated	23.00 kW	20.00 kW
SCOP	4.67	3.70
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	24.76 kW	19.09 kW
COP T _j = +2°C	3.77	2.90
C _{dh} T _j = +2 °C	0.990	0.990
P _{dh} T _j = +7°C	14.91 kW	12.89 kW
COP T _j = +7°C	4.20	3.21
C _{dh} T _j = +7 °C	0.990	0.990
P _{dh} T _j = 12°C	6.56 kW	5.72 kW
COP T _j = 12°C	5.33	4.36
C _{dh} T _j = +12 °C	0.990	0.990
P _{dh} T _j = T _{biv}	24.76 kW	19.09 kW
COP T _j = T _{biv}	3.77	2.90
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	24.76 kW	19.09 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.77	2.90
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}		
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	7 W	7 W
PSB	6 W	6 W
PCK	0 W	0 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	6574 kWh	7228 kWh