

Subtype Hi-Therma Monobloc 8kW

| | |
|---------------------|---|
| Certificate Holder | Qingdao Hisense Hitachi Air-conditioning Systems Co.,Ltd. |
| Address | Qianwangang Road |
| ZIP | 266555 |
| City | Qingdao, Shandong |
| Country | CN |
| Certification Body | BRE Global Limited |
| Subtype title | Hi-Therma Monobloc 8kW |
| Registration number | 041-K021-04 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R32 |
| Mass of Refrigerant | 1.21 kg |
| Certification Date | 01.03.2022 |
| Testing basis | Heat Pump Keymark Scheme Rules Rev 09 |

Model AHZ-080HCDS1

| | |
|-------------------------------------|-----------------------|
| Model name | AHZ-080HCDS1 |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water

EN 14511-4 | Heating

| | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 64 dB(A) | 64 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|-----------------|-----------------|--------------------|
| η_s | 197 % | 137 % |
| Prated | 6.52 kW | 6.07 kW |
| SCOP | 5.00 | 3.50 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 5.74 kW | 5.34 kW |
| COP Tj = -7°C | 3.09 | 2.18 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 3.47 kW | 3.11 kW |
| COP Tj = +2°C | 4.76 | 3.41 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = +7°C | 2.44 kW | 2.09 kW |
| COP Tj = +7°C | 6.65 | 4.36 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 1.48 kW | 1.23 kW |
| COP Tj = 12°C | 9.58 | 6.52 |
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 5.74 kW | 5.34 kW |
| COP Tj = Tbiv | 3.09 | 2.18 |

| | | |
|---|-------------|-------------|
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.14 kW | 5.81 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.84 | 1.72 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 60 °C | 60 °C |
| Poff | 10 W | 10 W |
| PTO | 11 W | 11 W |
| PSB | 10 W | 10 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.37 kW | 0.25 kW |
| Annual energy consumption Qhe | 2680 kWh | 3574 kWh |