

Subtype Sherpa S2 E 8/10

Certificate Holder	Olimpia Splendid S.p.A.
Address	Via Industriale, 1/3
ZIP	25060
City	Cellatica (BS)
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	Sherpa S2 E 8/10
Registration number	ICIM-PDC-000131-00
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	3.9 kg
Certification Date	10.12.2021
Testing basis	Heat Pump KEYMARK rev9

Model Sherpa S2 E 8

Model name	Sherpa S2 E 8
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	128 %
Prated	8.88 kW	7.92 kW
SCOP	4.78	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.85 kW	7.01 kW
COP Tj = -7°C	2.96	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.20 kW	4.46 kW
COP Tj = +2°C	4.55	3.19
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.33 kW	2.95 kW
COP Tj = +7°C	6.58	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.08 kW	1.38 kW
COP Tj = 12°C	8.66	5.11
Cdh Tj = +12 °C	0.900	0.900

Pdh Tj = Tbiv	7.85 kW	7.01 kW
COP Tj = Tbiv	2.96	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.45 kW	6.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	29 W	29 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.43 kW	1.30 kW
Annual energy consumption Qhe	3837 kWh	4988 kWh

Model Sherpa S2 E 10

Model name	Sherpa S2 E 10
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	128 %
Prated	8.88 kW	7.92 kW
SCOP	4.78	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.85 kW	7.01 kW
COP Tj = -7°C	2.96	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.20 kW	4.46 kW
COP Tj = +2°C	4.55	3.19
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.33 kW	2.95 kW
COP Tj = +7°C	6.58	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.08 kW	1.38 kW
COP Tj = 12°C	8.66	5.11
Cdh Tj = +12 °C	0.900	0.900

Pdh Tj = Tbiv	7.85 kW	7.01 kW
COP Tj = Tbiv	2.96	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.45 kW	6.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	29 W	29 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.43 kW	1.30 kW
Annual energy consumption Qhe	3837 kWh	4988 kWh

Model Sherpa Aquadue S2 E 8

Model name	Sherpa Aquadue S2 E 8
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	128 %
Prated	8.88 kW	7.92 kW
SCOP	4.78	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.85 kW	7.01 kW
COP Tj = -7°C	2.96	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.20 kW	4.46 kW
COP Tj = +2°C	4.55	3.19
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.33 kW	2.95 kW
COP Tj = +7°C	6.58	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.08 kW	1.38 kW
COP Tj = 12°C	8.66	5.11
Cdh Tj = +12 °C	0.900	0.900

Pdh Tj = Tbiv	7.85 kW	7.01 kW
COP Tj = Tbiv	2.96	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.45 kW	6.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	29 W	29 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.43 kW	1.30 kW
Annual energy consumption Qhe	3837 kWh	4988 kWh

Model Sherpa Aquadue S2 E 10

Model name	Sherpa Aquadue S2 E 10
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	128 %
Prated	8.88 kW	7.92 kW
SCOP	4.78	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.85 kW	7.01 kW
COP Tj = -7°C	2.96	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.20 kW	4.46 kW
COP Tj = +2°C	4.55	3.19
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.33 kW	2.95 kW
COP Tj = +7°C	6.58	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.08 kW	1.38 kW
COP Tj = 12°C	8.66	5.11
Cdh Tj = +12 °C	0.900	0.900

Pdh Tj = Tbiv	7.85 kW	7.01 kW
COP Tj = Tbiv	2.96	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.45 kW	6.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	29 W	29 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.43 kW	1.30 kW
Annual energy consumption Qhe	3837 kWh	4988 kWh

Model Sherpa Tower S2 E 8

Model name	Sherpa Tower S2 E 8
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	128 %
Prated	8.88 kW	7.92 kW
SCOP	4.78	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.85 kW	7.01 kW
COP Tj = -7°C	2.96	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.20 kW	4.46 kW
COP Tj = +2°C	4.55	3.19
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.33 kW	2.95 kW
COP Tj = +7°C	6.58	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.08 kW	1.38 kW
COP Tj = 12°C	8.66	5.11
Cdh Tj = +12 °C	0.900	0.900

Pdh Tj = Tbiv	7.85 kW	7.01 kW
COP Tj = Tbiv	2.96	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.45 kW	6.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	29 W	29 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.43 kW	1.30 kW
Annual energy consumption Qhe	3837 kWh	4988 kWh

Model Sherpa Tower S2 E 10

Model name	Sherpa Tower S2 E 10
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	128 %
Prated	8.88 kW	7.92 kW
SCOP	4.78	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.85 kW	7.01 kW
COP Tj = -7°C	2.96	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.20 kW	4.46 kW
COP Tj = +2°C	4.55	3.19
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.33 kW	2.95 kW
COP Tj = +7°C	6.58	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.08 kW	1.38 kW
COP Tj = 12°C	8.66	5.11
Cdh Tj = +12 °C	0.900	0.900

Pdh Tj = Tbiv	7.85 kW	7.01 kW
COP Tj = Tbiv	2.96	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.45 kW	6.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	29 W	29 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.43 kW	1.30 kW
Annual energy consumption Qhe	3837 kWh	4988 kWh

Model Sherpa Aquadue Tower S2 E 8

Model name	Sherpa Aquadue Tower S2 E 8
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	128 %
Prated	8.88 kW	7.92 kW
SCOP	4.78	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.85 kW	7.01 kW
COP Tj = -7°C	2.96	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.20 kW	4.46 kW
COP Tj = +2°C	4.55	3.19
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.33 kW	2.95 kW
COP Tj = +7°C	6.58	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.08 kW	1.38 kW
COP Tj = 12°C	8.66	5.11
Cdh Tj = +12 °C	0.900	0.900

Pdh Tj = Tbiv	7.85 kW	7.01 kW
COP Tj = Tbiv	2.96	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.45 kW	6.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	29 W	29 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.43 kW	1.30 kW
Annual energy consumption Qhe	3837 kWh	4988 kWh

Model Sherpa Aquadue Tower S2 E 10

Model name	Sherpa Aquadue Tower S2 E 10
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	30.10.2025

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	128 %
Prated	8.88 kW	7.92 kW
SCOP	4.78	3.28
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.85 kW	7.01 kW
COP Tj = -7°C	2.96	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.20 kW	4.46 kW
COP Tj = +2°C	4.55	3.19
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.33 kW	2.95 kW
COP Tj = +7°C	6.58	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.08 kW	1.38 kW
COP Tj = 12°C	8.66	5.11
Cdh Tj = +12 °C	0.900	0.900

Pdh Tj = Tbiv	7.85 kW	7.01 kW
COP Tj = Tbiv	2.96	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.45 kW	6.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	29 W	29 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.43 kW	1.30 kW
Annual energy consumption Qhe	3837 kWh	4988 kWh