

Subtype Sherpa S3 E 4 - 6

Certificate Holder	Olimpia Splendid S.p.A.
Address	Via Industriale, 1/3
ZIP	25060
City	Cellatica (BS)
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	Sherpa S3 E 4 - 6
Registration number	ICIM-PDC-000182
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	23.01.2023
Testing basis	Heat Pump KEYMARK V11

Model SHERPA S3 E 4 - SHERPA AQUADUE S3 E 4

Model name	SHERPA S3 E 4 - SHERPA AQUADUE S3 E 4
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	191 %	130 %
Prated	5.50 kW	4.40 kW
SCOP	4.85	3.31
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.88 kW	3.89 kW
COP Tj = -7°C	3.19	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.05 kW	2.38 kW
COP Tj = +2°C	4.78	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.93 kW	2.70 kW
COP Tj = +7°C	6.13	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.48 kW	1.32 kW
COP Tj = 12°C	8.05	5.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.88 kW	3.89 kW

COP Tj = Tbiv	3.19	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.41 kW	3.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.11 kW	0.98 kW
Annual energy consumption Qhe	2351 kWh	2742 kWh

Model SHERPA S3 E 6 - SHERPA AQUADUE S3 E 6

Model name	SHERPA S3 E 6 - SHERPA AQUADUE S3 E 6
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	138 %
Prated	6.80 kW	5.70 kW
SCOP	4.95	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.03 kW	5.04 kW
COP Tj = -7°C	3.09	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.88 kW	3.12 kW
COP Tj = +2°C	4.85	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.39 kW	2.08 kW
COP Tj = +7°C	6.63	4.54
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.39 kW	1.28 kW
COP Tj = 12°C	7.93	5.59
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.03 kW	5.04 kW

COP $T_j = T_{biv}$	3.09	2.17
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	5.36 kW	4.52 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.76	1.91
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.900	0.900
WTOL	65 °C	65 °C
P _{off}	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.18 kW
Annual energy consumption Q _{he}	2845 kWh	3343 kWh