

Subtype S-Therm Ontario SMH-140

Certificate Holder	SINCLAIR Global Group s.r.o.
Address	Purkyňova 45
ZIP	61200
City	Brno
Country	CZ
Certification Body	BRE Global Limited
Subtype title	S-Therm Ontario SMH-140
Registration number	041-K037-15
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	2.2 kg
Certification Date	28.02.2023
Testing basis	Heat Pump Keymark Scheme Rules Rev 11

Model SMH-140IRB2

Model name	SMH-140IRB2
Application	Heating + DHW
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l

Model SMH-140IRB2-3

Model name	SMH-140IRB2-3
Application	Heating + DHW
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l