

Subtype 10. Yutaki M 2.0HP R32

Certificate Holder	Johnson Controls-Hitachi AirConditioning Spain
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella
ZIP	08233
City	Vacarisses, Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	10. Yutaki M 2.0HP R32
Registration number	041-K002-38
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.2 kg
Certification Date	02.08.2019

Model 01. RASM-2VRE - Heating Only

Model name	01. RASM-2VRE - Heating Only
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	133 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1798 kWh	2401 kWh

Model 02. RASM-2VRE - with cooling kit

Model name	02. RASM-2VRE - with cooling kit
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	4.00 kW	4.00 kW
SCOP	4.73	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.00 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1754 kWh	2357 kWh