

Subtype 19. Yutaki M 4.0HP (mono)

Certificate Holder	Johnson Controls-Hitachi AirConditioning Spain
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella
ZIP	08233
City	Vacarisses, Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	19. Yutaki M 4.0HP (mono)
Registration number	041-K002-19
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.8 kg

Model RASM-4VNE - Heating Only

Model name	RASM-4VNE - Heating Only
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	187 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.75	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.60 kW	8.60 kW
COP Tj = -7°C	2.74	1.80
Pdh Tj = +2°C	5.84 kW	5.23 kW
COP Tj = +2°C	5.20	3.60
Pdh Tj = +7°C	3.76 kW	3.52 kW
COP Tj = +7°C	5.80	4.80
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	6.40	5.80
Pdh Tj = Tbiv	9.60 kW	8.60 kW
COP Tj = Tbiv	2.74	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	8.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90

WTOL	55 °C	55 °C
Poff	13 W	13 W
PTO	0 W	0 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	4714 kWh	5786 kWh

Model RASM-4VNE - with cooling kit

Model name	RASM-4VNE - with cooling kit
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	137 %
Prated	11.00 kW	10.00 kW
SCOP	4.80	3.50
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.60 kW	8.60 kW
COP Tj = -7°C	2.74	1.80
Pdh Tj = +2°C	5.84 kW	5.23 kW
COP Tj = +2°C	5.20	3.60
Pdh Tj = +7°C	3.76 kW	3.52 kW
COP Tj = +7°C	5.80	4.80
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	6.40	5.80
Pdh Tj = Tbiv	9.60 kW	8.60 kW
COP Tj = Tbiv	2.74	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	8.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90

WTOL	55 °C	55 °C
Poff	13 W	13 W
PTO	0 W	0 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	1.20 kW
Annual energy consumption Qhe	4666 kWh	5738 kWh