

This information was generated by the HP KEYMARK database on 25 Feb 2023

	NIMBUS/ARIANEXT/AEROTOP/ENERGION 35/50 M – COMPACT	Reg. No.	ICIM-PDC-000109
Certificate Holder			
	Ariston Thermo Group		
	Viale Aristide Merloni 45		I-60044
	Fabriano (AN)		Italy
Certification Body	ICIM S.p.A.		
Subtype title	NIMBUS/ARIANEXT/AEROTOP/ENERGION 35/50 M – COMPACT		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1 kg		
Certification Date	21.10.2022		
Testing basis	Heat Pump KEYMARK rev9		

Model: AEROTOP MONO 04.2 M-C2RX

Configure model

Model name	AEROTOP MONO 04.2 M-C2RX
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.50 kW	2.95 kW
El input	0.69 kW	1.09 kW
COP	5.10	2.70

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C
El input	1.03 kW
Cooling capacity	3.5

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	3.5 kW
SEER	4.87
P _{dc} T _j = 35°C	3.5 kW
EER T _j = 35°C	3
P _{dc} T _j = 30°C	2.58 kW
EER T _j = 30°C	4.33
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	1.72 kW
EER T _j = 25°C	5.86
C _{dc} T _j = 25 °C	0.95
P _{dc} T _j = 20°C	1.79 kW
EER T _j = 20°C	7.24
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	628 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.20 kW	4.63 kW
η_s	192 %	134 %
P _{rated}	5.20 kW	4.63 kW
SCOP	4.89	3.43
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.60 kW	4.10 kW
COP T _j = -7°C	3.21	2.28
C _{dh} T _j = -7 °C	0.991	0.993
P _{dh} T _j = +2°C	2.88 kW	2.63 kW
COP T _j = +2°C	4.66	3.35
C _{dh} T _j = +2 °C	0.979	0.983
P _{dh} T _j = +7°C	1.85 kW	1.76 kW
COP T _j = +7°C	6.56	4.22

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.954	0.969
Pdh Tj = 12°C	1.92 kW	1.88 kW
COP Tj = 12°C	8.49	6.30
Cdh Tj = +12 °C	0.942	0.956
Pdh Tj = Tbiv	4.60 kW	4.10 kW
COP Tj = Tbiv	3.21	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.03 kW	2.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.993
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.17 kW	2.17 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2198 kWh	2790 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:55 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: AEROTOP MONO 05.2 M-C2RX

Configure model	
Model name	AEROTOP MONO 05.2 M-C2RX
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.00 kW	3.80 kW
El input	1.00 kW	1.36 kW
COP	5.00	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2		
	+7°C/+12°C	+18°C/+23°C
El input	1.75 kW	
Cooling capacity	5	
EER	2.85	4.56

EN 14825		

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	5 kW
SEER	4.85
P _{dc} T _j = 35°C	5 kW
EER T _j = 35°C	2.85
P _{dc} T _j = 30°C	3.77 kW
EER T _j = 30°C	4.25
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	2.32 kW
EER T _j = 25°C	5.38
C _{dc} T _j = 25 °C	0.97
P _{dc} T _j = 20°C	1.87 kW
EER T _j = 20°C	7.85
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	925 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.65 kW	5.65 kW
η_s	183 %	136 %
P _{rated}	5.65 kW	5.65 kW
SCOP	4.66	3.48
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	5.00 kW	5.00 kW
COP T _j = -7°C	3.10	2.28
C _{dh} T _j = -7 °C	0.992	0.994
P _{dh} T _j = +2°C	3.11 kW	3.11 kW
COP T _j = +2°C	4.32	3.30
C _{dh} T _j = +2 °C	0.981	0.986
P _{dh} T _j = +7°C	1.96 kW	2.19 kW
COP T _j = +7°C	6.48	4.58

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.955	0.972
Pdh Tj = 12°C	1.86 kW	1.84 kW
COP Tj = 12°C	8.41	6.33
Cdh Tj = +12 °C	0.939	0.953
Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.10	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.69 kW	3.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.96 kW	2.47 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2505 kWh	3360 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:31 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: AEROTOP MONO 04.2 M-CRX 1Z

Configure model

Model name	AEROTOP MONO 04.2 M-CRX 1Z
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.50 kW	2.95 kW
El input	0.69 kW	1.09 kW
COP	5.10	2.70

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	1.03 kW
Cooling capacity	3.5

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	3.5 kW
SEER	4.87
P _{dc} T _j = 35°C	3.5 kW
EER T _j = 35°C	3
P _{dc} T _j = 30°C	2.58 kW
EER T _j = 30°C	4.33
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	1.72 kW
EER T _j = 25°C	5.86
C _{dc} T _j = 25 °C	0.95
P _{dc} T _j = 20°C	1.79 kW
EER T _j = 20°C	7.24
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	628 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.20 kW	4.63 kW
η_s	192 %	134 %
P _{rated}	5.20 kW	4.63 kW
SCOP	4.89	3.43
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.60 kW	4.10 kW
COP T _j = -7°C	3.21	2.28
C _{dh} T _j = -7 °C	0.991	0.993
P _{dh} T _j = +2°C	2.88 kW	2.63 kW
COP T _j = +2°C	4.66	3.35
C _{dh} T _j = +2 °C	0.979	0.983
P _{dh} T _j = +7°C	1.85 kW	1.76 kW
COP T _j = +7°C	6.56	4.22

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.954	0.969
Pdh Tj = 12°C	1.92 kW	1.88 kW
COP Tj = 12°C	8.49	6.30
Cdh Tj = +12 °C	0.942	0.956
Pdh Tj = Tbiv	4.60 kW	4.10 kW
COP Tj = Tbiv	3.21	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.03 kW	2.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.993
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.17 kW	2.17 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2198 kWh	2790 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:55 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: AEROTOP MONO 04.2 M-CRX 2Z

Configure model	
Model name	AEROTOP MONO 04.2 M-CRX 2Z
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.50 kW	2.95 kW
El input	0.69 kW	1.09 kW
COP	5.10	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C
El input	1.03 kW
Cooling capacity	3.5

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	3.5 kW
SEER	4.87
P _{dc} T _j = 35°C	3.5 kW
EER T _j = 35°C	3
P _{dc} T _j = 30°C	2.58 kW
EER T _j = 30°C	4.33
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	1.72 kW
EER T _j = 25°C	5.86
C _{dc} T _j = 25 °C	0.95
P _{dc} T _j = 20°C	1.79 kW
EER T _j = 20°C	7.24
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	628 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.20 kW	4.63 kW
η_s	192 %	134 %
P _{rated}	5.20 kW	4.63 kW
SCOP	4.89	3.43
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.60 kW	4.10 kW
COP T _j = -7°C	3.21	2.28
C _{dh} T _j = -7 °C	0.991	0.993
P _{dh} T _j = +2°C	2.88 kW	2.63 kW
COP T _j = +2°C	4.66	3.35
C _{dh} T _j = +2 °C	0.979	0.983
P _{dh} T _j = +7°C	1.85 kW	1.76 kW
COP T _j = +7°C	6.56	4.22

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.954	0.969
Pdh Tj = 12°C	1.92 kW	1.88 kW
COP Tj = 12°C	8.49	6.30
Cdh Tj = +12 °C	0.942	0.956
Pdh Tj = Tbiv	4.60 kW	4.10 kW
COP Tj = Tbiv	3.21	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.03 kW	2.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.993
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.17 kW	2.17 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2198 kWh	2790 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:55 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: AEROTOP MONO 05.2 M-CRX 1Z

Configure model

Model name	AEROTOP MONO 05.2 M-CRX 1Z
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	5.00 kW	3.80 kW
El input	1.00 kW	1.36 kW
COP	5.00	2.80

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.75 kW	
Cooling capacity	5	
EER	2.85	4.56

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	5 kW
SEER	4.85
P _{dc} T _j = 35°C	5 kW
EER T _j = 35°C	2.85
P _{dc} T _j = 30°C	3.77 kW
EER T _j = 30°C	4.25
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	2.32 kW
EER T _j = 25°C	5.38
C _{dc} T _j = 25 °C	0.97
P _{dc} T _j = 20°C	1.87 kW
EER T _j = 20°C	7.85
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	925 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.65 kW	5.65 kW
η_s	183 %	136 %
P _{rated}	5.65 kW	5.65 kW
SCOP	4.66	3.48
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	5.00 kW	5.00 kW
COP T _j = -7°C	3.10	2.28
C _{dh} T _j = -7 °C	0.992	0.994
P _{dh} T _j = +2°C	3.11 kW	3.11 kW
COP T _j = +2°C	4.32	3.30
C _{dh} T _j = +2 °C	0.981	0.986
P _{dh} T _j = +7°C	1.96 kW	2.19 kW
COP T _j = +7°C	6.48	4.58

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.955	0.972
Pdh Tj = 12°C	1.86 kW	1.84 kW
COP Tj = 12°C	8.41	6.33
Cdh Tj = +12 °C	0.939	0.953
Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.10	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.69 kW	3.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.96 kW	2.47 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2505 kWh	3360 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:31 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: AEROTOP MONO 05.2 M-CRX 2Z

Configure model	
Model name	AEROTOP MONO 05.2 M-CRX 2Z
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.00 kW	3.80 kW
El input	1.00 kW	1.36 kW
COP	5.00	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.75 kW	
Cooling capacity	5	
EER	2.85	4.56

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	5 kW
SEER	4.85
P _{dc} T _j = 35°C	5 kW
EER T _j = 35°C	2.85
P _{dc} T _j = 30°C	3.77 kW
EER T _j = 30°C	4.25
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	2.32 kW
EER T _j = 25°C	5.38
C _{dc} T _j = 25 °C	0.97
P _{dc} T _j = 20°C	1.87 kW
EER T _j = 20°C	7.85
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	925 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.65 kW	5.65 kW
η_s	183 %	136 %
P _{rated}	5.65 kW	5.65 kW
SCOP	4.66	3.48
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	5.00 kW	5.00 kW
COP T _j = -7°C	3.10	2.28
C _{dh} T _j = -7 °C	0.992	0.994
P _{dh} T _j = +2°C	3.11 kW	3.11 kW
COP T _j = +2°C	4.32	3.30
C _{dh} T _j = +2 °C	0.981	0.986
P _{dh} T _j = +7°C	1.96 kW	2.19 kW
COP T _j = +7°C	6.48	4.58

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.955	0.972
Pdh Tj = 12°C	1.86 kW	1.84 kW
COP Tj = 12°C	8.41	6.33
Cdh Tj = +12 °C	0.939	0.953
Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.10	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.69 kW	3.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.96 kW	2.47 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2505 kWh	3360 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:31 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: ARIANEXT COMPACT 35 M 2Z LINK R32

Configure model	
Model name	ARIANEXT COMPACT 35 M 2Z LINK R32
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.50 kW	2.95 kW
El input	0.69 kW	1.09 kW
COP	5.10	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C
El input	1.03 kW
Cooling capacity	3.5

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	3.5 kW
SEER	4.87
P _{dc} T _j = 35°C	3.5 kW
EER T _j = 35°C	3
P _{dc} T _j = 30°C	2.58 kW
EER T _j = 30°C	4.33
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	1.72 kW
EER T _j = 25°C	5.86
C _{dc} T _j = 25 °C	0.95
P _{dc} T _j = 20°C	1.79 kW
EER T _j = 20°C	7.24
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	628 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.20 kW	4.63 kW
η_s	192 %	134 %
P _{rated}	5.20 kW	4.63 kW
SCOP	4.89	3.43
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.60 kW	4.10 kW
COP T _j = -7°C	3.21	2.28
C _{dh} T _j = -7 °C	0.991	0.993
P _{dh} T _j = +2°C	2.88 kW	2.63 kW
COP T _j = +2°C	4.66	3.35
C _{dh} T _j = +2 °C	0.979	0.983
P _{dh} T _j = +7°C	1.85 kW	1.76 kW
COP T _j = +7°C	6.56	4.22

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.954	0.969
Pdh Tj = 12°C	1.92 kW	1.88 kW
COP Tj = 12°C	8.49	6.30
Cdh Tj = +12 °C	0.942	0.956
Pdh Tj = Tbiv	4.60 kW	4.10 kW
COP Tj = Tbiv	3.21	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.03 kW	2.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.993
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.17 kW	2.17 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2198 kWh	2790 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:55 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: ARIANEXT COMPACT 35 M LINK R32

Configure model	
Model name	ARIANEXT COMPACT 35 M LINK R32
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.50 kW	2.95 kW
El input	0.69 kW	1.09 kW
COP	5.10	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C
El input	1.03 kW
Cooling capacity	3.5

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	3.5 kW
SEER	4.87
P _{dc} T _j = 35°C	3.5 kW
EER T _j = 35°C	3
P _{dc} T _j = 30°C	2.58 kW
EER T _j = 30°C	4.33
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	1.72 kW
EER T _j = 25°C	5.86
C _{dc} T _j = 25 °C	0.95
P _{dc} T _j = 20°C	1.79 kW
EER T _j = 20°C	7.24
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	628 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.20 kW	4.63 kW
η_s	192 %	134 %
P _{rated}	5.20 kW	4.63 kW
SCOP	4.89	3.43
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.60 kW	4.10 kW
COP T _j = -7°C	3.21	2.28
C _{dh} T _j = -7 °C	0.991	0.993
P _{dh} T _j = +2°C	2.88 kW	2.63 kW
COP T _j = +2°C	4.66	3.35
C _{dh} T _j = +2 °C	0.979	0.983
P _{dh} T _j = +7°C	1.85 kW	1.76 kW
COP T _j = +7°C	6.56	4.22

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.954	0.969
Pdh Tj = 12°C	1.92 kW	1.88 kW
COP Tj = 12°C	8.49	6.30
Cdh Tj = +12 °C	0.942	0.956
Pdh Tj = Tbiv	4.60 kW	4.10 kW
COP Tj = Tbiv	3.21	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.03 kW	2.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.993
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.17 kW	2.17 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2198 kWh	2790 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:55 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: ARIANEXT COMPACT 50 M 2Z LINK R32

Configure model	
Model name	ARIANEXT COMPACT 50 M 2Z LINK R32
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.00 kW	3.80 kW
El input	1.00 kW	1.36 kW
COP	5.00	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.75 kW	
Cooling capacity	5	
EER	2.85	4.56

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	5 kW
SEER	4.85
P _{dc} T _j = 35°C	5 kW
EER T _j = 35°C	2.85
P _{dc} T _j = 30°C	3.77 kW
EER T _j = 30°C	4.25
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	2.32 kW
EER T _j = 25°C	5.38
C _{dc} T _j = 25 °C	0.97
P _{dc} T _j = 20°C	1.87 kW
EER T _j = 20°C	7.85
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	925 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.65 kW	5.65 kW
η_s	183 %	136 %
P _{rated}	5.65 kW	5.65 kW
SCOP	4.66	3.48
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	5.00 kW	5.00 kW
COP T _j = -7°C	3.10	2.28
C _{dh} T _j = -7 °C	0.992	0.994
P _{dh} T _j = +2°C	3.11 kW	3.11 kW
COP T _j = +2°C	4.32	3.30
C _{dh} T _j = +2 °C	0.981	0.986
P _{dh} T _j = +7°C	1.96 kW	2.19 kW
COP T _j = +7°C	6.48	4.58

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.955	0.972
Pdh Tj = 12°C	1.86 kW	1.84 kW
COP Tj = 12°C	8.41	6.33
Cdh Tj = +12 °C	0.939	0.953
Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.10	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.69 kW	3.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.96 kW	2.47 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2505 kWh	3360 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:31 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: ARIANEXT COMPACT 50 M LINK R32

Configure model	
Model name	ARIANEXT COMPACT 50 M LINK R32
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.00 kW	3.80 kW
El input	1.00 kW	1.36 kW
COP	5.00	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.75 kW	
Cooling capacity	5	
EER	2.85	4.56

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	5 kW
SEER	4.85
P _{dc} T _j = 35°C	5 kW
EER T _j = 35°C	2.85
P _{dc} T _j = 30°C	3.77 kW
EER T _j = 30°C	4.25
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	2.32 kW
EER T _j = 25°C	5.38
C _{dc} T _j = 25 °C	0.97
P _{dc} T _j = 20°C	1.87 kW
EER T _j = 20°C	7.85
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	925 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.65 kW	5.65 kW
η_s	183 %	136 %
P _{rated}	5.65 kW	5.65 kW
SCOP	4.66	3.48
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	5.00 kW	5.00 kW
COP T _j = -7°C	3.10	2.28
C _{dh} T _j = -7 °C	0.992	0.994
P _{dh} T _j = +2°C	3.11 kW	3.11 kW
COP T _j = +2°C	4.32	3.30
C _{dh} T _j = +2 °C	0.981	0.986
P _{dh} T _j = +7°C	1.96 kW	2.19 kW
COP T _j = +7°C	6.48	4.58

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.955	0.972
Pdh Tj = 12°C	1.86 kW	1.84 kW
COP Tj = 12°C	8.41	6.33
Cdh Tj = +12 °C	0.939	0.953
Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.10	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.69 kW	3.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.96 kW	2.47 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2505 kWh	3360 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:31 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: ENERGION M COMPACT 40

Configure model	
Model name	ENERGION M COMPACT 40
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.50 kW	2.95 kW
El input	0.69 kW	1.09 kW
COP	5.10	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C
El input	1.03 kW
Cooling capacity	3.5

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	3.5 kW
SEER	4.87
P _{dc} T _j = 35°C	3.5 kW
EER T _j = 35°C	3
P _{dc} T _j = 30°C	2.58 kW
EER T _j = 30°C	4.33
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	1.72 kW
EER T _j = 25°C	5.86
C _{dc} T _j = 25 °C	0.95
P _{dc} T _j = 20°C	1.79 kW
EER T _j = 20°C	7.24
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	628 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.20 kW	4.63 kW
η_s	192 %	134 %
P _{rated}	5.20 kW	4.63 kW
SCOP	4.89	3.43
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.60 kW	4.10 kW
COP T _j = -7°C	3.21	2.28
C _{dh} T _j = -7 °C	0.991	0.993
P _{dh} T _j = +2°C	2.88 kW	2.63 kW
COP T _j = +2°C	4.66	3.35
C _{dh} T _j = +2 °C	0.979	0.983
P _{dh} T _j = +7°C	1.85 kW	1.76 kW
COP T _j = +7°C	6.56	4.22

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.954	0.969
Pdh Tj = 12°C	1.92 kW	1.88 kW
COP Tj = 12°C	8.49	6.30
Cdh Tj = +12 °C	0.942	0.956
Pdh Tj = Tbiv	4.60 kW	4.10 kW
COP Tj = Tbiv	3.21	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.03 kW	2.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.993
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.17 kW	2.17 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2198 kWh	2790 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:55 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: ENERGION M COMPACT 40 2Z

Configure model	
Model name	ENERGION M COMPACT 40 2Z
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.50 kW	2.95 kW
El input	0.69 kW	1.09 kW
COP	5.10	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C
El input	1.03 kW
Cooling capacity	3.5

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	3.5 kW
SEER	4.87
P _{dc} T _j = 35°C	3.5 kW
EER T _j = 35°C	3
P _{dc} T _j = 30°C	2.58 kW
EER T _j = 30°C	4.33
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	1.72 kW
EER T _j = 25°C	5.86
C _{dc} T _j = 25 °C	0.95
P _{dc} T _j = 20°C	1.79 kW
EER T _j = 20°C	7.24
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	628 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
$P_{designh}$	5.20 kW	4.63 kW
η_s	192 %	134 %
P_{rated}	5.20 kW	4.63 kW
SCOP	4.89	3.43
T_{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
$P_{dh} T_j = -7^{\circ}C$	4.60 kW	4.10 kW
$COP T_j = -7^{\circ}C$	3.21	2.28
$C_{dh} T_j = -7^{\circ}C$	0.991	0.993
$P_{dh} T_j = +2^{\circ}C$	2.88 kW	2.63 kW
$COP T_j = +2^{\circ}C$	4.66	3.35
$C_{dh} T_j = +2^{\circ}C$	0.979	0.983
$P_{dh} T_j = +7^{\circ}C$	1.85 kW	1.76 kW
$COP T_j = +7^{\circ}C$	6.56	4.22

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.954	0.969
Pdh Tj = 12°C	1.92 kW	1.88 kW
COP Tj = 12°C	8.49	6.30
Cdh Tj = +12 °C	0.942	0.956
Pdh Tj = Tbiv	4.60 kW	4.10 kW
COP Tj = Tbiv	3.21	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.03 kW	2.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.993
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.17 kW	2.17 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2198 kWh	2790 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:55 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: ENERGION M COMPACT 50

Configure model	
Model name	ENERGION M COMPACT 50
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.00 kW	3.80 kW
El input	1.00 kW	1.36 kW
COP	5.00	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.75 kW	
Cooling capacity	5	
EER	2.85	4.56

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	5 kW
SEER	4.85
P _{dc} T _j = 35°C	5 kW
EER T _j = 35°C	2.85
P _{dc} T _j = 30°C	3.77 kW
EER T _j = 30°C	4.25
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	2.32 kW
EER T _j = 25°C	5.38
C _{dc} T _j = 25 °C	0.97
P _{dc} T _j = 20°C	1.87 kW
EER T _j = 20°C	7.85
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	925 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.65 kW	5.65 kW
η_s	183 %	136 %
P _{rated}	5.65 kW	5.65 kW
SCOP	4.66	3.48
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	5.00 kW	5.00 kW
COP T _j = -7°C	3.10	2.28
C _{dh} T _j = -7 °C	0.992	0.994
P _{dh} T _j = +2°C	3.11 kW	3.11 kW
COP T _j = +2°C	4.32	3.30
C _{dh} T _j = +2 °C	0.981	0.986
P _{dh} T _j = +7°C	1.96 kW	2.19 kW
COP T _j = +7°C	6.48	4.58

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.955	0.972
Pdh Tj = 12°C	1.86 kW	1.84 kW
COP Tj = 12°C	8.41	6.33
Cdh Tj = +12 °C	0.939	0.953
Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.10	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.69 kW	3.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.96 kW	2.47 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2505 kWh	3360 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:31 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: ENERGION M COMPACT 50 2Z

Configure model	
Model name	ENERGION M COMPACT 50 2Z
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.00 kW	3.80 kW
El input	1.00 kW	1.36 kW
COP	5.00	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.75 kW	
Cooling capacity	5	
EER	2.85	4.56

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	5 kW
SEER	4.85
P _{dc} T _j = 35°C	5 kW
EER T _j = 35°C	2.85
P _{dc} T _j = 30°C	3.77 kW
EER T _j = 30°C	4.25
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	2.32 kW
EER T _j = 25°C	5.38
C _{dc} T _j = 25 °C	0.97
P _{dc} T _j = 20°C	1.87 kW
EER T _j = 20°C	7.85
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	925 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.65 kW	5.65 kW
η_s	183 %	136 %
P _{rated}	5.65 kW	5.65 kW
SCOP	4.66	3.48
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	5.00 kW	5.00 kW
COP T _j = -7°C	3.10	2.28
C _{dh} T _j = -7 °C	0.992	0.994
P _{dh} T _j = +2°C	3.11 kW	3.11 kW
COP T _j = +2°C	4.32	3.30
C _{dh} T _j = +2 °C	0.981	0.986
P _{dh} T _j = +7°C	1.96 kW	2.19 kW
COP T _j = +7°C	6.48	4.58

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.955	0.972
Pdh Tj = 12°C	1.86 kW	1.84 kW
COP Tj = 12°C	8.41	6.33
Cdh Tj = +12 °C	0.939	0.953
Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.10	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.69 kW	3.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.96 kW	2.47 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2505 kWh	3360 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:31 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: NIMBUS COMPACT 35 M 2Z NET R32

Configure model	
Model name	NIMBUS COMPACT 35 M 2Z NET R32
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.50 kW	2.95 kW
El input	0.69 kW	1.09 kW
COP	5.10	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C
El input	1.03 kW
Cooling capacity	3.5

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	3.5 kW
SEER	4.87
P _{dc} T _j = 35°C	3.5 kW
EER T _j = 35°C	3
P _{dc} T _j = 30°C	2.58 kW
EER T _j = 30°C	4.33
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	1.72 kW
EER T _j = 25°C	5.86
C _{dc} T _j = 25 °C	0.95
P _{dc} T _j = 20°C	1.79 kW
EER T _j = 20°C	7.24
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
P _{TO}	14 W
P _{SB}	14 W
P _{CK}	0 W
Annual energy consumption Q _{ce}	628 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.20 kW	4.63 kW
η_s	192 %	134 %
P _{rated}	5.20 kW	4.63 kW
SCOP	4.89	3.43
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.60 kW	4.10 kW
COP T _j = -7°C	3.21	2.28
C _{dh} T _j = -7 °C	0.991	0.993
P _{dh} T _j = +2°C	2.88 kW	2.63 kW
COP T _j = +2°C	4.66	3.35
C _{dh} T _j = +2 °C	0.979	0.983
P _{dh} T _j = +7°C	1.85 kW	1.76 kW
COP T _j = +7°C	6.56	4.22

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.954	0.969
Pdh Tj = 12°C	1.92 kW	1.88 kW
COP Tj = 12°C	8.49	6.30
Cdh Tj = +12 °C	0.942	0.956
Pdh Tj = Tbiv	4.60 kW	4.10 kW
COP Tj = Tbiv	3.21	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.03 kW	2.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.993
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.17 kW	2.17 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2198 kWh	2790 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:55 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: NIMBUS COMPACT 35 M NET R32

Configure model	
Model name	NIMBUS COMPACT 35 M NET R32
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.50 kW	2.95 kW
El input	0.69 kW	1.09 kW
COP	5.10	2.70

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C
El input	1.03 kW
Cooling capacity	3.5

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	3.5 kW
SEER	4.87
P _{dc} T _j = 35°C	3.5 kW
EER T _j = 35°C	3
P _{dc} T _j = 30°C	2.58 kW
EER T _j = 30°C	4.33
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	1.72 kW
EER T _j = 25°C	5.86
C _{dc} T _j = 25 °C	0.95
P _{dc} T _j = 20°C	1.79 kW
EER T _j = 20°C	7.24
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	628 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.20 kW	4.63 kW
η_s	192 %	134 %
P _{rated}	5.20 kW	4.63 kW
SCOP	4.89	3.43
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	4.60 kW	4.10 kW
COP T _j = -7°C	3.21	2.28
C _{dh} T _j = -7 °C	0.991	0.993
P _{dh} T _j = +2°C	2.88 kW	2.63 kW
COP T _j = +2°C	4.66	3.35
C _{dh} T _j = +2 °C	0.979	0.983
P _{dh} T _j = +7°C	1.85 kW	1.76 kW
COP T _j = +7°C	6.56	4.22

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.954	0.969
Pdh Tj = 12°C	1.92 kW	1.88 kW
COP Tj = 12°C	8.49	6.30
Cdh Tj = +12 °C	0.942	0.956
Pdh Tj = Tbiv	4.60 kW	4.10 kW
COP Tj = Tbiv	3.21	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.03 kW	2.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.25	1.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.991	0.993
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.17 kW	2.17 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2198 kWh	2790 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:55 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: NIMBUS COMPACT 50 M 2Z NET R32

Configure model	
Model name	NIMBUS COMPACT 50 M 2Z NET R32
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.00 kW	3.80 kW
El input	1.00 kW	1.36 kW
COP	5.00	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.75 kW	
Cooling capacity	5	
EER	2.85	4.56

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	5 kW
SEER	4.85
P _{dc} T _j = 35°C	5 kW
EER T _j = 35°C	2.85
P _{dc} T _j = 30°C	3.77 kW
EER T _j = 30°C	4.25
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	2.32 kW
EER T _j = 25°C	5.38
C _{dc} T _j = 25 °C	0.97
P _{dc} T _j = 20°C	1.87 kW
EER T _j = 20°C	7.85
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	925 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
$P_{designh}$	5.65 kW	5.65 kW
η_s	183 %	136 %
P_{rated}	5.65 kW	5.65 kW
SCOP	4.66	3.48
T_{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
$P_{dh} T_j = -7^{\circ}C$	5.00 kW	5.00 kW
$COP T_j = -7^{\circ}C$	3.10	2.28
$C_{dh} T_j = -7^{\circ}C$	0.992	0.994
$P_{dh} T_j = +2^{\circ}C$	3.11 kW	3.11 kW
$COP T_j = +2^{\circ}C$	4.32	3.30
$C_{dh} T_j = +2^{\circ}C$	0.981	0.986
$P_{dh} T_j = +7^{\circ}C$	1.96 kW	2.19 kW
$COP T_j = +7^{\circ}C$	6.48	4.58

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.955	0.972
Pdh Tj = 12°C	1.86 kW	1.84 kW
COP Tj = 12°C	8.41	6.33
Cdh Tj = +12 °C	0.939	0.953
Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.10	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.69 kW	3.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.96 kW	2.47 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2505 kWh	3360 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:31 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l

Model: NIMBUS COMPACT 50 M NET R32

Configure model	
Model name	NIMBUS COMPACT 50 M NET R32
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.00 kW	3.80 kW
El input	1.00 kW	1.36 kW
COP	5.00	2.80

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.75 kW	
Cooling capacity	5	
EER	2.85	4.56

EN 14825

This information was generated by the HP KEYMARK database on 25 Feb 2023

	+7°C/+12°C
P _{designc}	5 kW
SEER	4.85
P _{dc} T _j = 35°C	5 kW
EER T _j = 35°C	2.85
P _{dc} T _j = 30°C	3.77 kW
EER T _j = 30°C	4.25
C _{dc} T _j = 30 °C	0.98
P _{dc} T _j = 25°C	2.32 kW
EER T _j = 25°C	5.38
C _{dc} T _j = 25 °C	0.97
P _{dc} T _j = 20°C	1.87 kW
EER T _j = 20°C	7.85
C _{dc} T _j = 20 °C	0.94
P _{off}	14 W
PTO	14 W
PSB	14 W
PCK	0 W
Annual energy consumption Q _{ce}	925 kWh

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
P _{designh}	5.65 kW	5.65 kW
η_s	183 %	136 %
P _{rated}	5.65 kW	5.65 kW
SCOP	4.66	3.48
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	5.00 kW	5.00 kW
COP T _j = -7°C	3.10	2.28
C _{dh} T _j = -7 °C	0.992	0.994
P _{dh} T _j = +2°C	3.11 kW	3.11 kW
COP T _j = +2°C	4.32	3.30
C _{dh} T _j = +2 °C	0.981	0.986
P _{dh} T _j = +7°C	1.96 kW	2.19 kW
COP T _j = +7°C	6.48	4.58

This information was generated by the HP KEYMARK database on 25 Feb 2023

Cdh Tj = +7 °C	0.955	0.972
Pdh Tj = 12°C	1.86 kW	1.84 kW
COP Tj = 12°C	8.41	6.33
Cdh Tj = +12 °C	0.939	0.953
Pdh Tj = Tbiv	5.00 kW	5.00 kW
COP Tj = Tbiv	3.10	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.69 kW	3.18 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.994
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	13 W	13 W
PSB	13 W	13 W
PCK	13 W	13 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.96 kW	2.47 kW
Backup Heater	4.00 kW	4.00 kW
Annual energy consumption Qhe	2505 kWh	3360 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 25 Feb 2023

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	131 %
COP	3.10
Heating up time	01:31 h:min
Standby power input	38.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	233 l