

Subtype Ecodan Power Inverter 8-170D AA

Certificate Holder	Mitsubishi Electric Air Conditioning Systems Europe LTD
Address	Nettlehill Road, Houston Industrial Estate
ZIP	EH54 5EQ
City	Livingston
Country	GB
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
Subtype title	Ecodan Power Inverter 8-170D AA
Registration number	037-0010-20
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	3 kg
Certification Date	14.02.2020
Testing basis	HP Keymark scheme rules rev. no. 6

Model PUAZ-SW75VAA + EHST17D-*M*D

Model name	PUAZ-SW75VAA + EHST17D-*M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	136 %
COP	3.21
Heating up time	02:20 h:min
Standby power input	39.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.82 kW	3.03 kW
COP	4.40	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	129 %
Prated	7.20 kW	7.10 kW
SCOP	4.12	3.31

Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.40 kW	6.30 kW
COP Tj = -7°C	2.43	2.04
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.90 kW	3.80 kW
COP Tj = +2°C	4.10	3.19
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.60 kW	2.90 kW
COP Tj = +7°C	5.62	4.59
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	3.10 kW	2.80 kW
COP Tj = 12°C	7.93	6.10
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.40 kW	6.30 kW
COP Tj = Tbiv	2.43	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.22 kW	6.14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.00 kW
Annual energy consumption Qhe	3607 kWh	4435 kWh

Model PUHZ-SW75VAA + ERST17D-*M*D

Model name	PUHZ-SW75VAA + ERST17D-*M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	136 %
COP	3.21
Heating up time	02:20 h:min
Standby power input	39.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.82 kW	3.03 kW
COP	4.40	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	166 %	132 %
Prated	7.20 kW	7.10 kW

SCOP	4.22	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.40 kW	6.30 kW
COP Tj = -7°C	2.43	2.04
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.90 kW	3.80 kW
COP Tj = +2°C	4.16	3.23
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.60 kW	2.90 kW
COP Tj = +7°C	5.62	4.59
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	3.10 kW	2.80 kW
COP Tj = 12°C	7.93	6.10
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.40 kW	6.30 kW
COP Tj = Tbiv	2.43	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.22 kW	6.14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.00 kW
Annual energy consumption Qhe	3525 kWh	4325 kWh

Model PUHZ-SW75YAA + EHST17D-*M*D

Model name	PUHZ-SW75YAA + EHST17D-*M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	136 %
COP	3.21
Heating up time	02:20 h:min
Standby power input	39.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.82 kW	3.03 kW
COP	4.40	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	160 %	128 %
Prated	7.20 kW	7.10 kW
SCOP	4.07	3.28

Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.40 kW	6.30 kW
COP Tj = -7°C	2.43	2.04
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.90 kW	3.80 kW
COP Tj = +2°C	4.07	3.19
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.60 kW	2.90 kW
COP Tj = +7°C	5.62	4.59
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	3.10 kW	2.80 kW
COP Tj = 12°C	7.93	6.10
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.40 kW	6.30 kW
COP Tj = Tbiv	2.43	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.22 kW	6.14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.00 kW
Annual energy consumption Qhe	3654 kWh	4470 kWh

Model PUHZ-SW75YAA + ERST17D-*M*D

Model name	PUHZ-SW75YAA + ERST17D-*M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	136 %
COP	3.21
Heating up time	02:20 h:min
Standby power input	39.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.82 kW	3.03 kW
COP	4.40	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	132 %
Prated	7.20 kW	7.10 kW

SCOP	4.20	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.40 kW	6.30 kW
COP Tj = -7°C	2.43	2.04
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.90 kW	3.80 kW
COP Tj = +2°C	4.14	3.23
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.60 kW	2.90 kW
COP Tj = +7°C	5.62	4.59
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	3.10 kW	2.80 kW
COP Tj = 12°C	7.93	6.10
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.40 kW	6.30 kW
COP Tj = Tbiv	2.54	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.22 kW	6.14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.00 kW
Annual energy consumption Qhe	3542 kWh	4361 kWh

Model PUHZ-SW75YAA + ERST17D-*M*BD

Model name	PUHZ-SW75YAA + ERST17D-*M*BD
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	n/a
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	136 %
COP	3.21
Heating up time	02:20 h:min
Standby power input	39.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.82 kW	3.03 kW
COP	4.40	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	132 %
Prated	7.20 kW	7.10 kW

SCOP	4.20	3.36
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.40 kW	6.30 kW
COP Tj = -7°C	2.43	2.04
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.90 kW	3.80 kW
COP Tj = +2°C	4.14	3.23
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.60 kW	2.90 kW
COP Tj = +7°C	5.62	4.59
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	3.10 kW	2.80 kW
COP Tj = 12°C	7.93	6.10
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.40 kW	6.30 kW
COP Tj = Tbiv	2.43	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.22 kW	6.14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.00 kW
Annual energy consumption Qhe	3542 kWh	4361 kWh

Model PUHZ-SW75VAA + ERST17D-*M*BD

Model name	PUHZ-SW75VAA + ERST17D-*M*BD
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	136 %
COP	3.21
Heating up time	02:20 h:min
Standby power input	39.0 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	236 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.82 kW	3.03 kW
COP	4.40	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	166 %	132 %
Prated	7.20 kW	7.10 kW

SCOP	4.22	3.37
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	6.40 kW	6.30 kW
COP Tj = -7°C	2.43	2.04
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.90 kW	3.80 kW
COP Tj = +2°C	4.16	3.23
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.60 kW	2.90 kW
COP Tj = +7°C	5.62	4.59
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	3.10 kW	2.80 kW
COP Tj = 12°C	7.93	6.10
Cdh Tj = +12 °C	0.960	0.970
Pdh Tj = Tbiv	6.40 kW	6.30 kW
COP Tj = Tbiv	2.43	2.04
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.22 kW	6.14 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.17	1.89
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.00 kW
Annual energy consumption Qhe	3525 kWh	4325 kWh