

Subtype DAIKIN ALTHERMA 3 R F 6KW (230L) /A

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA 3 R F 6KW (230L) /A
Registration number	011-1W0247
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	27.03.2018

Model ERGA06DVA / EHVH08S23D6V(G)

Model name	ERGA06DVA / EHVH08S23D6V(G)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	133 %
COP	3.30
Heating up time	1:47 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.25

Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.00 kW	6.10 kW
COP Tj = Tbiv	2.49	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3233 kWh	4456 kWh

Model ERGA06DVA / EHVH08S23D9W(G)

Model name	ERGA06DVA / EHVH08S23D9W(G)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	133 %
COP	3.30
Heating up time	1:47 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.25

Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.00 kW	6.10 kW
COP Tj = Tbiv	2.49	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3233 kWh	4456 kWh

Model ERGA06DVA / EHVX08S23D6V(G)

Model name	ERGA06DVA / EHVX08S23D6V(G)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	133 %
COP	3.30
Heating up time	1:47 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW

SCOP	4.52	3.27
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.00 kW	6.10 kW
COP Tj = Tbiv	2.49	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3196 kWh	4419 kWh

Model ERGA06DVA / EHVX08S23D9W(G)

Model name	ERGA06DVA / EHVX08S23D9W(G)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	133 %
COP	3.30
Heating up time	1:47 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW

SCOP	4.52	3.27
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.00 kW	6.10 kW
COP Tj = Tbiv	2.49	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3196 kWh	4419 kWh

Model ERGA06EVA / EHVX08S23E6V(G)

Model name	ERGA06EVA / EHVX08S23E6V(G)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	133 %
COP	3.30
Heating up time	1:47 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.55 kW	
Cooling capacity	5.09	
EER	3.28	

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

Sound power level outdoor	60 dB(A)	60 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW
SCOP	4.52	3.27
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.00 kW	6.10 kW
COP Tj = Tbiv	2.49	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3196 kWh	4419 kWh

EN 14825 Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	5.10 kW	
SEER	5.73	
Pdc Tj = 35°C	5.09 kW	
EER Tj = 35°C	3.28	
Pdc Tj = 30°C	3.75 kW	
EER Tj = 30°C	4.93	

Cdc Tj = 30 °C	1.0
Pdc Tj = 25°C	2.47 kW
EER Tj = 25°C	6.86
Cdc Tj = 25 °C	1.0
Pdc Tj = 20°C	2.52 kW
EER Tj = 20°C	8.36
Cdc Tj = 20 °C	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	533 kWh

Model ERGA06EVA / EHVX08S23E9W

Model name	ERGA06EVA / EHVX08S23E9W
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	133 %
COP	3.30
Heating up time	1:47 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.55 kW	
Cooling capacity	5.09	
EER	3.28	

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)

Sound power level outdoor	60 dB(A)	60 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
η_s	178 %	128 %
Prated	7.00 kW	7.00 kW
SCOP	4.52	3.27
Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.00 kW	6.10 kW
COP Tj = Tbiv	2.49	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3196 kWh	4419 kWh
EN 14825 Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	5.10 kW	
SEER	5.73	
Pdc Tj = 35°C	5.09 kW	
EER Tj = 35°C	3.28	
Pdc Tj = 30°C	3.75 kW	
EER Tj = 30°C	4.93	

Cdc Tj = 30 °C	1.0
Pdc Tj = 25°C	2.47 kW
EER Tj = 25°C	6.86
Cdc Tj = 25 °C	1.0
Pdc Tj = 20°C	2.52 kW
EER Tj = 20°C	8.36
Cdc Tj = 20 °C	1.0
Poff	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Qce	533 kWh

Model ERGA06EVA / EHVH08S23E9W

Model name	ERGA06EVA / EHVH08S23E9W
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	133 %
COP	3.30
Heating up time	1:47 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.25

Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.00 kW	6.10 kW
COP Tj = Tbiv	2.49	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3233 kWh	4456 kWh

Model ERGA06EVA / EHVH08SU23E6V

Model name	ERGA06EVA / EHVH08SU23E6V
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	133 %
COP	3.30
Heating up time	1:47 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	179 %	130 %
Prated	8.00 kW	8.00 kW
SCOP	4.56	3.32

Tbiv	-8 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	6.90 kW
COP Tj = -7°C	2.77	1.96
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	4.20 kW	4.40 kW
COP Tj = +2°C	4.35	3.20
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.30 kW
COP Tj = +7°C	6.49	4.64
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.90 kW	4.10 kW
COP Tj = 12°C	8.52	6.22
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	7.50 kW
COP Tj = Tbiv	2.66	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	7.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.64
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	0.90 kW
Annual energy consumption Qhe	3625 kWh	4975 kWh

Model ERGA06EVA / EHVH08S23E6V

Model name	ERGA06EVA / EHVH08S23E6V
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	133 %
COP	3.30
Heating up time	1:47 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.00 kW	5.80 kW
El input	1.24 kW	2.15 kW
COP	4.85	2.70

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.25

Tbiv	-6 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.00 kW	5.90 kW
COP Tj = -7°C	2.86	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.90 kW	3.90 kW
COP Tj = +2°C	4.25	3.16
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.30	4.49
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.00 kW	6.10 kW
COP Tj = Tbiv	2.49	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.00 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.49	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	2.50 kW
Annual energy consumption Qhe	3233 kWh	4456 kWh