

Subtype Alféa Excellia 11

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	Alféa Excellia 11
Registration number	012-002
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.5 kg
Certification Date	09.12.2022
Testing basis	EN 14511:2013, EN 16147:2011, EN 14825:2013, EN 12102:2013

Model Alféa Excellia 11

Model name	Alféa Excellia 11
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.80 kW	7.59 kW
El input	2.54 kW	3.07 kW
COP	4.25	2.47

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	151 %	112 %
Prated	11.30 kW	9.30 kW
SCOP	3.85	2.87
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.60	1.90
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.80
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.30	3.80

Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	6.90	4.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.00 kW	8.20 kW
COP Tj = Tbiv	2.60	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	8.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.20	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	45 W	22 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	1.30 kW
Annual energy consumption Qhe	6062 kWh	6623 kWh

Model Alféa Excellia A.I. 11

Model name	Alféa Excellia A.I. 11
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.80 kW	7.59 kW
El input	2.54 kW	3.07 kW
COP	4.25	2.47

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	151 %	112 %
Prated	11.30 kW	9.30 kW
SCOP	3.85	2.87
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.60	1.90
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.80
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.30	3.80

Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	6.90	4.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.00 kW	8.20 kW
COP Tj = Tbiv	2.60	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	8.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.20	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	45 W	22 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	1.30 kW
Annual energy consumption Qhe	6062 kWh	6623 kWh

Model Alféa Excellia Duo 11

Model name	Alféa Excellia Duo 11
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	88 %
COP	2.25
Heating up time	0:46 h:min
Standby power input	40.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	250 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.80 kW	7.59 kW
El input	2.54 kW	3.07 kW
COP	4.25	2.47

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	151 %	112 %
Prated	11.30 kW	9.30 kW
SCOP	3.85	2.87
Tbiv	-7 °C	-7 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.60	1.90
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.80
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.30	3.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	6.90	4.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.00 kW	8.20 kW
COP Tj = Tbiv	2.60	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	8.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.20	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	45 W	22 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	1.30 kW
Annual energy consumption Qhe	6062 kWh	6623 kWh

Model Alféa Excellia Duo A.I. 11

Model name	Alféa Excellia Duo A.I. 11
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	88 %
COP	2.25
Heating up time	0:46 h:min
Standby power input	40.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	250 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.80 kW	7.59 kW
El input	2.54 kW	3.07 kW
COP	4.25	2.47

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	151 %	112 %
Prated	11.30 kW	9.30 kW
SCOP	3.85	2.87
Tbiv	-7 °C	-7 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.60	1.90
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.80
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.30	3.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	7.40 kW	7.00 kW
COP Tj = 12°C	6.90	4.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.00 kW	8.20 kW
COP Tj = Tbiv	2.60	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	8.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.20	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	45 W	22 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	1.30 kW
Annual energy consumption Qhe	6062 kWh	6623 kWh