

Subtype DAIKIN ALTHERMA 3 R 7 ECH2O 04KW (500L)

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA 3 R 7 ECH2O 04KW (500L)
Registration number	011-1W0368
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	09.04.2020
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 9 (as of 2021-03)

Model ERGA04EV7 / EHSX04P50D3

Model name	ERGA04EV7 / EHSX04P50D3
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	106 %
COP	2.57
Heating up time	2:47 h:min
Standby power input	38.2 W
Reference hot water temperature	45.2 °C
Mixed water at 40°C	237 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.00 kW	6.00 kW

SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	5.30 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.00	
Pdh Tj = +2°C	3.70 kW	3.30 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.20 kW	5.30 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.22 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh

Model ERGA04EV7 / EHSXB04P50D3

Model name	ERGA04EV7 / EHSXB04P50D3
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.66
Heating up time	2:29 h:min
Standby power input	42.0 W
Reference hot water temperature	45.0 °C
Mixed water at 40°C	211 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.00 kW	6.00 kW

SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	5.30 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.00	
Pdh Tj = +2°C	3.70 kW	3.30 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.20 kW	5.30 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.22 kW	4.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.80 kW	2.00 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh

Model ERGA04EV7 / EHSX(B)04P50E

Model name	ERGA04EV7 / EHSX(B)04P50E
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	125 %
COP	3.06
Heating up time	2:41 h:min
Standby power input	25.3 W
Reference hot water temperature	44.6 °C
Mixed water at 40°C	227.9 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	129 %
Prated	6.0 kW	6.0 kW

SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh