

Subtype 03. Yutaki S & S Combi 3.0HP

Certificate Holder	Johnson Controls-Hitachi AirConditioning Spain
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella
ZIP	08233
City	Vacarisses, Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	03. Yutaki S & S Combi 3.0HP
Registration number	041-K002-03
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	1.7 kg

Model RAS-3WHVNP RWM-3.0NE - Heating Only

Model name	RAS-3WHVNP RWM-3.0NE - Heating Only
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	125 %
Prated	7.00 kW	6.00 kW
SCOP	4.20	3.20
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW

COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3286 kWh	3724 kWh

Model RAS-3WHVNP RWD-3.0NWE-200S - Heating Only

Model name	RAS-3WHVNP RWD-3.0NWE-200S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	132 %
COP	3.30
Heating up time	1:43 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	125 %
Prated	7.00 kW	6.00 kW
SCOP	4.20	3.20

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3286 kWh	3724 kWh

Model RAS-3WHVNP RWD-3.0NWE-260S - Heating Only

Model name	RAS-3WHVNP RWD-3.0NWE-260S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	125 %
Prated	7.00 kW	6.00 kW
SCOP	4.20	3.20

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3286 kWh	3724 kWh

Model RAS-3WHVNP RWD-3.0NWE-200S-K - UK- Heating Only

Model name	RAS-3WHVNP RWD-3.0NWE-200S-K - UK- Heating Only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	132 %
COP	3.30
Heating up time	1:43 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	125 %
Prated	7.00 kW	6.00 kW
SCOP	4.20	3.20

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3286 kWh	3724 kWh

Model RAS-3WHVNP RWD-3.0NWE-260S-K - UK- Heating Only

Model name	RAS-3WHVNP RWD-3.0NWE-260S-K - UK- Heating Only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	125 %
Prated	7.00 kW	6.00 kW
SCOP	4.20	3.20

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3286 kWh	3724 kWh

Model RAS-3WHVNP RWD-3.0NWSE-260S - Solar - Heating Only

Model name	RAS-3WHVNP RWD-3.0NWSE-260S - Solar - Heating Only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	125 %
Prated	7.00 kW	6.00 kW
SCOP	4.20	3.20

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3286 kWh	3724 kWh

Model RAS-3WHVNP RWM-3.0NE - with cooling kit

Model name	RAS-3WHVNP RWM-3.0NE - with cooling kit
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	167 %	127 %
Prated	7.00 kW	6.00 kW
SCOP	4.25	3.25
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW

COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3242 kWh	3690 kWh

Model RAS-3WHVNP RWD-3.0NWE-200S - with cooling kit

Model name	RAS-3WHVNP RWD-3.0NWE-200S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	132 %
COP	3.30
Heating up time	1:43 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	263 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	167 %	127 %
Prated	7.00 kW	6.00 kW
SCOP	4.25	3.25

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3242 kWh	3690 kWh

Model RAS-3WHVNP RWD-3.0NWE-260S - with cooling kit

Model name	RAS-3WHVNP RWD-3.0NWE-260S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	167 %	127 %
Prated	7.00 kW	6.00 kW
SCOP	4.25	3.25

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3242 kWh	3690 kWh

Model RAS-3WHVNP RWD-3.0NWSE-260S - Solar - with cooling kit

Model name	RAS-3WHVNP RWD-3.0NWSE-260S - Solar - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:10 h:min
Standby power input	41.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	2.92 kW	2.08 kW
COP	4.55	2.57

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	167 %	127 %
Prated	7.00 kW	6.00 kW

SCOP	4.25	3.25
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.40 kW	4.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	11 W	11 W
PTO	0 W	0 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	1.50 kW
Annual energy consumption Qhe	3242 kWh	3690 kWh