

Subtype Aquarea Monobloc 9-12 kW T-CAP (H Series)

Certificate Holder	Panasonic Marketing Europe GmbH
Address	Hagenauer Strasse 43, Wiesbaden
ZIP	65203
City	Wiesbaden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Aquarea Monobloc 9-12 kW T-CAP (H Series)
Registration number	011-1W0206
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.3 kg
Certification Date	08.01.2020
Testing basis	HP KEYMARK certification scheme rules V8

Model WH-MXC09H3E5

Model name	WH-MXC09H3E5
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	kW	kW
Cooling capacity		
EER		

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	130 %
Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	160 %	125 %
Prated	11.00 kW	11.00 kW
SCOP	4.08	3.20
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	6.70 kW	6.50 kW
COP Tj = -7°C	3.28	2.56
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	4.30 kW	4.00 kW
COP Tj = +2°C	4.99	3.91
Cdh Tj = +2 °C	0.990	0.990

Pdh Tj = +7°C	5.00 kW	4.80 kW
COP Tj = +7°C	6.29	4.99
Cdh Tj = +7 °C	0.980	0.990
Pdh Tj = 12°C	5.80 kW	5.70 kW
COP Tj = 12°C	7.45	6.32
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.20 kW	8.90 kW
COP Tj = Tbiv	2.48	1.93
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.80 kW	8.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.85	1.52
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.20 kW	2.10 kW
Annual energy consumption Qhe	6651 kWh	8468 kWh
Pdh Tj = -15°C (if TOL	9.20	8.90
COP Tj = -15°C (if TOL	2.48	1.93
Cdh Tj = -15 °C	1.000	1.000

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	235 %	158 %
Prated	9.00 kW	9.00 kW
SCOP	5.95	4.02
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.90 kW	9.00 kW
COP Tj = +2°C	3.49	2.39
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.70 kW	5.70 kW
COP Tj = +7°C	5.49	3.33
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.30 kW
COP Tj = 12°C	7.29	5.35
Cdh Tj = +12 °C	0.990	0.990

Pdh Tj = Tbiv	8.90 kW	9.00 kW
COP Tj = Tbiv	3.49	2.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.90 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.49	2.39
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.10 kW	0.00 kW
Annual energy consumption Qhe	2020 kWh	2991 kWh

Model WH-MXC12H9E8		
Model name	WH-MXC12H9E8	
Application	Heating (medium temp)	
Units	Outdoor	
Climate zone (for heating)	Warmer Climate, Colder Climate	
Reversibility	Yes	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	3x400V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	3.56 kW	1.95 kW
Cooling capacity	10.00	10.00
EER	2.81	5.13
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	170 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input		
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	160 %	125 %
Prated	14.00 kW	13.00 kW
SCOP	4.08	3.20
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.40 kW	7.90 kW
COP Tj = -7°C	3.20	2.54
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	5.00 kW	4.10 kW
COP Tj = +2°C	5.09	3.97
Cdh Tj = +2 °C	0.990	0.990

Pdh Tj = +7°C	5.10 kW	4.80 kW
COP Tj = +7°C	6.61	4.89
Cdh Tj = +7 °C	0.980	0.990
Pdh Tj = 12°C	5.90 kW	5.60 kW
COP Tj = 12°C	7.99	6.00
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	11.20 kW	10.40 kW
COP Tj = Tbiv	2.48	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.90 kW	8.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.50
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input		
Supplementary Heater: PSUP	3.10 kW	4.10 kW
Annual energy consumption Qhe	8460 kWh	10012 kWh
Pdh Tj = -15°C (if TOL	11.20	10.40
COP Tj = -15°C (if TOL	2.48	1.94
Cdh Tj = -15 °C	1.000	1.000

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	231 %	158 %
Prated	12.00 kW	12.00 kW
SCOP	5.86	4.02
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.90 kW	11.70 kW
COP Tj = +2°C	3.18	2.15
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	7.60 kW	7.80 kW
COP Tj = +7°C	5.25	3.33
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	5.90 kW	5.70 kW
COP Tj = 12°C	7.33	5.39
Cdh Tj = +12 °C	0.990	0.990

Pdh Tj = Tbiv	11.90 kW	11.70 kW
COP Tj = Tbiv	3.18	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.18	2.15
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input		
Supplementary Heater: PSUP	0.10 kW	0.30 kW
Annual energy consumption Qhe	2738 kWh	3990 kWh

Model WH-MXC09H3E8

Model name	WH-MXC09H3E8
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	kW	kW
Cooling capacity		
EER		

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	130 %
Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input		
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	160 %	125 %
Prated	11.00 kW	11.00 kW
SCOP	4.08	3.20
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	6.70 kW	6.50 kW
COP Tj = -7°C	3.28	2.56
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	4.30 kW	4.00 kW
COP Tj = +2°C	4.99	3.91
Cdh Tj = +2 °C	0.990	0.990

Pdh Tj = +7°C	5.00 kW	4.80 kW
COP Tj = +7°C	6.29	4.99
Cdh Tj = +7 °C	0.980	0.990
Pdh Tj = 12°C	5.80 kW	5.70 kW
COP Tj = 12°C	7.45	6.32
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.20 kW	8.90 kW
COP Tj = Tbiv	2.48	1.93
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.80 kW	8.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.85	1.52
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input		
Supplementary Heater: PSUP	1.20 kW	2.10 kW
Annual energy consumption Qhe	6651 kWh	8468 kWh
Pdh Tj = -15°C (if TOL	9.20	8.90
COP Tj = -15°C (if TOL	2.48	1.93
Cdh Tj = -15 °C	1.000	1.000

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	235 %	158 %
Prated	9.00 kW	9.00 kW
SCOP	5.95	4.02
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.90 kW	9.00 kW
COP Tj = +2°C	3.49	2.39
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.70 kW	5.70 kW
COP Tj = +7°C	5.49	3.33
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.30 kW
COP Tj = 12°C	7.29	5.35
Cdh Tj = +12 °C	0.990	0.990

Pdh Tj = Tbiv	8.90 kW	9.00 kW
COP Tj = Tbiv	3.49	2.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.90 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.49	2.39
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input		
Supplementary Heater: PSUP	0.10 kW	0.00 kW
Annual energy consumption Qhe	2020 kWh	2991 kWh

Model WH-MXC12H6E5

Model name	WH-MXC12H6E5
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	3.56 kW	1.95 kW
Cooling capacity	10.00	10.00
EER	2.81	5.13

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	170 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	160 %	125 %
Prated	14.00 kW	13.00 kW
SCOP	4.08	3.20
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.40 kW	7.90 kW
COP Tj = -7°C	3.20	2.54
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	5.00 kW	4.10 kW
COP Tj = +2°C	5.09	3.97
Cdh Tj = +2 °C	0.990	0.990

Pdh Tj = +7°C	5.10 kW	4.80 kW
COP Tj = +7°C	6.61	4.89
Cdh Tj = +7 °C	0.980	0.990
Pdh Tj = 12°C	5.90 kW	5.60 kW
COP Tj = 12°C	7.99	6.00
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	11.20 kW	10.40 kW
COP Tj = Tbiv	2.48	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.90 kW	8.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.50
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.10 kW	4.10 kW
Annual energy consumption Qhe	8460 kWh	10012 kWh
Pdh Tj = -15°C (if TOL	11.20	10.40
COP Tj = -15°C (if TOL	2.48	1.94
Cdh Tj = -15 °C	1.000	1.000

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	231 %	158 %
Prated	12.00 kW	12.00 kW
SCOP	5.86	4.02
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.90 kW	11.70 kW
COP Tj = +2°C	3.18	2.15
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	7.60 kW	7.80 kW
COP Tj = +7°C	5.25	3.33
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	5.90 kW	5.70 kW
COP Tj = 12°C	7.33	5.39
Cdh Tj = +12 °C	0.990	0.990

Pdh Tj = Tbiv	11.90 kW	11.70 kW
COP Tj = Tbiv	3.18	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.18	2.15
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.10 kW	0.30 kW
Annual energy consumption Qhe	2738 kWh	3990 kWh