

Subtype Yutampo II - RAW-35NHB & TAW-190NHB

Certificate Holder	Johnson Controls-Hitachi AirConditioning Spain
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella
ZIP	08233
City	Vacarisses, Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	Yutampo II - RAW-35NHB & TAW-190NHB
Registration number	041-K002-27
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R410A
Mass of Refrigerant	1.2 kg
Certification Date	05.02.2018
Testing basis	Heat Pump Keymark Scheme Rules Rev 08

Model RAW-35NHB & TAW-190NHB

Model name	RAW-35NHB & TAW-190NHB
Application	Heating + DHW
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	31.10.2024

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Heat Pump for Domestic Hot Water (DHW)**EN 16147 | Operating test**

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

EN 12102-2 | Average Climate

Sound power level indoor	16 dB(A)
Sound power level outdoor	63 dB(A)

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	123 %
COP	3.10
Heating up time	3:15 h:min
Standby power input	24.9 W
Reference hot water temperature	53.5 °C
Mixed water at 40°C	256 l