

Subtype Thermastage Compact Combi 06

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	Thermastage Compact Combi 06
Registration number	012-C700127
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	0.97 kg
Certification Date	09.09.2021
Testing basis	EN 14511:2018, EN 14825:2018, EN 12102:2017, EN 16147:2017

Model Thermostage Compact combi 06

Model name	Thermostage Compact combi 06
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.60 kW	5.60 kW
El input	1.16 kW	2.02 kW
COP	4.81	2.77

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	190 %	132 %
Prated	6.10 kW	5.40 kW
SCOP	4.82	3.37
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.40 kW	4.80 kW
COP Tj = -7°C	2.97	2.08
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.30 kW	2.90 kW
COP Tj = +2°C	4.64	3.22
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.10 kW	1.90 kW

COP Tj = +7°C	6.67	4.62
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	8.34	6.57
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	5.40 kW	4.80 kW
COP Tj = Tbiv	2.97	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.70 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.79	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	4 W	4 W
PTO	12 W	13 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.20 kW
Annual energy consumption Qhe	2614 kWh	3307 kWh

Model Thermostage Compact Duo 06

Model name	Thermostage Compact Duo 06
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	132 %
COP	3.30
Heating up time	1:35 h:min
Standby power input	31.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	245 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.60 kW	5.60 kW
El input	1.16 kW	2.02 kW
COP	4.81	2.77

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	190 %	132 %
Prated	6.10 kW	5.40 kW
SCOP	4.82	3.37

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.40 kW	4.80 kW
COP Tj = -7°C	2.97	2.08
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.30 kW	2.90 kW
COP Tj = +2°C	4.64	3.22
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.10 kW	1.90 kW
COP Tj = +7°C	6.67	4.62
Cdh Tj = +7 °C	0.960	0.970
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	8.34	6.57
Cdh Tj = +12 °C	0.960	0.960
Pdh Tj = Tbiv	5.40 kW	4.80 kW
COP Tj = Tbiv	2.97	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.70 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.79	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	55 °C	55 °C
Poff	4 W	4 W
PTO	12 W	13 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.20 kW
Annual energy consumption Qhe	2614 kWh	3307 kWh