

Subtype 31. Yutaki S (N1) & S Combi (NW1) 220L 4HP R410A (3ph)

Certificate Holder	Johnson Controls-Hitachi AirConditioning Spain
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella
ZIP	08233
City	Vacarisses, Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	31. Yutaki S (N1) & S Combi (NW1) 220L 4HP R410A (3ph)
Registration number	041-K002-52
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	3.3 kg
Certification Date	08.02.2022
Testing basis	Heat Pump Keymark Scheme Rules Rev 09

Model 03. RAS-4WHNPE RWD-4.0NW1E-220S - Heating Only

Model name	03. RAS-4WHNPE RWD-4.0NW1E-220S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	180 %	135 %
Prated	11.00 kW	10.00 kW
SCOP	4.58	3.44

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4823 kWh	5837 kWh

Model 04. RAS-4WHNPE RWD-4.0NW1E-220S - with cooling kit

Model name	04. RAS-4WHNPE RWD-4.0NW1E-220S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	n/a
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.87 kW	2.31 kW
Cooling capacity	7.20	10.40
EER	3.84	4.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)

Sound power level outdoor 58 dB(A) 58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.64	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4753 kWh	5767 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.20 kW	10.40 kW
SEER	5.00	6.22
Pdc Tj = 35°C	7.20 kW	10.40 kW
EER Tj = 35°C	3.84	4.50
Pdc Tj = 30°C	5.30 kW	7.66 kW
EER Tj = 30°C	4.60	6.30

Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.50 kW	4.93 kW
EER Tj = 25°C	5.80	7.20
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.60 kW	5.10 kW
EER Tj = 20°C	7.50	8.20
Cdc Tj = 20 °C	0.900	0.900
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Annual energy consumption Qce	504 kWh	585 kWh

Model 05. RAS-4WHNPE RWD-4.0NW1E-220S-K - UK Version - Heating Only

Model name	05. RAS-4WHNPE RWD-4.0NW1E-220S-K - UK Version - Heating Only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	180 %	135 %
Prated	11.00 kW	10.00 kW

SCOP	4.58	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4823 kWh	5837 kWh

Model 06. RAS-4WHNPE RWD-4.0NW1E-220S-K - UK Version - with cooling kit

Model name	06. RAS-4WHNPE RWD-4.0NW1E-220S-K - UK Version - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.87 kW	2.31 kW
Cooling capacity	7.20	10.40
EER	3.84	4.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.64	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4753 kWh	5767 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.20 kW	10.40 kW
SEER	5.00	6.22
Pdc Tj = 35°C	7.20 kW	10.40 kW
EER Tj = 35°C	3.84	4.50
Pdc Tj = 30°C	5.30 kW	7.66 kW

EER Tj = 30°C	4.60	6.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.50 kW	4.93 kW
EER Tj = 25°C	5.80	7.20
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.60 kW	5.10 kW
EER Tj = 20°C	7.50	8.20
Cdc Tj = 20 °C	0.900	0.900
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Annual energy consumption Qce	504 kWh	585 kWh

Model 01. RAS-4WHNPE RWM-4.0N1E - Heating Only

Model name	01. RAS-4WHNPE RWM-4.0N1E - Heating Only
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	180 %	135 %
Prated	11.00 kW	10.00 kW
SCOP	4.58	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW

COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4823 kWh	5837 kWh

Model 02. RAS-4WHNPE RWM-4.0N1E - with cooling kit

Model name	02. RAS-4WHNPE RWM-4.0N1E - with cooling kit
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.87 kW	2.31 kW
Cooling capacity	7.20	10.40
EER	3.84	4.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.64	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4753 kWh	5767 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.20 kW	10.40 kW
SEER	5.00	6.22
Pdc Tj = 35°C	7.20 kW	10.40 kW
EER Tj = 35°C	3.84	4.50
Pdc Tj = 30°C	5.30 kW	7.66 kW
EER Tj = 30°C	4.60	6.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.50 kW	4.93 kW
EER Tj = 25°C	5.80	7.20
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.60 kW	5.10 kW
EER Tj = 20°C	7.50	8.20
Cdc Tj = 20 °C	0.900	0.900
Poff	19 W	19 W
PTO	0 W	0 W

PSB	19 W	19 W
PCK	0 W	0 W
Annual energy consumption Qce	504 kWh	585 kWh