

Subtype Grant Aerona3 HPID13R32

Certificate Holder	Grant Engineering (UK) Ltd
Address	Hopton Industrial Estate, Hopton House
ZIP	SN10 2EU
City	Devizes
Country	GB
Certification Body	BRE Global Limited
Subtype title	Grant Aerona3 HPID13R32
Registration number	041-K006-03
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	2.2 kg
Certification Date	01.03.2022
Testing basis	Heat Pump Keymark Scheme Rules Rev 09

Model HPID13R32		
Model name	HPID13R32	
Application	Heating + DHW + low temp	
Units	Outdoor	
Climate zone (for heating)	n/a	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	1x230V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 16147 Average Climate		
Declared load profile	L	
Efficiency η_{DHW}	113 %	
COP	2.74	
Heating up time	01:03 h:min	
Standby power input	26.3 W	
Reference hot water temperature	49.99 °C	
Mixed water at 40°C	287 l	
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	13.6 kW	11.4 kW
El input	2.59 kW	3.53 kW
COP	5.25	3.23
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	60.8 dB(A)	60.8 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
η_s	215 %	160 %
Prated	10.00 kW	10.00 kW
SCOP	5.46	4.08
Tbiv	-8 °C	-8 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.60 kW	9.68 kW
COP Tj = -7°C	3.03	2.16
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	6.09 kW	6.05 kW
COP Tj = +2°C	6.20	3.92
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	4.30 kW	4.14 kW
COP Tj = +7°C	8.50	8.62
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.10 kW	4.11 kW
COP Tj = 12°C	10.30	8.62
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	9.14 kW	8.91 kW
COP Tj = Tbiv	3.02	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.69 kW	7.36 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.98	2.04
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	100 W	100 W
PTO	40 W	40 W
PSB	100 W	100 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.31 kW	2.64 kW
Annual energy consumption Qhe	3787 kWh	5066 kWh