

Subtype Yutaki M 5.0HP R32 (tri)

Certificate Holder	Johnson Controls-Hitachi AirConditioning Spain
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella
ZIP	08233
City	Vacarisses, Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	Yutaki M 5.0HP R32 (tri)
Registration number	041-K002-62
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	3 kg
Certification Date	14.10.2022
Testing basis	Heat Pump Keymark Scheme Rules Rev 09

Model RASM-5R1E - heating only

Model name	RASM-5R1E - heating only
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.67 kW	4.71 kW
COP	4.50	2.55

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	128 %
Prated	12.00 kW	12.00 kW
SCOP	4.13	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.70 kW
COP Tj = -7°C	2.94	2.35
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.50 kW	6.50 kW
COP Tj = +2°C	4.36	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	6.30 kW
COP Tj = +7°C	5.03	4.06

Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.50 kW
COP Tj = 12°C	5.95	5.23
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.70 kW	10.70 kW
COP Tj = Tbiv	2.94	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.47	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	35 °C	55 °C
Poff	29 W	29 W
PTO	0 W	0 W
PSB	29 W	29 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.40 kW	1.40 kW
Annual energy consumption Qhe	6051 kWh	7654 kWh

Model RASM-5R1E - with cooling kit

Model name	RASM-5R1E - with cooling kit
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.67 kW	4.71 kW
COP	4.50	2.55

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	3.64 kW	2.76 kW
Cooling capacity	12.00	13.00
EER	3.30	4.71

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	12.00 kW	12.00 kW
SCOP	4.13	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.70 kW

COP Tj = -7°C	2.94	2.35
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.50 kW	6.50 kW
COP Tj = +2°C	4.36	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	6.30 kW
COP Tj = +7°C	5.03	4.06
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.50 kW
COP Tj = 12°C	5.95	5.23
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.70 kW	10.70 kW
COP Tj = Tbiv	2.94	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.47	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	35 °C	55 °C
Poff	29 W	29 W
PTO	0 W	0 W
PSB	29 W	29 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.40 kW	1.40 kW
Annual energy consumption Qhe	5945 kWh	7548 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.00 kW	13.00 kW
SEER	4.05	7.14
Pdc Tj = 35°C	12.00 kW	13.00 kW
EER Tj = 35°C	3.30	4.71
Cdc Tj = 35 °C		
Pdc Tj = 30°C	8.84 kW	9.58 kW
EER Tj = 30°C	4.16	6.43
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	5.68 kW	6.16 kW
EER Tj = 25°C	4.61	9.06
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.14 kW	4.90 kW
EER Tj = 20°C	4.46	10.39
Cdc Tj = 20 °C	0.900	0.900
Poff	29 W	29 W
PTO	0 W	0 W

PSB	29 W	29 W
PCK	0 W	0 W
Annual energy consumption Qce	1038 kWh	637 kWh

Model RASM-5RW1E & HWM-WE - heating only

Model name	RASM-5RW1E & HWM-WE - heating only
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	n/a
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.67 kW	4.71 kW
COP	4.50	2.55

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	128 %
Prated	12.00 kW	12.00 kW
SCOP	4.13	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.70 kW
COP Tj = -7°C	2.94	2.35
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.50 kW	6.50 kW
COP Tj = +2°C	4.36	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	6.30 kW

COP Tj = +7°C	5.03	4.06
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.50 kW
COP Tj = 12°C	5.95	5.23
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.70 kW	10.70 kW
COP Tj = Tbiv	2.94	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.47	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	35 °C	55 °C
Poff	29 W	29 W
PTO	0 W	0 W
PSB	29 W	29 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.40 kW	1.40 kW
Annual energy consumption Qhe	6051 kWh	7654 kWh

Model RASM-5RW1E & HWM-WE - with cooling kit

Model name	RASM-5RW1E & HWM-WE - with cooling kit
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	n/a
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.67 kW	4.71 kW
COP	4.50	2.55

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	3.64 kW	2.76 kW
Cooling capacity	12.00	13.00
EER	3.30	4.71

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	12.00 kW	12.00 kW
SCOP	4.13	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	10.70 kW	10.70 kW
COP Tj = -7°C	2.94	2.35
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.50 kW	6.50 kW
COP Tj = +2°C	4.36	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	6.30 kW
COP Tj = +7°C	5.03	4.06
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.50 kW
COP Tj = 12°C	5.95	5.23
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.70 kW	10.70 kW
COP Tj = Tbiv	2.94	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.47	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	35 °C	55 °C
Poff	29 W	29 W
PTO	0 W	0 W
PSB	29 W	29 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.40 kW	1.40 kW
Annual energy consumption Qhe	5945 kWh	7548 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.00 kW	13.00 kW
SEER	4.05	7.14
Pdc Tj = 35°C	12.00 kW	13.00 kW
EER Tj = 35°C	3.30	4.71
Cdc Tj = 35 °C		
Pdc Tj = 30°C	8.84 kW	9.58 kW
EER Tj = 30°C	4.16	6.43
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	5.68 kW	6.16 kW
EER Tj = 25°C	4.61	9.06
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.14 kW	4.90 kW
EER Tj = 20°C	4.46	10.39
Cdc Tj = 20 °C	0.900	0.900
Poff	29 W	29 W

PTO	0 W	0 W
PSB	29 W	29 W
PCK	0 W	0 W
Annual energy consumption Qce	1038 kWh	637 kWh

Model RASM-5RW1E & HWD-WE-220S - heating only

Model name	RASM-5RW1E & HWD-WE-220S - heating only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	n/a
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	95 %
COP	2.30
Heating up time	1:10 h:min
Standby power input	56.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.67 kW	4.71 kW
COP	4.50	2.55

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	128 %
Prated	12.00 kW	12.00 kW
SCOP	4.13	3.26

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.70 kW
COP Tj = -7°C	2.94	2.35
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.50 kW	6.50 kW
COP Tj = +2°C	4.36	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	6.30 kW
COP Tj = +7°C	5.03	4.06
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.50 kW
COP Tj = 12°C	5.95	5.23
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.70 kW	10.70 kW
COP Tj = Tbiv	2.94	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.47	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	35 °C	55 °C
Poff	29 W	29 W
PTO	0 W	0 W
PSB	29 W	29 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.40 kW	1.40 kW
Annual energy consumption Qhe	6051 kWh	7654 kWh

Model RASM-5RW1E & HWD-WE-220S-K - heating only

Model name	RASM-5RW1E & HWD-WE-220S-K - heating only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	n/a
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	95 %
COP	2.30
Heating up time	1:10 h:min
Standby power input	56.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.67 kW	4.71 kW
COP	4.50	2.55

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)
Sound power level outdoor	63 dB(A)	63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	128 %
Prated	12.00 kW	12.00 kW
SCOP	4.13	3.26

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.70 kW
COP Tj = -7°C	2.94	2.35
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.50 kW	6.50 kW
COP Tj = +2°C	4.36	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	6.30 kW
COP Tj = +7°C	5.03	4.06
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.50 kW
COP Tj = 12°C	5.95	5.23
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.70 kW	10.70 kW
COP Tj = Tbiv	2.94	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.47	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	35 °C	55 °C
Poff	29 W	29 W
PTO	0 W	0 W
PSB	29 W	29 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.40 kW	1.40 kW
Annual energy consumption Qhe	6051 kWh	7654 kWh

Model RASM-5RW1E & HWD-WE-220S - with cooling kit

Model name	RASM-5RW1E & HWD-WE-220S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	n/a
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	95 %
COP	2.30
Heating up time	1:10 h:min
Standby power input	56.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.67 kW	4.71 kW
COP	4.50	2.55

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	3.64 kW	2.76 kW
Cooling capacity	12.00	13.00
EER	3.30	4.71

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	49 dB(A)	49 dB(A)

Sound power level outdoor 63 dB(A) 63 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	165 %	129 %
Prated	12.00 kW	12.00 kW
SCOP	4.13	3.26
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.70 kW
COP Tj = -7°C	2.94	2.35
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.50 kW	6.50 kW
COP Tj = +2°C	4.36	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.20 kW	6.30 kW
COP Tj = +7°C	5.03	4.06
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.50 kW
COP Tj = 12°C	5.95	5.23
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.70 kW	10.70 kW
COP Tj = Tbiv	2.94	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.47	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	35 °C	55 °C
Poff	29 W	29 W
PTO	0 W	0 W
PSB	29 W	29 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.40 kW	1.40 kW
Annual energy consumption Qhe	5945 kWh	7548 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.00 kW	13.00 kW
SEER	4.05	7.14
Pdc Tj = 35°C	12.00 kW	13.00 kW
EER Tj = 35°C	3.30	4.71
Cdc Tj = 35 °C		
Pdc Tj = 30°C	8.84 kW	9.58 kW

EER Tj = 30°C	4.16	6.43
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	5.68 kW	6.16 kW
EER Tj = 25°C	4.61	9.06
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.14 kW	4.90 kW
EER Tj = 20°C	4.46	10.39
Cdc Tj = 20 °C	0.900	0.900
Poff	29 W	29 W
PTO	0 W	0 W
PSB	29 W	29 W
PCK	0 W	0 W
Annual energy consumption Qce	1038 kWh	637 kWh