

Certificate Holder	Zhongshan Amitime Electric Co., Ltd
Address	5th Yandong Rd
ZIP	
City	Zhongshan City - Guangdong
Country	CN
Certification Body	BRE Global Limited
Subtype title	DC Inverter Air to Water Heat Pump Unit-R32-09
Registration number	041-K027-05
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.4 kg
Certification Date	26.08.2022
Testing basis	Heat Pump Keymark Scheme Rules Rev 09



Model Indoor unit: PAVH-09V1DC/IB, Outdoo	or unit: PAVH-09V1FEB	
Model name	Indoor unit: PAVH-09V1DC/IB,	Outdoor unit:
	PAVH-09V1FEB	
Application	Heating (medium temp)	
Units	Indoor, Outdoor	
Climate zone (for heating)	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	1x230V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4   Heating		
	naccod	
Shutting off the heat transfer medium flow		
Complete power supply failure Defrost test	passed	
	passed	
Starting and operating test	passed	
EN 12102-1   Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	46 dB(A)
Sound power level outdoor	53 dB(A)	54 dB(A)
EN 14825   Average Climate		
	Low temperature	Medium temperature
ηs	181 %	130 %
Prated	6.39 kW	5.97 kW
SCOP	4.61	3.32
Tbiv	-7 °C	-7 °C
TOL		, .
	-10 °C	-10 °C
$Pdh Tj = -7^{\circ}C$	-10 °C 5.65 kW	
-		-10 °C
$COP Tj = -7^{\circ}C$	5.65 kW	-10 °C 5.28 kW
COP Tj = -7°C Cdh Tj = -7 °C	5.65 kW 3.19	-10 °C 5.28 kW 1.94
COP Tj = -7 °C Cdh Tj = -7 °C Pdh Tj = +2 °C	5.65 kW 3.19 0.900	-10 °C 5.28 kW 1.94 0.900
COP Tj = -7 °C $Cdh Tj = -7 °C$ $Pdh Tj = +2 °C$ $COP Tj = +2 °C$	5.65 kW 3.19 0.900 3.52 kW	-10 °C 5.28 kW 1.94 0.900 3.41 kW
COP Tj = -7 °C $Cdh Tj = -7 °C$ $Pdh Tj = +2 °C$ $COP Tj = +2 °C$ $Cdh Tj = +2 °C$	5.65 kW 3.19 0.900 3.52 kW 4.43	-10 °C 5.28 kW 1.94 0.900 3.41 kW 3.34
COP Tj = -7 °C $Cdh Tj = -7 °C$ $Pdh Tj = +2 °C$ $COP Tj = +2 °C$ $Cdh Tj = +2 °C$ $Pdh Tj = +7 °C$	5.65 kW 3.19 0.900 3.52 kW 4.43 0.900	-10 °C 5.28 kW 1.94 0.900 3.41 kW 3.34 0.900
COP Tj = -7 °C $Cdh Tj = -7 °C$ $Pdh Tj = +2 °C$ $COP Tj = +2 °C$ $Cdh Tj = +2 °C$ $Pdh Tj = +7 °C$ $COP Tj = +7 °C$	5.65 kW 3.19 0.900 3.52 kW 4.43 0.900 3.36 kW	-10 °C 5.28 kW 1.94 0.900 3.41 kW 3.34 0.900 3.15 kW
COP Tj = -7 °C $Cdh Tj = -7 °C$ $Pdh Tj = +2 °C$ $COP Tj = +2 °C$ $Cdh Tj = +2 °C$ $Pdh Tj = +7 °C$ $COP Tj = +7 °C$ $COP Tj = +7 °C$	5.65 kW 3.19 0.900 3.52 kW 4.43 0.900 3.36 kW 6.36	-10 °C 5.28 kW 1.94 0.900 3.41 kW 3.34 0.900 3.15 kW 4.60
Pdh Tj = $-7^{\circ}$ C COP Tj = $-7^{\circ}$ C Cdh Tj = $-7^{\circ}$ C Pdh Tj = $+2^{\circ}$ C COP Tj = $+2^{\circ}$ C Cdh Tj = $+2^{\circ}$ C Pdh Tj = $+7^{\circ}$ C COP Tj = $+7^{\circ}$ C Cdh Tj = $+7^{\circ}$ C Pdh Tj = $12^{\circ}$ C COP Tj = $12^{\circ}$ C	5.65 kW 3.19 0.900 3.52 kW 4.43 0.900 3.36 kW 6.36 0.900	-10 °C 5.28 kW 1.94 0.900 3.41 kW 3.34 0.900 3.15 kW 4.60 0.900



Registration number 041-K027-05

Pdh Tj = Tbiv	5.65 kW	5.28 kW
COP Tj = Tbiv	3.19	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.32 kW	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	57 °C	57 °C
Poff	10 W	10 W
РТО	19 W	19 W
PSB	10 W	10 W
РСК	27 W	27 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.07 kW	1.17 kW
Annual energy consumption Qhe	2864 kWh	3720 kWh