

## Subtype Aquarea Monobloc 16 kW T-CAP (J Series) + TD23

|                     |                                                                |
|---------------------|----------------------------------------------------------------|
| Certificate Holder  | Panasonic Marketing Europe GmbH                                |
| Address             | Hagenauer Strasse 43, Wiesbaden                                |
| ZIP                 | 65203                                                          |
| City                | Wiesbaden                                                      |
| Country             | DE                                                             |
| Certification Body  | DIN CERTCO Gesellschaft für Konformitätsbewertung mbH          |
| Subtype title       | Aquarea Monobloc 16 kW T-CAP (J Series) + TD23                 |
| Registration number | 011-1W0563                                                     |
| Heat Pump Type      | Outdoor Air/Water                                              |
| Refrigerant         | R32                                                            |
| Mass of Refrigerant | 1.8 kg                                                         |
| Certification Date  | 22.12.2022                                                     |
| Testing basis       | European KEYMARK Scheme for Heat Pumps Rev. 10 (as of 2022-06) |

## Model WH-MXC16J9E8 + PAW-TD23B6E5

|                                     |                             |
|-------------------------------------|-----------------------------|
| Model name                          | WH-MXC16J9E8 + PAW-TD23B6E5 |
| Application                         | Heating + DHW + low temp    |
| Units                               | Outdoor                     |
| Climate zone (for heating)          | n/a                         |
| Reversibility                       | Yes                         |
| Cooling mode application (optional) | n/a                         |
| Any additional heat sources         | n/a                         |

## General data

|                  |             |
|------------------|-------------|
| Power supply     | 3x400V 50Hz |
| Off-peak product | n/a         |

## Outdoor Air/Water

## EN 16147 | Average Climate

|                                 |            |
|---------------------------------|------------|
| Declared load profile           | L          |
| Efficiency $\eta_{DHW}$         | 87 %       |
| COP                             | 2.00       |
| Heating up time                 | 0:48 h:min |
| Standby power input             | 80.0 W     |
| Reference hot water temperature | 47.9 °C    |
| Mixed water at 40°C             | 232 l      |

## EN 16147 | Colder Climate

|                                 |            |
|---------------------------------|------------|
| Declared load profile           | XL         |
| Efficiency $\eta_{DHW}$         | 81 %       |
| COP                             | 1.88       |
| Heating up time                 | 1:09 h:min |
| Standby power input             | 120.0 W    |
| Reference hot water temperature | 52.5 °C    |
| Mixed water at 40°C             | 388 l      |

## EN 16147 | Warmer Climate

|                                 |            |
|---------------------------------|------------|
| Declared load profile           | XL         |
| Efficiency $\eta_{DHW}$         | 134 %      |
| COP                             | 3.23       |
| Heating up time                 | 1:17 h:min |
| Standby power input             | 40.0 W     |
| Reference hot water temperature | 52.7 °C    |
| Mixed water at 40°C             | 390 l      |

## EN 14511-4 | Heating

|                                            |        |
|--------------------------------------------|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure              | passed |

|                             |        |
|-----------------------------|--------|
| Defrost test                | passed |
| Starting and operating test | passed |

#### EN 14511-2 | Heating

|             | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 16.00 kW        | 16.00 kW           |
| El input    | 3.54 kW         | 5.59 kW            |
| COP         | 4.52            | 2.86               |

#### EN 12102-1 | Average Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 66 dB(A)        | 66 dB(A)           |

#### EN 14825 | Average Climate

|                                                     | Low temperature | Medium temperature |
|-----------------------------------------------------|-----------------|--------------------|
| $\eta_s$                                            | 176 %           | 129 %              |
| Prated                                              | 13.00 kW        | 16.00 kW           |
| SCOP                                                | 4.46            | 3.31               |
| Tbiv                                                | -10 °C          | -10 °C             |
| TOL                                                 | -10 °C          | -10 °C             |
| Pdh Tj = -7°C                                       | 11.50 kW        | 14.20 kW           |
| COP Tj = -7°C                                       | 2.70            | 1.86               |
| Cdh Tj = -7 °C                                      | 1.000           | 1.000              |
| Pdh Tj = +2°C                                       | 7.00 kW         | 8.60 kW            |
| COP Tj = +2°C                                       | 4.43            | 3.30               |
| Cdh Tj = +2 °C                                      | 0.990           | 0.990              |
| Pdh Tj = +7°C                                       | 8.00 kW         | 7.90 kW            |
| COP Tj = +7°C                                       | 5.68            | 4.31               |
| Cdh Tj = +7 °C                                      | 0.990           | 0.990              |
| Pdh Tj = 12°C                                       | 9.30 kW         | 9.20 kW            |
| COP Tj = 12°C                                       | 7.28            | 5.55               |
| Cdh Tj = +12 °C                                     | 0.990           | 0.990              |
| Pdh Tj = Tbiv                                       | 13.00 kW        | 16.00 kW           |
| COP Tj = Tbiv                                       | 2.70            | 1.67               |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 13.00 kW        | 16.00 kW           |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.70            | 1.67               |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900           | 0.900              |
| WTOL                                                | 55 °C           | 55 °C              |
| Poff                                                | 12 W            | 12 W               |
| PTO                                                 | 14 W            | 14 W               |
| PSB                                                 | 12 W            | 12 W               |
| PCK                                                 | 0 W             | 0 W                |

|                                            |             |             |
|--------------------------------------------|-------------|-------------|
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP                 | 0.00 kW     | 0.00 kW     |
| Annual energy consumption Q <sub>he</sub>  | 6018 kWh    | 9984 kWh    |

#### EN 12102-1 | Colder Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 66 dB(A)        | 66 dB(A)           |

#### EN 14825 | Colder Climate

|                                                                                                                             | Low temperature | Medium temperature |
|-----------------------------------------------------------------------------------------------------------------------------|-----------------|--------------------|
| η <sub>s</sub>                                                                                                              | 150 %           | 125 %              |
| Prated                                                                                                                      | 19.00 kW        | 18.00 kW           |
| SCOP                                                                                                                        | 3.83            | 3.20               |
| T <sub>biv</sub>                                                                                                            | -15 °C          | -15 °C             |
| TOL                                                                                                                         | -22 °C          | -22 °C             |
| P <sub>dh</sub> T <sub>j</sub> = -7°C                                                                                       | 11.50 kW        | 10.90 kW           |
| COP T <sub>j</sub> = -7°C                                                                                                   | 2.69            | 2.57               |
| C <sub>dh</sub> T <sub>j</sub> = -7 °C                                                                                      | 1.000           | 1.000              |
| P <sub>dh</sub> T <sub>j</sub> = +2°C                                                                                       | 7.10 kW         | 6.80 kW            |
| COP T <sub>j</sub> = +2°C                                                                                                   | 5.04            | 3.97               |
| C <sub>dh</sub> T <sub>j</sub> = +2 °C                                                                                      | 0.990           | 0.990              |
| P <sub>dh</sub> T <sub>j</sub> = +7°C                                                                                       | 8.00 kW         | 7.90 kW            |
| COP T <sub>j</sub> = +7°C                                                                                                   | 6.35            | 5.04               |
| C <sub>dh</sub> T <sub>j</sub> = +7 °C                                                                                      | 0.990           | 0.990              |
| P <sub>dh</sub> T <sub>j</sub> = 12°C                                                                                       | 9.10 kW         | 9.00 kW            |
| COP T <sub>j</sub> = 12°C                                                                                                   | 7.59            | 6.31               |
| C <sub>dh</sub> T <sub>j</sub> = +12 °C                                                                                     | 0.990           | 0.990              |
| P <sub>dh</sub> T <sub>j</sub> = T <sub>biv</sub>                                                                           | 15.50 kW        | 14.70 kW           |
| COP T <sub>j</sub> = T <sub>biv</sub>                                                                                       | 2.42            | 1.83               |
| P <sub>dh</sub> T <sub>j</sub> = TOL or P <sub>dh</sub> T <sub>j</sub> = T <sub>designh</sub> if TOL < T <sub>designh</sub> | 15.30 kW        | 13.40 kW           |
| COP T <sub>j</sub> = TOL or COP T <sub>j</sub> = T <sub>designh</sub> if TOL < T <sub>designh</sub>                         | 1.91            | 1.39               |
| C <sub>dh</sub> T <sub>j</sub> = TOL or P <sub>dh</sub> T <sub>j</sub> = T <sub>designh</sub> if TOL < T <sub>designh</sub> | 0.900           | 0.900              |
| WTOL                                                                                                                        | 55 °C           | 55 °C              |
| P <sub>off</sub>                                                                                                            | 12 W            | 12 W               |
| PTO                                                                                                                         | 14 W            | 14 W               |
| PSB                                                                                                                         | 12 W            | 12 W               |
| PCK                                                                                                                         | 0 W             | 0 W                |
| Supplementary Heater: Type of energy input                                                                                  | Electricity     | Electricity        |
| Supplementary Heater: PSUP                                                                                                  | 3.70 kW         | 4.60 kW            |
| Annual energy consumption Q <sub>he</sub>                                                                                   | 12233 kWh       | 13870 kWh          |
| P <sub>dh</sub> T <sub>j</sub> = -15°C (if TOL                                                                              | 15.50           | 14.70              |
| COP T <sub>j</sub> = -15°C (if TOL                                                                                          | 2.42            | 1.83               |

|                 |       |       |
|-----------------|-------|-------|
| Cdh Tj = -15 °C | 0.900 | 0.900 |
|-----------------|-------|-------|

#### EN 12102-1 | Warmer Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 66 dB(A)        | 66 dB(A)           |

#### EN 14825 | Warmer Climate

|                                                     | Low temperature | Medium temperature |
|-----------------------------------------------------|-----------------|--------------------|
| $\eta_s$                                            | 232 %           | 160 %              |
| Prated                                              | 16.00 kW        | 16.00 kW           |
| SCOP                                                | 5.88            | 4.09               |
| Tbiv                                                | 2 °C            | 2 °C               |
| TOL                                                 | 2 °C            | 2 °C               |
| Pdh Tj = +2°C                                       | 16.00 kW        | 16.00 kW           |
| COP Tj = +2°C                                       | 2.96            | 2.03               |
| Cdh Tj = +2 °C                                      | 1.000           | 1.000              |
| Pdh Tj = +7°C                                       | 10.30 kW        | 10.30 kW           |
| COP Tj = +7°C                                       | 5.32            | 3.56               |
| Cdh Tj = +7 °C                                      | 0.990           | 1.000              |
| Pdh Tj = 12°C                                       | 9.10 kW         | 8.90 kW            |
| COP Tj = 12°C                                       | 7.25            | 5.21               |
| Cdh Tj = +12 °C                                     | 0.990           | 0.990              |
| Pdh Tj = Tbiv                                       | 16.00 kW        | 16.00 kW           |
| COP Tj = Tbiv                                       | 2.96            | 2.03               |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 16.00 kW        | 16.00 kW           |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.96            | 2.03               |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900           | 0.900              |
| WTOL                                                | 55 °C           | 55 °C              |
| Poff                                                | 12 W            | 12 W               |
| PTO                                                 | 14 W            | 14 W               |
| PSB                                                 | 12 W            | 12 W               |
| PCK                                                 | 0 W             | 0 W                |
| Supplementary Heater: Type of energy input          | Electricity     | Electricity        |
| Supplementary Heater: PSUP                          | 0.00 kW         | 0.00 kW            |
| Annual energy consumption Qhe                       | 3634 kWh        | 5230 kWh           |