

Subtype Chappée ERIA S PLUS R32 4-6 & ERIA S PLUS FIT-IN R32 4-6

Certificate Holder	BDR Thermea FR (CHAPPEE)
Address	57 rue de la Gare
ZIP	67580
City	Mertzwiller
Country	FR
Certification Body	Kiwa Nederland B.V.
Subtype title	Chappée ERIA S PLUS R32 4-6 & ERIA S PLUS FIT-IN R32 4-6
Registration number	007-DN0141
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	11.11.2022
Testing basis	European KEYMARK Scheme for Heat Pumps (v10)

Model ERIA S PLUS FIT-IN R32 4 MR/EM

Model name	ERIA S PLUS FIT-IN R32 4 MR/EM
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	135 %
COP	3.25
Heating up time	1:30 h:min
Standby power input	27.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	249 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.25 kW	4.40 kW
El input	0.82 kW	1.49 kW
COP	5.20	2.95

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.76 kW	4.64 kW
Cooling capacity	1.32	0.84
EER	3.60	5.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)

Sound power level outdoor	52 dB(A)	52 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
η_s	193 %	132 %
Prated	5.52 kW	4.40 kW
SCOP	4.90	3.38
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.88 kW	3.89 kW
COP Tj = -7°C	3.19	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.06 kW	2.38 kW
COP Tj = +2°C	4.78	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.94 kW	1.56 kW
COP Tj = +7°C	6.40	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.48 kW	1.32 kW
COP Tj = 12°C	8.05	5.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.88 kW	3.89 kW
COP Tj = Tbiv	3.19	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	3.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.11 kW	0.98 kW
Annual energy consumption Qhe	2326 kWh	2686 kWh

EN 14825 Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	4.76 kW	4.64 kW
SEER	4.44	8.25
Pdc Tj = 35°C	4.76 kW	4.64 kW
EER Tj = 35°C	3.60	5.50
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	3.44 kW	3.38 kW

EER Tj = 30°C	4.55	7.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	2.19 kW	2.09 kW
EER Tj = 25°C	5.12	8.95
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	0.95 kW	1.16 kW
EER Tj = 20°C	4.29	13.20
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W
PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	643 kWh	337 kWh

Model ERIA S PLUS FIT-IN R32 6 MR/EM

Model name	ERIA S PLUS FIT-IN R32 6 MR/EM
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	135 %
COP	3.25
Heating up time	1:30 h:min
Standby power input	27.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	249 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.20 kW	6.00 kW
El input	1.24 kW	2.00 kW
COP	5.00	3.00

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	7.18 kW	6.70 kW
Cooling capacity	2.39	1.35
EER	3.01	4.95

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)

Sound power level outdoor 52 dB(A) 52 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	138 %
Prated	6.82 kW	5.70 kW
SCOP	4.95	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.03 kW	5.05 kW
COP Tj = -7°C	3.09	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.88 kW	3.12 kW
COP Tj = +2°C	4.85	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.40 kW	2.09 kW
COP Tj = +7°C	6.63	4.54
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.39 kW	1.28 kW
COP Tj = 12°C	7.83	5.59
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.03 kW	5.05 kW
COP Tj = Tbiv	3.09	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.36 kW	4.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.18 kW
Annual energy consumption Qhe	2846 kWh	3341 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.18 kW	6.70 kW
SEER	4.75	8.44
Pdc Tj = 35°C	7.18 kW	6.70 kW
EER Tj = 35°C	3.01	4.95
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	5.21 kW	4.93 kW

EER Tj = 30°C	4.47	7.22
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.42 kW	3.51 kW
EER Tj = 25°C	5.21	9.45
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	1.51 kW	1.43 kW
EER Tj = 20°C	5.68	12.89
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W
PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	907 kWh	477 kWh

Model ERIA S PLUS R32 4 MR/EM		
Model name	ERIA S PLUS R32 4 MR/EM	
Application	Heating (medium temp)	
Units	Indoor, Outdoor	
Climate zone (for heating)	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C	
Any additional heat sources	n/a	
General data		
Power supply	1x230V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	4.25 kW	4.40 kW
El input	0.82 kW	1.49 kW
COP	5.20	2.95
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	4.76 kW	4.64 kW
Cooling capacity	1.32	0.84
EER	3.60	5.50
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	193 %	132 %
Prated	5.52 kW	4.40 kW
SCOP	4.90	3.38
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	4.88 kW	3.89 kW
COP Tj = -7°C	3.19	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.06 kW	2.38 kW
COP Tj = +2°C	4.78	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.94 kW	1.56 kW
COP Tj = +7°C	6.40	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.48 kW	1.32 kW
COP Tj = 12°C	8.05	5.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.88 kW	3.89 kW
COP Tj = Tbiv	3.19	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	3.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.11 kW	0.98 kW
Annual energy consumption Qhe	2326 kWh	2686 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	4.76 kW	4.64 kW
SEER	4.44	8.25
Pdc Tj = 35°C	4.76 kW	4.64 kW
EER Tj = 35°C	3.60	5.50
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	3.44 kW	3.38 kW
EER Tj = 30°C	4.55	7.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	2.19 kW	2.09 kW
EER Tj = 25°C	5.12	8.95
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	0.95 kW	1.16 kW
EER Tj = 20°C	4.29	13.20
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W

PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	643 kWh	337 kWh

Model ERIA S PLUS R32 6 MR/EM

Model name	ERIA S PLUS R32 6 MR/EM
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.20 kW	6.00 kW
El input	1.24 kW	2.00 kW
COP	5.00	3.00

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	7.18 kW	6.70 kW
Cooling capacity	2.39	1.35
EER	3.01	4.95

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	138 %
Prated	6.82 kW	5.70 kW
SCOP	4.95	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	6.03 kW	5.05 kW
COP Tj = -7°C	3.09	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.88 kW	3.12 kW
COP Tj = +2°C	4.85	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.40 kW	2.09 kW
COP Tj = +7°C	6.63	4.54
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.39 kW	1.28 kW
COP Tj = 12°C	7.83	5.59
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.03 kW	5.05 kW
COP Tj = Tbiv	3.09	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.36 kW	4.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.18 kW
Annual energy consumption Qhe	2846 kWh	3341 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.18 kW	6.70 kW
SEER	4.75	8.44
Pdc Tj = 35°C	7.18 kW	6.70 kW
EER Tj = 35°C	3.01	4.95
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	5.21 kW	4.93 kW
EER Tj = 30°C	4.47	7.22
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.42 kW	3.51 kW
EER Tj = 25°C	5.21	9.45
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	1.51 kW	1.43 kW
EER Tj = 20°C	5.68	12.89
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W

PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	907 kWh	477 kWh

Model ERIA S PLUS R32 4 MR/H		
Model name	ERIA S PLUS R32 4 MR/H	
Application	Heating (medium temp)	
Units	Indoor, Outdoor	
Climate zone (for heating)	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C	
Any additional heat sources	n/a	
General data		
Power supply	1x230V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	4.25 kW	4.40 kW
El input	0.82 kW	1.49 kW
COP	5.20	2.95
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	4.76 kW	4.64 kW
Cooling capacity	1.32	0.84
EER	3.60	5.50
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	193 %	132 %
Prated	5.52 kW	4.40 kW
SCOP	4.90	3.38
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	4.88 kW	3.89 kW
COP Tj = -7°C	3.19	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.06 kW	2.38 kW
COP Tj = +2°C	4.78	3.30
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.94 kW	1.56 kW
COP Tj = +7°C	6.40	4.41
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.48 kW	1.32 kW
COP Tj = 12°C	8.05	5.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.88 kW	3.89 kW
COP Tj = Tbiv	3.19	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	3.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.11 kW	0.98 kW
Annual energy consumption Qhe	2326 kWh	2686 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	4.76 kW	4.64 kW
SEER	4.44	8.25
Pdc Tj = 35°C	4.76 kW	4.64 kW
EER Tj = 35°C	3.60	5.50
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	3.44 kW	3.38 kW
EER Tj = 30°C	4.55	7.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	2.19 kW	2.09 kW
EER Tj = 25°C	5.12	8.95
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	0.95 kW	1.16 kW
EER Tj = 20°C	4.29	13.20
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W

PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	643 kWh	337 kWh

Model ERIA S PLUS R32 6 MR/H		
Model name	ERIA S PLUS R32 6 MR/H	
Application	Heating (medium temp)	
Units	Indoor, Outdoor	
Climate zone (for heating)	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C	
Any additional heat sources	n/a	
General data		
Power supply	n/a	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	6.20 kW	6.00 kW
El input	1.24 kW	2.00 kW
COP	5.00	3.00
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	7.18 kW	6.70 kW
Cooling capacity	2.39	1.35
EER	3.01	4.95
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	195 %	138 %
Prated	6.82 kW	5.70 kW
SCOP	4.95	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	6.03 kW	5.05 kW
COP Tj = -7°C	3.09	2.17
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.88 kW	3.12 kW
COP Tj = +2°C	4.85	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.40 kW	2.09 kW
COP Tj = +7°C	6.63	4.54
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.39 kW	1.28 kW
COP Tj = 12°C	7.83	5.59
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.03 kW	5.05 kW
COP Tj = Tbiv	3.09	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.36 kW	4.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.91
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.18 kW
Annual energy consumption Qhe	2846 kWh	3341 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.18 kW	6.70 kW
SEER	4.75	8.44
Pdc Tj = 35°C	7.18 kW	6.70 kW
EER Tj = 35°C	3.01	4.95
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	5.21 kW	4.93 kW
EER Tj = 30°C	4.47	7.22
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.42 kW	3.51 kW
EER Tj = 25°C	5.21	9.45
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	1.51 kW	1.43 kW
EER Tj = 20°C	5.68	12.89
Cdc Tj = 20 °C	0.900	0.900
Poff	14 W	14 W

PTO	10 W	10 W
PSB	14 W	14 W
PCK	0 W	0 W
Annual energy consumption Qce	907 kWh	477 kWh