

| Certificate Holder | Lailey and Coates International Limited |
|--------------------|---|
| ddress | No.128 ShaGangWest Road |
| TIP | 528477 |
| ity | GuangDong |
| Country | CN |
| ertification Body | BRE Global Limited |
| ubtype title | Inverter Heat Pump-Mono System 100 |
| egistration number | 041-K039-02 |
| eat Pump Type | Outdoor Air/Water |
| efrigerant | R32 |
| ass of Refrigerant | 2 kg |
| ertification Date | 18.11.2022 |
| esting basis | Heat Pump Keymark Scheme Rules Rev 11 |



| Model Outdoor Unit: LCM-100R; Indoor Unit | :: LCM-R | | |
|--|--|--------------------------------|--|
| Model name | Outdoor Unit: LCM-100R; Indoor Unit: LCM-R | | |
| Application | Heating (medium temp) | | |
| Units | Outdoor | | |
| Climate zone (for heating) | n/a | | |
| Reversibility | Yes | | |
| Cooling mode application (optional) | n/a | | |
| Any additional heat sources | n/a | | |
| General data | | | |
| | 1220\/ 50U- | | |
| Power supply | 1x230V 50Hz | | |
| Off-peak product | n/a | | |
| Outdoor Air/Water | | | |
| EN 14511-4 Heating | | | |
| Shutting off the heat transfer medium flow | passed | | |
| Complete power supply failure | passed | | |
| Defrost test | passed | | |
| Starting and operating test | passed | | |
| EN 12102-1 Average Climate | | | |
| LN 12102-1 Average Climate | | NA 12 1 | |
| Cound names lavel outdoor | Low temperature 68 dB(A) | Medium temperature 68 dB(A) | |
| Sound power level outdoor | 08 UB(A) | 08 UB(A) | |
| EN 14825 Average Climate | | | |
| | Low temperature | Medium temperature | |
| ης | 177 % | 134 % | |
| Prated | 6.54 kW | 6.08 kW | |
| SCOP | 4.50 | 3.43 | |
| Tbiv | -7 °C | -7 °C | |
| TOL | -10 °C | -10 °C | |
| Pdh Tj = -7°C | 5.79 kW | 5.38 kW | |
| COP Tj = -7°C | 2.67 | 1.89 | |
| Cdh Tj = -7 °C | 0.900 | 0.900 | |
| Pdh Tj = +2°C | 4.14 kW | 3.69 kW | |
| COP Tj = +2°C | 4.35 | 3.38 | |
| Cdh Tj = +2 °C | 0.900 | 0.900 | |
| <u> </u> | | | |
| Pdh Tj = +7°C | 3.21 kW | 4.13 kW | |
| COP Tj = +7°C | 6.09 | 4.68 | |
| Cdh Tj = $+7$ °C | 0.990 | 0.990 | |
| Pdh Tj = 12°C | 3.78 kW | 4.91 kW | |
| COP Tj = 12°C | 8.20 | 6.71 | |
| Cdh Tj = $+12$ °C | 0.990 | 0.990 | |
| Pdh Tj = Tbiv | 5.79 kW | 5.38 kW | |
| COP Tj = Tbiv | 2.67 | 1.89 | |



| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.02 kW | 5.28 kW |
|---|-------------|-------------|
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.44 | 1.70 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 59 °C | 59 °C |
| Poff | 8 W | 8 W |
| PTO | 8 W | 8 W |
| PSB | 8 W | 8 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.53 kW | 0.80 kW |
| Annual energy consumption Qhe | 3002 kWh | 3662 kWh |