

Subtype Ecodan Power Inverter (TR) 6/8/10 + 300F AA

Certificate Holder	Mitsubishi Electric Air Conditioning Systems Europe LTD
Address	Nettlehill Road, Houston Industrial Estate
ZIP	EH54 5EQ
City	Livingston
Country	GB
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
Subtype title	Ecodan Power Inverter (TR) 6/8/10 + 300F AA
Registration number	037-0143-23
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.8 kg
Certification Date	05.12.2023
Testing basis	HP Keymark scheme rules rev. no. 11

Model PUZ-SWM60VAA + ERST30F-*M*E

Model name	PUZ-SWM60VAA + ERST30F-*M*E
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.14
Heating up time	2:42 h:min
Standby power input	44.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5 kW	4 kW
El input	1 kW	1.63 kW
COP	5.02	2.45

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.46 kW	1.11 kW
Cooling capacity	5.1	6
EER	3.5	5.4

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	185 %	128 %
Prated	6 kW	6 kW
SCOP	4.7	3.29
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.37 kW	5.31 kW
COP Tj = -7°C	3.38	2.27
Cdh Tj = -7 °C	0.991	0.994
Pdh Tj = +2°C	4.79 kW	4.4 kW
COP Tj = +2°C	4.77	3.2
Cdh Tj = +2 °C	0.985	0.989
Pdh Tj = +7°C	4.9 kW	4.1 kW
COP Tj = +7°C	5.61	3.99
Cdh Tj = +7 °C	0.983	0.985
Pdh Tj = 12°C	3 kW	2.7 kW
COP Tj = 12°C	6.19	5.58
Cdh Tj = +12 °C	0.969	0.969
Pdh Tj = Tbiv	6 kW	6 kW
COP Tj = Tbiv	2.74	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6 kW	6 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.74	1.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.993	0.995
WTOL	70 °C	70 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2640 kWh	3772 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	5.1 kW	6 kW
SEER	3.89	5.93
Pdc Tj = 35°C	5.1 kW	6 kW
EER Tj = 35°C	3.5	5.4
Cdc Tj = 35 °C	0.99	0.987

Pdc Tj = 30°C	3.76 kW	4.42 kW
EER Tj = 30°C	3.84	5.95
Cdc Tj = 30 °C	0.985	0.98
Pdc Tj = 25°C	2.42 kW	3.3 kW
EER Tj = 25°C	4.07	6.38
Cdc Tj = 25 °C	0.975	0.971
Pdc Tj = 20°C	2.5 kW	3.5 kW
EER Tj = 20°C	4.57	7
Cdc Tj = 20 °C	0.973	0.97
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Annual energy consumption Qce	787 kWh	608 kWh

Model PUZ-SWM80VAA + ERST30F-*M*E

Model name	PUZ-SWM80VAA + ERST30F-*M*E
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.14
Heating up time	2:42 h:min
Standby power input	44.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6 kW	4 kW
El input	1.2 kW	1.6 kW
COP	5.02	2.5

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.15 kW	1.62 kW
Cooling capacity	7.1	8
EER	3.3	4.95

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	184 %	130 %
Prated	8 kW	8 kW
SCOP	4.68	3.34
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.08 kW	7.08 kW
COP Tj = -7°C	3.22	2.27
Cdh Tj = -7 °C	0.993	0.995
Pdh Tj = +2°C	4.4 kW	4.4 kW
COP Tj = +2°C	4.78	3.2
Cdh Tj = +2 °C	0.984	0.989
Pdh Tj = +7°C	5 kW	4.4 kW
COP Tj = +7°C	5.61	4.18
Cdh Tj = +7 °C	0.983	0.986
Pdh Tj = 12°C	3 kW	2.8 kW
COP Tj = 12°C	6.19	5.79
Cdh Tj = +12 °C	0.969	0.969
Pdh Tj = Tbiv	7.08 kW	7.08 kW
COP Tj = Tbiv	3.2	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.5 kW	7.4 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.995	0.996
WTOL	70 °C	70 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.5 kW	0.6 kW
Annual energy consumption Qhe	3528 kWh	4952 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.1 kW	8 kW
SEER	4.13	5.74
Pdc Tj = 35°C	7.1 kW	8 kW
EER Tj = 35°C	3.3	4.95
Cdc Tj = 35 °C	0.993	0.991

Pdc Tj = 30°C	5.23 kW	5.92 kW
EER Tj = 30°C	3.85	5.7
Cdc Tj = 30 °C	0.989	0.986
Pdc Tj = 25°C	3.36 kW	3.79 kW
EER Tj = 25°C	4.55	6
Cdc Tj = 25 °C	0.98	0.976
Pdc Tj = 20°C	2.5 kW	3.5 kW
EER Tj = 20°C	4.69	6.75
Cdc Tj = 20 °C	0.972	0.971
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Annual energy consumption Qce	1031 kWh	836 kWh

Model PUZ-SWM80YAA + ERST30F-*M*E

Model name	PUZ-SWM80YAA + ERST30F-*M*E
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.14
Heating up time	2:42 h:min
Standby power input	44.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6 kW	4 kW
El input	1.2 kW	1.6 kW
COP	5.02	2.5

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.15 kW	1.62 kW
Cooling capacity	7.1	8
EER	3.3	4.95

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	54 dB(A)	54 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	184 %	130 %
Prated	8 kW	8 kW
SCOP	4.67	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.08 kW	7.08 kW
COP Tj = -7°C	3.22	2.27
Cdh Tj = -7 °C	0.99	0.993
Pdh Tj = +2°C	4.4 kW	4.4 kW
COP Tj = +2°C	4.78	3.2
Cdh Tj = +2 °C	0.976	0.984
Pdh Tj = +7°C	5 kW	4.4 kW
COP Tj = +7°C	5.61	4.18
Cdh Tj = +7 °C	0.975	0.979
Pdh Tj = 12°C	3 kW	2.8 kW
COP Tj = 12°C	6.19	5.79
Cdh Tj = +12 °C	0.955	0.955
Pdh Tj = Tbiv	7.08 kW	7.08 kW
COP Tj = Tbiv	3.2	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.5 kW	7.4 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.992	0.995
WTOL	70 °C	70 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.5 kW	0.6 kW
Annual energy consumption Qhe	3540 kWh	4964 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.1 kW	8 kW
SEER	4.07	5.63
Pdc Tj = 35°C	7.1 kW	8 kW
EER Tj = 35°C	3.3	4.95
Cdc Tj = 35 °C	0.99	0.986

Pdc Tj = 30°C	5.23 kW	5.92 kW
EER Tj = 30°C	3.85	5.7
Cdc Tj = 30 °C	0.984	0.979
Pdc Tj = 25°C	3.36 kW	3.79 kW
EER Tj = 25°C	4.55	6
Cdc Tj = 25 °C	0.97	0.965
Pdc Tj = 20°C	2.5 kW	3.5 kW
EER Tj = 20°C	4.69	6.75
Cdc Tj = 20 °C	0.959	0.958
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Annual energy consumption Qce	1048 kWh	853 kWh

Model PUZ-SWM100VAA + ERST30F-*M*E

Model name	PUZ-SWM100VAA + ERST30F-*M*E
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.14
Heating up time	2:42 h:min
Standby power input	44.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8 kW	7 kW
El input	1.59 kW	2.59 kW
COP	5.02	2.7

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	3 kW	2.22 kW
Cooling capacity	9	10
EER	3	4.5

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	134 %
Prated	10 kW	10 kW
SCOP	4.6	3.42
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.8 kW	8.8 kW
COP Tj = -7°C	3.05	2.15
Cdh Tj = -7 °C	0.995	0.996
Pdh Tj = +2°C	5.4 kW	5.4 kW
COP Tj = +2°C	4.61	3.35
Cdh Tj = +2 °C	0.987	0.991
Pdh Tj = +7°C	5.2 kW	4.8 kW
COP Tj = +7°C	5.7	4.39
Cdh Tj = +7 °C	0.984	0.986
Pdh Tj = 12°C	3.2 kW	2.9 kW
COP Tj = 12°C	6.61	5.99
Cdh Tj = +12 °C	0.969	0.969
Pdh Tj = Tbiv	8.8 kW	8.8 kW
COP Tj = Tbiv	3.05	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9 kW	8.5 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.7
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.996	0.997
WTOL	70 °C	70 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1 kW	1.5 kW
Annual energy consumption Qhe	4494 kWh	6033 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	9 kW	10 kW
SEER	3.98	5.73
Pdc Tj = 35°C	9 kW	10 kW
EER Tj = 35°C	3	4.5
Cdc Tj = 35 °C	0.995	0.993

Pdc Tj = 30°C	6.63 kW	7.37 kW
EER Tj = 30°C	3.82	5.68
Cdc Tj = 30 °C	0.991	0.988
Pdc Tj = 25°C	4.26 kW	4.74 kW
EER Tj = 25°C	4.43	6.05
Cdc Tj = 25 °C	0.984	0.981
Pdc Tj = 20°C	2.5 kW	3.5 kW
EER Tj = 20°C	4.23	6.55
Cdc Tj = 20 °C	0.975	0.972
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Annual energy consumption Qce	1357 kWh	1047 kWh

Model PUZ-SWM100YAA + ERST30F-*M*E

Model name	PUZ-SWM100YAA + ERST30F-*M*E
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.14
Heating up time	2:42 h:min
Standby power input	44.2 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8 kW	7 kW
El input	1.59 kW	2.59 kW
COP	5.02	2.7

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	3 kW	2.22 kW
Cooling capacity	9	10
EER	3	4.5

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	180 %	134 %
Prated	10 kW	10 kW
SCOP	4.59	3.42
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.8 kW	8.8 kW
COP Tj = -7°C	3.05	2.15
Cdh Tj = -7 °C	0.992	0.995
Pdh Tj = +2°C	5.4 kW	5.4 kW
COP Tj = +2°C	4.61	3.35
Cdh Tj = +2 °C	0.981	0.986
Pdh Tj = +7°C	5.2 kW	4.8 kW
COP Tj = +7°C	5.7	4.39
Cdh Tj = +7 °C	0.976	0.98
Pdh Tj = 12°C	3.2 kW	2.9 kW
COP Tj = 12°C	6.61	5.99
Cdh Tj = +12 °C	0.955	0.955
Pdh Tj = Tbiv	8.8 kW	8.8 kW
COP Tj = Tbiv	3.05	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9 kW	8.5 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.4	1.7
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.994	0.996
WTOL	70 °C	70 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1 kW	1.5 kW
Annual energy consumption Qhe	4505 kWh	6042 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	9 kW	10 kW
SEER	3.93	5.64
Pdc Tj = 35°C	9 kW	10 kW
EER Tj = 35°C	3	4.5
Cdc Tj = 35 °C	0.993	0.99

Pdc Tj = 30°C	6.63 kW	7.37 kW
EER Tj = 30°C	3.82	5.68
Cdc Tj = 30 °C	0.987	0.983
Pdc Tj = 25°C	4.26 kW	4.74 kW
EER Tj = 25°C	4.43	6.05
Cdc Tj = 25 °C	0.977	0.972
Pdc Tj = 20°C	2.5 kW	3.5 kW
EER Tj = 20°C	4.23	6.55
Cdc Tj = 20 °C	0.963	0.959
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Annual energy consumption Qce	1372 kWh	1064 kWh