

Subtype Alféa Extensa M Compact 11

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	Alféa Extensa M Compact 11
Registration number	012-C700221
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.47 kg
Certification Date	29.11.2023
Testing basis	EN 14511:2022, EN 14825:2022, EN 12102:2022..

Model Alféa Extensa M Compact 11

Model name	Alféa Extensa M Compact 11
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.00 kW	10.00 kW
El input	2.05 kW	3.36 kW
COP	4.88	2.98

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	206 %	146 %
Prated	10.20 kW	9.90 kW
SCOP	5.24	3.73
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.00 kW	8.80 kW
COP Tj = -7°C	3.14	2.25
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	5.50 kW	5.30 kW
COP Tj = +2°C	5.22	3.62
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	4.00 kW	3.70 kW
COP Tj = +7°C	7.07	5.09

Cdh Tj = +7 �C	0.970	0.980
Pdh Tj = 12�C	4.50 kW	4.40 kW
COP Tj = 12�C	8.89	6.93
Cdh Tj = +12 �C	0.970	0.970
Pdh Tj = Tbiv	9.00 kW	8.80 kW
COP Tj = Tbiv	3.14	2.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.81	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	60 �C	60 �C
Poff	8 W	8 W
PTO	17 W	16 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.20 kW	1.90 kW
Annual energy consumption Qhe	4018 kWh	5480 kWh