

Subtype Carrier XP ENERGY T 14T AIO

Certificate Holder	Riello S.p.A.
Address	Via Ing. Pilade Riello 7
ZIP	37045
City	Legnago (VR)
Country	IT
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Carrier XP ENERGY T 14T AIO
Registration number	011-1W0712
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.4 kg
Certification Date	24.10.2023
Testing basis	HP KEYMARK certification scheme rules V12

Model 38AW140H9RT / 80AWX140M31RTA

Model name	38AW140H9RT / 80AWX140M31RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	126 %
COP	3.05
Heating up time	0:41 h:min
Standby power input	38 W
Reference hot water temperature	48.8 °C
Mixed water at 40°C	220 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14 kW	15.5 kW
El input	3.04 kW	5.6 kW
COP	4.6	2.77

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	138 %
Prated	11 kW	11 kW

SCOP	4.57	3.55
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.06 kW	9.93 kW
COP Tj = -7°C	2.68	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	6.23 kW	6.24 kW
COP Tj = +2°C	4.55	3.34
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	3.97 kW	3.86 kW
COP Tj = +7°C	6.27	4.76
Cdh Tj = +7 °C	0.92	0.93
Pdh Tj = 12°C	4.28 kW	4.24 kW
COP Tj = 12°C	9.16	7.27
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	10.06 kW	9.93 kW
COP Tj = Tbiv	2.68	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.88 kW	9.35 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.89	0.91
WTOL	65 °C	65 °C
Poff	11 W	11 W
PTO	52 W	52 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.12 kW	1.7 kW
Annual energy consumption Qhe	5053 kWh	6567 kWh

Model 38AW140H9RT / 80AWX140M61RTA

Model name	38AW140H9RT / 80AWX140M61RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	126 %
COP	3.05
Heating up time	0:41 h:min
Standby power input	38 W
Reference hot water temperature	48.8 °C
Mixed water at 40°C	220 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14 kW	15.5 kW
El input	3.04 kW	5.6 kW
COP	4.6	2.77

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	138 %
Prated	11 kW	11 kW

SCOP	4.57	3.55
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.06 kW	9.93 kW
COP Tj = -7°C	2.68	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	6.23 kW	6.24 kW
COP Tj = +2°C	4.55	3.34
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	3.97 kW	3.86 kW
COP Tj = +7°C	6.27	4.76
Cdh Tj = +7 °C	0.92	0.93
Pdh Tj = 12°C	4.28 kW	4.24 kW
COP Tj = 12°C	9.16	7.27
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	10.06 kW	9.93 kW
COP Tj = Tbiv	2.68	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.88 kW	9.35 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.89	0.91
WTOL	65 °C	65 °C
Poff	11 W	11 W
PTO	52 W	52 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.12 kW	1.7 kW
Annual energy consumption Qhe	5053 kWh	6567 kWh

Model 38AW140H9RT / 80AWX140T61RTA

Model name	38AW140H9RT / 80AWX140T61RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	126 %
COP	3.05
Heating up time	0:41 h:min
Standby power input	38 W
Reference hot water temperature	48.8 °C
Mixed water at 40°C	220 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14 kW	15.5 kW
El input	3.04 kW	5.6 kW
COP	4.6	2.77

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	138 %
Prated	11 kW	11 kW

SCOP	4.57	3.55
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.06 kW	9.93 kW
COP Tj = -7°C	2.68	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	6.23 kW	6.24 kW
COP Tj = +2°C	4.55	3.34
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	3.97 kW	3.86 kW
COP Tj = +7°C	6.27	4.76
Cdh Tj = +7 °C	0.92	0.93
Pdh Tj = 12°C	4.28 kW	4.24 kW
COP Tj = 12°C	9.16	7.27
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	10.06 kW	9.93 kW
COP Tj = Tbiv	2.68	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.88 kW	9.35 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.89	0.91
WTOL	65 °C	65 °C
Poff	11 W	11 W
PTO	52 W	52 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.12 kW	1.7 kW
Annual energy consumption Qhe	5053 kWh	6567 kWh

Model 38AW140H9RT / 80AWX140M32RTA

Model name	38AW140H9RT / 80AWX140M32RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	126 %
COP	3.05
Heating up time	0:41 h:min
Standby power input	38 W
Reference hot water temperature	48.8 °C
Mixed water at 40°C	220 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14 kW	15.5 kW
El input	3.04 kW	5.6 kW
COP	4.6	2.77

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	138 %
Prated	11 kW	11 kW

SCOP	4.57	3.55
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.06 kW	9.93 kW
COP Tj = -7°C	2.68	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	6.23 kW	6.24 kW
COP Tj = +2°C	4.55	3.34
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	3.97 kW	3.86 kW
COP Tj = +7°C	6.27	4.76
Cdh Tj = +7 °C	0.92	0.93
Pdh Tj = 12°C	4.28 kW	4.24 kW
COP Tj = 12°C	9.16	7.27
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	10.06 kW	9.93 kW
COP Tj = Tbiv	2.68	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.88 kW	9.35 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.89	0.91
WTOL	65 °C	65 °C
Poff	11 W	11 W
PTO	52 W	52 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.12 kW	1.7 kW
Annual energy consumption Qhe	5053 kWh	6567 kWh

Model 38AW140H9RT / 80AWX140M62RTA

Model name	38AW140H9RT / 80AWX140M62RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	126 %
COP	3.05
Heating up time	0:41 h:min
Standby power input	38 W
Reference hot water temperature	48.8 °C
Mixed water at 40°C	220 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14 kW	15.5 kW
El input	3.04 kW	5.6 kW
COP	4.6	2.77

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	138 %
Prated	11 kW	11 kW

SCOP	4.57	3.55
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.06 kW	9.93 kW
COP Tj = -7°C	2.68	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	6.23 kW	6.24 kW
COP Tj = +2°C	4.55	3.34
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	3.97 kW	3.86 kW
COP Tj = +7°C	6.27	4.76
Cdh Tj = +7 °C	0.92	0.93
Pdh Tj = 12°C	4.28 kW	4.24 kW
COP Tj = 12°C	9.16	7.27
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	10.06 kW	9.93 kW
COP Tj = Tbiv	2.68	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.88 kW	9.35 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.89	0.91
WTOL	65 °C	65 °C
Poff	11 W	11 W
PTO	52 W	52 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.12 kW	1.7 kW
Annual energy consumption Qhe	5053 kWh	6567 kWh

Model 38AW140H9RT / 80AWX140T62RTA

Model name	38AW140H9RT / 80AWX140T62RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	126 %
COP	3.05
Heating up time	0:41 h:min
Standby power input	38 W
Reference hot water temperature	48.8 °C
Mixed water at 40°C	220 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14 kW	15.5 kW
El input	3.04 kW	5.6 kW
COP	4.6	2.77

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	183 %	138 %
Prated	11 kW	11 kW

SCOP	4.57	3.55
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.06 kW	9.93 kW
COP Tj = -7°C	2.68	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	6.23 kW	6.24 kW
COP Tj = +2°C	4.55	3.34
Cdh Tj = +2 °C	0.96	0.97
Pdh Tj = +7°C	3.97 kW	3.86 kW
COP Tj = +7°C	6.27	4.76
Cdh Tj = +7 °C	0.92	0.93
Pdh Tj = 12°C	4.28 kW	4.24 kW
COP Tj = 12°C	9.16	7.27
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	10.06 kW	9.93 kW
COP Tj = Tbiv	2.68	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.88 kW	9.35 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	2.01
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.89	0.91
WTOL	65 °C	65 °C
Poff	11 W	11 W
PTO	52 W	52 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.12 kW	1.7 kW
Annual energy consumption Qhe	5053 kWh	6567 kWh