

Subtype DAIKIN ALTHERMA H ECH2O 5KW (300L)

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA H ECH2O 5KW (300L)
Registration number	011-1W0268
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	1.3 kg

Model EBLQ05C2V3 / EKHWMXB300C

Model name	EBLQ05C2V3 / EKHWMXB300C
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	96 %
COP	2.29
Heating up time	1:56 h:min
Standby power input	45.0 W
Reference hot water temperature	48.0 °C
Mixed water at 40°C	155 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20

Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.36 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh

Model EBLQ05C2V3 / EKHWMX300C

Model name	EBLQ05C2V3 / EKHWMX300C
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	96 %
COP	2.29
Heating up time	1:56 h:min
Standby power input	45.0 W
Reference hot water temperature	48.0 °C
Mixed water at 40°C	155 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.40 kW	4.20 kW
El input	0.88 kW	1.56 kW
COP	5.00	2.70

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	172 %	125 %
Prated	4.40 kW	4.20 kW
SCOP	4.39	3.20

Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.60 kW
COP Tj = -7°C	2.90	1.98
Pdh Tj = +2°C	2.40 kW	2.10 kW
COP Tj = +2°C	4.21	3.10
Pdh Tj = +7°C	1.70 kW	2.80 kW
COP Tj = +7°C	5.85	4.27
Pdh Tj = 12°C	2.04 kW	2.70 kW
COP Tj = 12°C	7.71	6.33
Pdh Tj = Tbiv	4.36 kW	4.20 kW
COP Tj = Tbiv	2.52	1.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.36 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.65
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	6 W	6 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2040 kWh	2679 kWh