

Subtype DAIKIN ALTHERMA H ECH2O 7KW (300L)

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA H ECH2O 7KW (300L)
Registration number	011-1W0270
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	1.45 kg

Model EBLQ07C2V3 / EKHWMXB300C

Model name	EBLQ07C2V3 / EKHWMXB300C
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	87 %
COP	2.09
Heating up time	1:35 h:min
Standby power input	47.0 W
Reference hot water temperature	48.2 °C
Mixed water at 40°C	155 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.00 kW	6.10 kW
El input	1.55 kW	2.22 kW
COP	4.52	2.75

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	163 %	125 %
Prated	7.00 kW	6.10 kW
SCOP	4.14	3.22

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	5.50 kW
COP Tj = -7°C	2.57	1.98
Pdh Tj = +2°C	3.77 kW	3.20 kW
COP Tj = +2°C	4.00	3.17
Pdh Tj = +7°C	2.59 kW	3.60 kW
COP Tj = +7°C	5.75	4.20
Pdh Tj = 12°C	2.61 kW	3.40 kW
COP Tj = 12°C	7.27	5.82
Pdh Tj = Tbiv	6.20 kW	5.50 kW
COP Tj = Tbiv	2.57	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.81 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.15	1.74
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	8 W	8 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.19 kW	3.00 kW
Annual energy consumption Qhe	3460 kWh	3906 kWh

Model EBLQ07C2V3 / EKHWMX300C

Model name	EBLQ07C2V3 / EKHWMX300C
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	87 %
COP	2.09
Heating up time	1:35 h:min
Standby power input	47.0 W
Reference hot water temperature	48.2 °C
Mixed water at 40°C	155 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.00 kW	6.10 kW
El input	1.55 kW	2.22 kW
COP	4.52	2.75

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	163 %	125 %
Prated	7.00 kW	6.10 kW
SCOP	4.14	3.22

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.20 kW	5.50 kW
COP Tj = -7°C	2.57	1.98
Pdh Tj = +2°C	3.77 kW	3.20 kW
COP Tj = +2°C	4.00	3.17
Pdh Tj = +7°C	2.59 kW	3.60 kW
COP Tj = +7°C	5.75	4.20
Pdh Tj = 12°C	2.61 kW	3.40 kW
COP Tj = 12°C	7.27	5.82
Pdh Tj = Tbiv	6.20 kW	5.50 kW
COP Tj = Tbiv	2.57	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.81 kW	3.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.15	1.74
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	8 W	8 W
PTO	8 W	8 W
PSB	8 W	8 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.19 kW	3.00 kW
Annual energy consumption Qhe	3460 kWh	3906 kWh