

Subtype THERMOR AEROLIA TRI 11 2024

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	THERMOR AEROLIA TRI 11 2024
Registration number	012-C700295
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.5 kg
Certification Date	16.04.2024
Testing basis	EN 14511:2022, EN 14825:2022, EN 16147:2017, EN 12102:2022

Model THERMOR AEROLIA TRI 11 2024

Model name	THERMOR AEROLIA TRI 11 2024
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.80 kW	9.30 kW
El input	2.51 kW	3.52 kW
COP	4.30	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	157 %	118 %
Prated	11.30 kW	9.30 kW
SCOP	4.00	3.02
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.74	1.93
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.79	2.92
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.40 kW	5.80 kW

COP Tj = +7°C	5.38	4.14
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	7.50 kW	7.30 kW
COP Tj = 12°C	6.81	5.32
Cdh Tj = +12 °C	0.980	0.980
Pdh Tj = Tbiv	10.00 kW	8.20 kW
COP Tj = Tbiv	2.74	1.93
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.30 kW	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.46	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	22 W	22 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.70 kW
Annual energy consumption Qhe	5834 kWh	6353 kWh

Model THERMOR AEROLIA DUO TRI 11 2024

Model name	THERMOR AEROLIA DUO TRI 11 2024
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	100 %
COP	2.50
Heating up time	1:10 h:min
Standby power input	40.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	250 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.80 kW	9.30 kW
El input	2.51 kW	3.52 kW
COP	4.30	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	157 %	118 %
Prated	11.30 kW	9.30 kW
SCOP	4.00	3.02

Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.74	1.93
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.79	2.92
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.40 kW	5.80 kW
COP Tj = +7°C	5.38	4.14
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	7.50 kW	7.30 kW
COP Tj = 12°C	6.81	5.32
Cdh Tj = +12 °C	0.980	0.980
Pdh Tj = Tbiv	10.00 kW	8.20 kW
COP Tj = Tbiv	2.74	1.93
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.30 kW	7.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.46	1.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	22 W	22 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	1.70 kW
Annual energy consumption Qhe	5834 kWh	6353 kWh