

Subtype Alféa Excellia HP A.I. Tri 15

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	Alféa Excellia HP A.I. Tri 15
Registration number	012-SC0306-18
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	3.8 kg
Certification Date	09.12.2022
Testing basis	EN 14511:2013, EN 16147:2017, EN 14825:2016, EN 12102:2013

Model Alféa Excellia HP A.I. Tri 15

Model name	Alféa Excellia HP A.I. Tri 15
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	15.10 kW	13.46 kW
El input	3.48 kW	4.75 kW
COP	4.34	2.83

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	130 %
Prated	17.40 kW	16.00 kW
SCOP	4.18	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	15.40 kW	14.20 kW
COP Tj = -7°C	2.90	2.12
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	9.40 kW	8.60 kW
COP Tj = +2°C	4.19	3.30
Cdh Tj = +2 °C	0.960	0.980
Pdh Tj = +7°C	6.70 kW	6.40 kW
COP Tj = +7°C	5.13	4.21

Cdh Tj = +7 �C	0.930	0.970
Pdh Tj = 12�C	8.00 kW	7.60 kW
COP Tj = 12�C	6.83	6.02
Cdh Tj = +12 �C	0.920	0.970
Pdh Tj = Tbiv	15.40 kW	14.20 kW
COP Tj = Tbiv	2.90	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.980	0.970
WTOL	60 �C	60 �C
Poff	16 W	16 W
PTO	96 W	43 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.70 kW	2.70 kW
Annual energy consumption Qhe	8606 kWh	9915 kWh

Model Alféa Excellia HP Duo A.I. Tri 15

Model name	Alféa Excellia HP Duo A.I. Tri 15
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	109 %
COP	2.56
Heating up time	0:54 h:min
Standby power input	48.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	250 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	15.10 kW	13.46 kW
El input	3.48 kW	4.75 kW
COP	4.34	2.83

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	130 %
Prated	17.40 kW	16.00 kW
SCOP	4.18	3.33
Tbiv	-7 °C	-7 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	15.40 kW	14.20 kW
COP Tj = -7°C	2.90	2.12
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	9.40 kW	8.60 kW
COP Tj = +2°C	4.19	3.30
Cdh Tj = +2 °C	0.960	0.980
Pdh Tj = +7°C	6.70 kW	6.40 kW
COP Tj = +7°C	5.13	4.21
Cdh Tj = +7 °C	0.930	0.970
Pdh Tj = 12°C	8.00 kW	7.60 kW
COP Tj = 12°C	6.83	6.02
Cdh Tj = +12 °C	0.920	0.970
Pdh Tj = Tbiv	15.40 kW	14.20 kW
COP Tj = Tbiv	2.90	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.980	0.970
WTOL	60 °C	60 °C
Poff	16 W	16 W
PTO	96 W	43 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.70 kW	2.70 kW
Annual energy consumption Qhe	8606 kWh	9915 kWh