

Subtype TTF 04, TTF 04 cool, TTC 04, TTC 04 cool

Certificate Holder	tecalor GmbH
Address	Fürstenbergerstr. 77
ZIP	37603
City	Holzminden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	TTF 04, TTF 04 cool, TTC 04, TTC 04 cool
Registration number	011-1W0038
Heat Pump Type	Brine/Water
Refrigerant	R410A
Mass of Refrigerant	1.05 kg
Certification Date	01.11.2016

Model TTF 04, all climates

Model name	TTF 04, all climates
Application	Heating (low temp)
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	
Prated	5.00 kW	
SCOP	4.92	
Tbiv	-10 °C	
TOL	-10 °C	
Pdh Tj = -7°C	4.80 kW	
COP Tj = -7°C	4.55	
Cdh Tj = -7 °C	0.90	
Pdh Tj = +2°C	4.80 kW	
COP Tj = +2°C	4.87	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.90 kW	
COP Tj = +7°C	5.18	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.52	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.50	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2002 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	195 %	
Prated	6.00 kW	
SCOP	5.07	
Tbiv	-15 °C	
TOL	-22 °C	
Pdh Tj = -7°C	4.90 kW	
COP Tj = -7°C	5.03	
Cdh Tj = -7 °C	0.90	
Pdh Tj = +2°C	4.90 kW	
COP Tj = +2°C	5.27	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.90 kW	
COP Tj = +7°C	5.47	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.50	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.92	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.92	
WTOL	65 °C	
Poff	0 W	
PTO	54 W	
PSB	9 W	
PCK	0 W	
Supplementary Heater: Type of energy input	Electricity	
Supplementary Heater: PSUP	1.17 kW	
Annual energy consumption Qhe	2888 kWh	
Pdh Tj = -15°C (if TOL	4.80	

COP Tj = -15°C (if TOL	4.92
Cdh Tj = -15 °C	0.90

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	187 %	
Prated	5.00 kW	
SCOP	4.87	
Tbiv	2 °C	
TOL	0 °C	
Pdh Tj = +2°C	4.80 kW	
COP Tj = +2°C	4.50	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.80 kW	
COP Tj = +7°C	4.80	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.29	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.50	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	
WTOL	65 °C	
Poff	0 W	
PTO	54 W	
PSB	9 W	
PCK	0 W	
Supplementary Heater: Type of energy input	Electricity	
Supplementary Heater: PSUP	0.00 kW	
Annual energy consumption Qhe	1310 kWh	

Model TTF 04, average climates

Model name	TTF 04, average climates
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	128 %
Prated	5.00 kW	4.00 kW
SCOP	4.92	3.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.80 kW	4.30 kW
COP Tj = -7°C	4.55	2.85
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.80 kW	4.50 kW
COP Tj = +2°C	4.87	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.90 kW	4.60 kW
COP Tj = +7°C	5.18	3.73
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.90 kW	4.70 kW
COP Tj = 12°C	5.52	4.18
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.80 kW	4.30 kW
COP Tj = Tbiv	4.50	2.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.30 kW

COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	4.50	2.72
WTOL	65 °C	65 °C
P _{off}	0 W	0 W
PTO	54 W	54 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2002 kWh	2583 kWh

Model TTF 04 cool, all climates

Model name	TTF 04 cool, all climates
Application	Heating (low temp)
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	
Prated	5.00 kW	
SCOP	4.92	
Tbiv	-10 °C	
TOL	-10 °C	
Pdh Tj = -7°C	4.80 kW	
COP Tj = -7°C	4.55	
Cdh Tj = -7 °C	0.90	
Pdh Tj = +2°C	4.80 kW	
COP Tj = +2°C	4.87	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.90 kW	
COP Tj = +7°C	5.18	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.52	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.50	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2002 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	195 %	
Prated	6.00 kW	
SCOP	5.07	
Tbiv	-15 °C	
TOL	-22 °C	
Pdh Tj = -7°C	4.90 kW	
COP Tj = -7°C	5.03	
Cdh Tj = -7 °C	0.90	
Pdh Tj = +2°C	4.90 kW	
COP Tj = +2°C	5.27	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.90 kW	
COP Tj = +7°C	5.47	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.50	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.92	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.92	
WTOL	65 °C	
Poff	0 W	
PTO	54 W	
PSB	9 W	
PCK	0 W	
Supplementary Heater: Type of energy input	Electricity	
Supplementary Heater: PSUP	1.17 kW	
Annual energy consumption Qhe	2888 kWh	
Pdh Tj = -15°C (if TOL	4.80	

COP Tj = -15°C (if TOL	4.92
Cdh Tj = -15 °C	0.90

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	187 %	
Prated	5.00 kW	
SCOP	4.87	
Tbiv	2 °C	
TOL	0 °C	
Pdh Tj = +2°C	4.80 kW	
COP Tj = +2°C	4.50	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.80 kW	
COP Tj = +7°C	4.80	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.29	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.50	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	
WTOL	65 °C	
Poff	0 W	
PTO	54 W	
PSB	9 W	
PCK	0 W	
Supplementary Heater: Type of energy input	Electricity	
Supplementary Heater: PSUP	0.00 kW	
Annual energy consumption Qhe	1310 kWh	

Model TTF 04 cool, average climates

Model name	TTF 04 cool, average climates
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	128 %
Prated	5.00 kW	4.00 kW
SCOP	4.92	3.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.80 kW	4.30 kW
COP Tj = -7°C	4.55	2.85
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.80 kW	4.50 kW
COP Tj = +2°C	4.87	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.90 kW	4.60 kW
COP Tj = +7°C	5.18	3.73
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.90 kW	4.70 kW
COP Tj = 12°C	5.52	4.18
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.80 kW	4.30 kW
COP Tj = Tbiv	4.50	2.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.30 kW

COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	4.50	2.72
WTOL	65 °C	65 °C
P _{off}	0 W	0 W
PTO	54 W	54 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2002 kWh	2583 kWh

Model TTC 04, all climates

Model name	TTC 04, all climates
Application	Heating (low temp)
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	
Prated	5.00 kW	
SCOP	4.92	
Tbiv	-10 °C	
TOL	-10 °C	
Pdh Tj = -7°C	4.80 kW	
COP Tj = -7°C	4.55	
Cdh Tj = -7 °C	0.90	
Pdh Tj = +2°C	4.80 kW	
COP Tj = +2°C	4.87	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.90 kW	
COP Tj = +7°C	5.18	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.52	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.50	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2002 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	195 %	
Prated	6.00 kW	
SCOP	5.07	
Tbiv	-15 °C	
TOL	-22 °C	
Pdh Tj = -7°C	4.90 kW	
COP Tj = -7°C	5.03	
Cdh Tj = -7 °C	0.90	
Pdh Tj = +2°C	4.90 kW	
COP Tj = +2°C	5.27	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.90 kW	
COP Tj = +7°C	5.47	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.50	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.92	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.92	
WTOL	65 °C	
Poff	0 W	
PTO	54 W	
PSB	9 W	
PCK	0 W	
Supplementary Heater: Type of energy input	Electricity	
Supplementary Heater: PSUP	1.17 kW	
Annual energy consumption Qhe	2888 kWh	
Pdh Tj = -15°C (if TOL	4.80	

COP Tj = -15°C (if TOL	4.92
Cdh Tj = -15 °C	0.90

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	187 %	
Prated	5.00 kW	
SCOP	4.87	
Tbiv	2 °C	
TOL	0 °C	
Pdh Tj = +2°C	4.80 kW	
COP Tj = +2°C	4.50	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.80 kW	
COP Tj = +7°C	4.80	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.29	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.50	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	
WTOL	65 °C	
Poff	0 W	
PTO	54 W	
PSB	9 W	
PCK	0 W	
Supplementary Heater: Type of energy input	Electricity	
Supplementary Heater: PSUP	0.00 kW	
Annual energy consumption Qhe	1310 kWh	

Model TTC 04, average climates

Model name	TTC 04, average climates
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	128 %
Prated	5.00 kW	4.00 kW
SCOP	4.92	3.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.80 kW	4.30 kW
COP Tj = -7°C	4.55	2.85
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.80 kW	4.50 kW
COP Tj = +2°C	4.87	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.90 kW	4.60 kW
COP Tj = +7°C	5.18	3.73
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.90 kW	4.70 kW
COP Tj = 12°C	5.52	4.18
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.80 kW	4.30 kW
COP Tj = Tbiv	4.50	2.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.30 kW

COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	4.50	2.72
WTOL	65 °C	65 °C
P _{off}	0 W	0 W
PTO	54 W	54 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2002 kWh	2583 kWh

Model TTC 04 cool, all climates

Model name	TTC 04 cool, all climates
Application	Heating (low temp)
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	
Prated	5.00 kW	
SCOP	4.92	
Tbiv	-10 °C	
TOL	-10 °C	
Pdh Tj = -7°C	4.80 kW	
COP Tj = -7°C	4.55	
Cdh Tj = -7 °C	0.90	
Pdh Tj = +2°C	4.80 kW	
COP Tj = +2°C	4.87	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.90 kW	
COP Tj = +7°C	5.18	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.52	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.50	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50
WTOL	65 °C
Poff	0 W
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2002 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	195 %	
Prated	6.00 kW	
SCOP	5.07	
Tbiv	-15 °C	
TOL	-22 °C	
Pdh Tj = -7°C	4.90 kW	
COP Tj = -7°C	5.03	
Cdh Tj = -7 °C	0.90	
Pdh Tj = +2°C	4.90 kW	
COP Tj = +2°C	5.27	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.90 kW	
COP Tj = +7°C	5.47	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.50	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.92	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.92	
WTOL	65 °C	
Poff	0 W	
PTO	54 W	
PSB	9 W	
PCK	0 W	
Supplementary Heater: Type of energy input	Electricity	
Supplementary Heater: PSUP	1.17 kW	
Annual energy consumption Qhe	2888 kWh	
Pdh Tj = -15°C (if TOL	4.80	

COP Tj = -15°C (if TOL	4.92
Cdh Tj = -15 °C	0.90

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	187 %	
Prated	5.00 kW	
SCOP	4.87	
Tbiv	2 °C	
TOL	0 °C	
Pdh Tj = +2°C	4.80 kW	
COP Tj = +2°C	4.50	
Cdh Tj = +2 °C	0.90	
Pdh Tj = +7°C	4.80 kW	
COP Tj = +7°C	4.80	
Cdh Tj = +7 °C	0.90	
Pdh Tj = 12°C	4.90 kW	
COP Tj = 12°C	5.29	
Cdh Tj = +12 °C	0.90	
Pdh Tj = Tbiv	4.80 kW	
COP Tj = Tbiv	4.50	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.50	
WTOL	65 °C	
Poff	0 W	
PTO	54 W	
PSB	9 W	
PCK	0 W	
Supplementary Heater: Type of energy input	Electricity	
Supplementary Heater: PSUP	0.00 kW	
Annual energy consumption Qhe	1310 kWh	

Model TTC 04 cool, average climates

Model name	TTC 04 cool, average climates
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	128 %
Prated	5.00 kW	4.00 kW
SCOP	4.92	3.40
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.80 kW	4.30 kW
COP Tj = -7°C	4.55	2.85
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.80 kW	4.50 kW
COP Tj = +2°C	4.87	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.90 kW	4.60 kW
COP Tj = +7°C	5.18	3.73
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.90 kW	4.70 kW
COP Tj = 12°C	5.52	4.18
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.80 kW	4.30 kW
COP Tj = Tbiv	4.50	2.72
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.80 kW	4.30 kW

COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	4.50	2.72
WTOL	65 °C	65 °C
P _{off}	0 W	0 W
PTO	54 W	54 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	2002 kWh	2583 kWh