

Subtype HMI120 / DHWT300

Certificate Holder	AERMEC S.p.A.
Address	Via Roma 996
ZIP	37040
City	Bevilacqua (VR)
Country	IT
Certification Body	BRE Global Limited
Subtype title	HMI120 / DHWT300
Registration number	041-K011-05
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	2.2 kg
Certification Date	25.03.2021
Testing basis	Heat Pump Keymark Scheme Rules Rev 08

Model HMI120 / DHWT300X

Model name	HMI120 / DHWT300X
Application	Heating + DHW
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.50 kW	
El input	4.12 kW	
COP	2.55	

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	69 dB(A)	

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	126 %	
Prated	10.00 kW	
SCOP	3.23	

Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	8.40 kW
COP Tj = -7°C	2.05
Cdh Tj = -7 °C	0.98
Pdh Tj = +2°C	5.50 kW
COP Tj = +2°C	3.15
Cdh Tj = +2 °C	0.98
Pdh Tj = +7°C	5.76 kW
COP Tj = +7°C	4.24
Cdh Tj = +7 °C	0.98
Pdh Tj = 12°C	6.36 kW
COP Tj = 12°C	5.06
Cdh Tj = +12 °C	0.98
Pdh Tj = Tbiv	8.40 kW
COP Tj = Tbiv	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.75
WTOL	55 °C
Poff	18 W
PTO	18 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.20 kW
Annual energy consumption Qhe	6406 kWh

Model HMI120T / DHWT300XT

Model name	HMI120T / DHWT300XT
Application	Heating + DHW
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.50 kW	
El input	4.12 kW	
COP	2.55	

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	69 dB(A)	

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	126 %	
Prated	10.00 kW	
SCOP	3.23	

Tbiv	-7 °C
TOL	-10 °C
Pdh Tj = -7°C	8.40 kW
COP Tj = -7°C	2.05
Cdh Tj = -7 °C	0.98
Pdh Tj = +2°C	5.50 kW
COP Tj = +2°C	3.15
Cdh Tj = +2 °C	0.98
Pdh Tj = +7°C	5.76 kW
COP Tj = +7°C	4.24
Cdh Tj = +7 °C	0.98
Pdh Tj = 12°C	6.36 kW
COP Tj = 12°C	5.06
Cdh Tj = +12 °C	0.98
Pdh Tj = Tbiv	8.40 kW
COP Tj = Tbiv	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.75
WTOL	55 °C
Poff	18 W
PTO	18 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.20 kW
Annual energy consumption Qhe	6406 kWh