

## Subtype Sphera EVO 2.0 Tower 190L 2.1, 3.1

Certificate Holder	Clivet s.p.a.
Address	Via camp lonc 25 c.ap.
ZIP	I-32032
City	z.i. Villapaiera - Feltre (BL)
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	Sphera EVO 2.0 Tower 190L 2.1, 3.1
Registration number	ICIM-PDC-000166
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	10.06.2022
Testing basis	HP KEYMARK certification scheme rules rev. n. 9

## Model SQKN-YEE 1 TC A 190 + MiSAN-YEE 1 S 2.1

Model name	SQKN-YEE 1 TC A 190 + MiSAN-YEE 1 S 2.1
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	2.82
Heating up time	2:30 h:min
Standby power input	45.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	204 l

## Model SQKN-YEE 1 TC A 190 + MiSAN-YEE 1 S 3.1

Model name	SQKN-YEE 1 TC A 190 + MiSAN-YEE 1 S 3.1
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	2.82
Heating up time	2:30 h:min
Standby power input	45.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	204 l