

Subtype Sphera EVO 2.0 Tower 190L 4.1, 5.1

Certificate Holder	Clivet s.p.a.
Address	Via camp lonc 25 c.ap.
ZIP	I-32032
City	z.i. Villapaiera - Feltre (BL)
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	Sphera EVO 2.0 Tower 190L 4.1, 5.1
Registration number	ICIM-PDC-000167
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.65 kg
Certification Date	10.06.2022
Testing basis	HP KEYMARK certification scheme rules rev. n. 9

Model SQKN-YEE 1 TC A 190 + MiSAN-YEE 1 S 4.1

Model name	SQKN-YEE 1 TC A 190 + MiSAN-YEE 1 S 4.1
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	116 %
COP	2.70
Heating up time	02:10 h:min
Standby power input	48.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	195 l

Model SQKN-YEE 1 TC A 190 + MiSAN-YEE 1 S 5.1

Model name	SQKN-YEE 1 TC A 190 + MiSAN-YEE 1 S 5.1
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	L
Efficiency η_{DHW}	116 %
COP	2.70
Heating up time	02:10 h:min
Standby power input	48.0 W
Reference hot water temperature	49.0 °C
Mixed water at 40°C	195 l