

Subtype Sherpa Aquadue Tower S3 E 4 - 6

Certificate Holder	Olimpia Splendid S.p.A.
Address	Via Industriale, 1/3
ZIP	25060
City	Cellatica (BS)
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	Sherpa Aquadue Tower S3 E 4 - 6
Registration number	ICIM-PDC-000188
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	23.01.2023
Testing basis	Heat Pump KEYMARK V11

Model SHERPA AQUADUE TOWER S3 E 4

Model name	SHERPA AQUADUE TOWER S3 E 4
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	106 %
COP	2.51
Heating up time	01:14 h:min
Standby power input	45.0 W
Reference hot water temperature	43.0 °C
Mixed water at 40°C	154 l

Model SHERPA AQUADUE TOWER S3 E 6

Model name	SHERPA AQUADUE TOWER S3 E 6
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	106 %
COP	2.51
Heating up time	01:14 h:min
Standby power input	45.0 W
Reference hot water temperature	43.0 °C
Mixed water at 40°C	154 l