

## Subtype Sherpa Tower S3 E 8 - 10

Certificate Holder	Olimpia Splendid S.p.A.
Address	Via Industriale, 1/3
ZIP	25060
City	Cellatica (BS)
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	Sherpa Tower S3 E 8 - 10
Registration number	ICIM-PDC-000186
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.65 kg
Certification Date	23.01.2023
Testing basis	Heat Pump KEYMARK V11

## Model SHERPA TOWER S3 E 8

Model name	SHERPA TOWER S3 E 8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	123 %
COP	2.97
Heating up time	01:00 h:min
Standby power input	40.0 W
Reference hot water temperature	43.7 °C
Mixed water at 40°C	230 l

## Model SHERPA TOWER S3 E 10

Model name	SHERPA TOWER S3 E 10
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	123 %
COP	2.97
Heating up time	01:00 h:min
Standby power input	40.0 W
Reference hot water temperature	43.7 °C
Mixed water at 40°C	230 l