

Subtype Air to Water Heat Pump 200

| | |
|---------------------|---|
| Certificate Holder | Guangdong New Energy Technology Development Co., Ltd. |
| Address | NO.125, Chuangyou Road |
| ZIP | 511340 |
| City | Guangdong |
| Country | CN |
| Certification Body | BRE Global Limited |
| Subtype title | Air to Water Heat Pump 200 |
| Registration number | 041-K054-03 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R32 |
| Mass of Refrigerant | 2.35 kg |
| Certification Date | 16.05.2023 |
| Testing basis | Heat Pump Keymark Scheme Rules Rev 11 |

Model NE-F200HCR4TINVM

| | |
|-------------------------------------|-----------------------|
| Model name | NE-F200HCR4TINVM |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 3x400V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water

EN 14511-4 | Heating

| | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 70 dB(A) | 71 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|-----------------|-----------------|--------------------|
| η_s | 177 % | 130 % |
| Prated | 12.87 kW | 11.83 kW |
| SCOP | 4.50 | 3.32 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 11.38 kW | 10.47 kW |
| COP Tj = -7°C | 3.41 | 2.25 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 7.18 kW | 6.42 kW |
| COP Tj = +2°C | 4.34 | 3.29 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = +7°C | 7.29 kW | 6.95 kW |
| COP Tj = +7°C | 5.73 | 4.18 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 7.63 kW | 7.97 kW |
| COP Tj = 12°C | 7.83 | 6.89 |
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 11.38 kW | 10.47 kW |
| COP Tj = Tbiv | 3.41 | 2.25 |

| | | |
|---|-------------|-------------|
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 12.79 kW | 11.77 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.69 | 1.85 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 60 °C | 60 °C |
| Poff | 5 W | 5 W |
| PTO | 16 W | 16 W |
| PSB | 5 W | 5 W |
| PCK | 24 W | 24 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.08 kW | 0.06 kW |
| Annual energy consumption Qhe | 5908 kWh | 7372 kWh |