

Subtype Hi-Therma Split 4 6kW with 185L tank

Certificate Holder	Johnson Controls Hitachi Air-Conditioning Europe SAS
Address	Parc Aktiland II - 2, Rue de Lombardie
ZIP	69800
City	SAINT PRIEST
Country	FR
Certification Body	BRE Global Limited
Subtype title	Hi-Therma Split 4 6kW with 185L tank
Registration number	041-K064-03
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	0.98 kg
Certification Date	14.08.2023
Testing basis	Heat-pump Keymark Scheme rules v12

Model HZKF04KSE-Q + HZKF04KIE-Q/HAQT-200

Model name	HZKF04KSE-Q + HZKF04KIE-Q/HAQT-200
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	125 %
COP	3.03
Heating up time	1:52 h:min
Standby power input	20.0 W
Reference hot water temperature	47.5 °C
Mixed water at 40°C	190 l

Model HZKF06KSE-Q + HZKF06KIE-Q/HAQT-200

Model name	HZKF06KSE-Q + HZKF06KIE-Q/HAQT-200
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water**EN 16147 | Average Climate**

Declared load profile	L
Efficiency η_{DHW}	125 %
COP	3.03
Heating up time	1:52 h:min
Standby power input	20.0 W
Reference hot water temperature	47.5 °C
Mixed water at 40°C	190 l