

Subtype Monobloc Air-to-Water Heat Pump System- R32- U082

| | |
|---------------------|--|
| Certificate Holder | Qingdao Haier Air Conditioner Electric Co., Ltd. |
| Address | Haier Development Zone Industrial Park, Economic Development Zone, Qingdao City, |
| ZIP | |
| City | Shandong Province |
| Country | CN |
| Certification Body | BRE Global Limited |
| Subtype title | Monobloc Air-to-Water Heat Pump System- R32- U082 |
| Registration number | 041-K073-02 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R32 |
| Mass of Refrigerant | 1.15 kg |
| Certification Date | 06.11.2023 |
| Testing basis | Heat Pump Keymark Scheme Rules Rev 12 |

Model AU082FYCRA(HW)

| | |
|-------------------------------------|-----------------------|
| Model name | AU082FYCRA(HW) |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water

EN 14511-4 | Heating

| | |
|--|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 64 dB(A) | 67 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|-----------------|-----------------|--------------------|
| η_s | 157 % | 116 % |
| Prated | 7.91 kW | 6.91 kW |
| SCOP | 4.00 | 2.98 |
| Tbiv | -7 °C | -7 °C |
| TOL | -25 °C | -25 °C |
| Pdh Tj = -7°C | 7.00 kW | 6.11 kW |
| COP Tj = -7°C | 2.88 | 1.92 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 4.37 kW | 3.64 kW |
| COP Tj = +2°C | 3.86 | 2.90 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = +7°C | 2.90 kW | 2.66 kW |
| COP Tj = +7°C | 5.17 | 4.13 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 4.96 kW | 2.07 kW |
| COP Tj = 12°C | 6.31 | 5.06 |
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 7.00 kW | 6.11 kW |
| COP Tj = Tbiv | 2.88 | 1.92 |

| | | |
|---|-------------|-------------|
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.88 kW | 5.56 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 3.05 | 1.58 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 55 °C | 55 °C |
| Poff | 5 W | 5 W |
| PTO | 50 W | 50 W |
| PSB | 5 W | 5 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.03 kW | 1.34 kW |
| Annual energy consumption Qhe | 4081 kWh | 4785 kWh |