

Subtype Daikin Altherma 3 R MT F+W 08 kW (180L)

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Daikin Altherma 3 R MT F+W 08 kW (180L)
Registration number	011-1W0651
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	3.25 kg
Certification Date	01.08.2023
Testing basis	HP KEYMARK certification scheme rules V12

Model ERRA08EV3 / ELVH12S18E(6V/9W)

Model name	ERRA08EV3 / ELVH12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EW1 / ELVH12S18E(6V/9W)

Model name	ERRA08EW1 / ELVH12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EV3 / ELVX12S18E(6V/9W)

Model name	ERRA08EV3 / ELVX12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EW1 / ELVX12S18E(6V/9W)

Model name	ERRA08EW1 / ELVX12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EV3 / ELVZ12S18E(6V/9W)

Model name	ERRA08EV3 / ELVZ12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EW1 / ELVZ12S18E(6V/9W)

Model name	ERRA08EW1 / ELVZ12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EV3 / ELBH12E(6V/9W)

Model name	ERRA08EV3 / ELBH12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	184 %	130 %
Prated	8.3 kW	12.5 kW
SCOP	4.69	3.34
Tbiv	-7 °C	-2 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	7.5 kW	8.5 kW
COP Tj = Tbiv	3.1	2.81

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	6.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.8	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	5.6 kW
Annual energy consumption Qhe	3659 kWh	7742 kWh

Model ERRA08EW1 / ELBH12E(6V/9W)

Model name	ERRA08EW1 / ELBH12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	190 %	134 %
Prated	8.3 kW	12.5 kW
SCOP	4.81	3.42
Tbiv	-7 °C	-2 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	7.5 kW	8.5 kW
COP Tj = Tbiv	3.2	2.9

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	6.9 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.9	2.04
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	5.6 kW
Annual energy consumption Qhe	3561 kWh	7541 kWh

Model ERRA08EV3 / ELBX12E(6V/9W)

Model name	ERRA08EV3 / ELBX12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	132 %
Prated	8.3 kW	12.5 kW
SCOP	4.79	3.37
Tbiv	-7 °C	-2 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	7.5 kW	8.5 kW

COP $T_j = T_{biv}$	3.1	2.81
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.9 kW	6.9 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.8	1.97
WTOL	35 °C	55 °C
P _{off}	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	5.6 kW
Annual energy consumption Q _{he}	3582 kWh	7664 kWh

Model ERRA08EW1 / ELBX12E(6V/9W)

Model name	ERRA08EW1 / ELBX12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	136 %
Prated	8.3 kW	12.5 kW
SCOP	4.95	3.47
Tbiv	-7 °C	-2 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	7.5 kW	8.5 kW

COP $T_j = T_{biv}$	3.2	2.9
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.9 kW	6.9 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.9	2.04
WTOL	35 °C	55 °C
P _{off}	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	5.6 kW
Annual energy consumption Q _{he}	3462 kWh	7442 kWh

Model ERRA08EV3 / ELVH12S18E(6V/9W) + cooling kit

Model name	ERRA08EV3 / ELVH12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EW1 / ELVH12S18E(6V/9W) + cooling kit

Model name	ERRA08EW1 / ELVH12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EV3 / ELVZ12S18E(6V/9W) + cooling kit

Model name	ERRA08EV3 / ELVZ12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EW1 / ELVZ12S18E(6V/9W) + cooling kit

Model name	ERRA08EW1 / ELVZ12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

Model ERRA08EV3 / ELBH12E(6V/9W) + cooling kit

Model name	ERRA08EV3 / ELBH12E(6V/9W) + cooling kit
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	132 %
Prated	8.3 kW	12.5 kW
SCOP	4.79	3.37
Tbiv	-7 °C	-2 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	7.5 kW	8.5 kW

COP $T_j = T_{biv}$	3.1	2.81
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.9 kW	6.9 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.8	1.97
WTOL	35 °C	55 °C
P _{off}	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	5.6 kW
Annual energy consumption Q _{he}	3582 kWh	7664 kWh

Model ERRA08EW1 / ELBH12E(6V/9W) + cooling kit

Model name	ERRA08EW1 / ELBH12E(6V/9W) + cooling kit
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	136 %
Prated	8.3 kW	12.5 kW
SCOP	4.95	3.47
Tbiv	-7 °C	-2 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	7.5 kW	8.5 kW

COP $T_j = T_{biv}$	3.2	2.9
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.9 kW	6.9 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.9	2.04
WTOL	35 °C	55 °C
P _{off}	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	5.6 kW
Annual energy consumption Q _{he}	3462 kWh	7442 kWh