

Subtype DAIKIN ALTHERMA 3 R W 8KW /A

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA 3 R W 8KW /A
Registration number	011-1W0248
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	02.03.2018
Testing basis	HP KEYMARK certification scheme rules rev. 7

Model ERGA08DVA / EHBX08D9W

Model name	ERGA08DVA / EHBX08D9W
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	129 %
Prated	8.00 kW	7.50 kW
SCOP	4.61	3.30
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3588 kWh	4694 kWh

Model ERGA08DVA / EHBX08D6V

Model name	ERGA08DVA / EHBX08D6V
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	129 %
Prated	8.00 kW	7.50 kW
SCOP	4.61	3.30
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3588 kWh	4694 kWh

Model ERGA08DVA / EHBH08D9W

Model name	ERGA08DVA / EHBH08D9W
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	179 %	128 %
Prated	8.00 kW	7.50 kW
SCOP	4.56	3.27
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3625 kWh	4731 kWh

Model ERGA08DVA / EHBH08D6V

Model name	ERGA08DVA / EHBH08D6V
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	Yes

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	179 %	128 %
Prated	8.00 kW	7.50 kW
SCOP	4.56	3.27
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3625 kWh	4731 kWh

Model ERGA08EVA / EHBX08E6V

Model name	ERGA08EVA / EHBX08E6V
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	129 %
Prated	8.00 kW	7.50 kW
SCOP	4.61	3.30
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3588 kWh	4694 kWh

Model ERGA08EVA / EHBX08E9W

Model name	ERGA08EVA / EHBX08E9W
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	181 %	129 %
Prated	8.00 kW	7.50 kW
SCOP	4.61	3.30
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3588 kWh	4694 kWh

Model ERGA08EVA / EHBH08E6V

Model name	ERGA08EVA / EHBH08E6V
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	179 %	128 %
Prated	8.00 kW	7.50 kW
SCOP	4.56	3.27
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3625 kWh	4731 kWh

Model ERGA08EVA / EHBH08E9W

Model name	ERGA08EVA / EHBH08E9W
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	179 %	128 %
Prated	8.00 kW	7.50 kW
SCOP	4.56	3.27
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	4.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.41	1.43
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3625 kWh	4731 kWh