

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Daikin Altherma LT split integrated solar 14 kW 3ph / ROTEX HPSU Compact (BIV) 14 kW 3ph	Reg. No.	011-1W0103
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	CETIAT		
Subtype title	Daikin Altherma LT split integrated solar 14 kW 3ph / ROTEX HPSU Compact (BIV) 14 kW 3ph		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	3.4 kg		
Certification Date	21.03.2017		

Model: ERLQ014C*W1 / EHSX16P50B

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	14.81 kW	12.44 kW
El input	3.47 kW	4.95 kW
COP	4.27	2.49
Indoor water flow rate	2.55 m ³ /h	1.53 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	153 %	130 %
Prated	14.50 kW	12.00 kW
SCOP	3.90	3.32
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.90 kW
COP Tj = -7°C	2.63	1.92
Cdh	1.00	1.00
Pdh Tj = +2°C	7.71 kW	6.60 kW
COP Tj = +2°C	4.07	3.30
Cdh	1.00	1.00
Pdh Tj = +7°C	5.05 kW	4.60 kW
COP Tj = +7°C	5.71	4.34
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	5.16 kW	5.50 kW
COP Tj = 12°C	6.71	6.45
Cdh	0.93	0.90
Pdh Tj = Tbiv	11.60 kW	10.90 kW
COP Tj = Tbiv	2.83	1.92
Pdh Tj = TOL	12.60 kW	9.80 kW
COP Tj = TOL	2.60	1.63
WTOL	35 °C	55 °C
Poff	50 W	50 W
PTO	105 W	105 W
PSB	50 W	50 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	7250 kWh	7654 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	83 %
COP	2.11
Heating up time	1:20 h:min
Standby power input	67.4 W
Reference hot water temperature	45.2 °C
Mixed water at 40°C	237 l

Model: RRLQ014C*W1 / HPSU Compact 516

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	14.81 kW	12.44 kW
El input	3.47 kW	4.95 kW
COP	4.27	2.49
Indoor water flow rate	2.55 m ³ /h	1.53 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	153 %	130 %
Prated	14.50 kW	12.00 kW
SCOP	3.90	3.32
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.90 kW
COP Tj = -7°C	2.63	1.92
Cdh	1.00	1.00
Pdh Tj = +2°C	7.71 kW	6.60 kW
COP Tj = +2°C	4.07	3.30
Cdh	1.00	1.00
Pdh Tj = +7°C	5.05 kW	4.60 kW
COP Tj = +7°C	5.71	4.34
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	5.16 kW	5.50 kW
COP Tj = 12°C	6.71	6.45
Cdh	0.93	0.90
Pdh Tj = Tbiv	11.60 kW	10.90 kW
COP Tj = Tbiv	2.83	1.92
Pdh Tj = TOL	12.60 kW	9.80 kW
COP Tj = TOL	2.60	1.63
WTOL	35 °C	55 °C
Poff	50 W	50 W
PTO	105 W	105 W
PSB	50 W	50 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	7250 kWh	7654 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	83 %
COP	2.11
Heating up time	1:20 h:min
Standby power input	67.4 W
Reference hot water temperature	45.2 °C
Mixed water at 40°C	237 l

Model: ERLQ014C*W1 / EHSXB16P50B

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	14.81 kW	12.44 kW
El input	3.47 kW	4.95 kW
COP	4.27	2.49
Indoor water flow rate	2.55 m ³ /h	1.53 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	153 %	130 %
Prated	14.50 kW	12.00 kW
SCOP	3.90	3.32
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.90 kW
COP Tj = -7°C	2.63	1.92
Cdh	1.00	1.00
Pdh Tj = +2°C	7.71 kW	6.60 kW
COP Tj = +2°C	4.07	3.30
Cdh	1.00	1.00
Pdh Tj = +7°C	5.05 kW	4.60 kW
COP Tj = +7°C	5.71	4.34
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	5.16 kW	5.50 kW
COP Tj = 12°C	6.71	6.45
Cdh	0.93	0.90
Pdh Tj = Tbiv	11.60 kW	10.90 kW
COP Tj = Tbiv	2.83	1.92
Pdh Tj = TOL	12.60 kW	9.80 kW
COP Tj = TOL	2.60	1.63
WTOL	35 °C	55 °C
Poff	50 W	50 W
PTO	105 W	105 W
PSB	50 W	50 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	7250 kWh	7654 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	84 %
COP	2.14
Heating up time	1:20 h:min
Standby power input	66.1 W
Reference hot water temperature	45.0 °C
Mixed water at 40°C	211 l

Model: RRLQ014C*W1 / HPSU Compact 516 Biv

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	14.81 kW	12.44 kW
El input	3.47 kW	4.95 kW
COP	4.27	2.49
Indoor water flow rate	2.55 m ³ /h	1.53 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	153 %	130 %
Prated	14.50 kW	12.00 kW
SCOP	3.90	3.32
Tbiv	-5 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.90 kW
COP Tj = -7°C	2.63	1.92
Cdh	1.00	1.00
Pdh Tj = +2°C	7.71 kW	6.60 kW
COP Tj = +2°C	4.07	3.30
Cdh	1.00	1.00
Pdh Tj = +7°C	5.05 kW	4.60 kW
COP Tj = +7°C	5.71	4.34
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	5.16 kW	5.50 kW
COP Tj = 12°C	6.71	6.45
Cdh	0.93	0.90
Pdh Tj = Tbiv	11.60 kW	10.90 kW
COP Tj = Tbiv	2.83	1.92
Pdh Tj = TOL	12.60 kW	9.80 kW
COP Tj = TOL	2.60	1.63
WTOL	35 °C	55 °C
Poff	50 W	50 W
PTO	105 W	105 W
PSB	50 W	50 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electrical	electrical
Supplementary Heater: PSUP	9.00 kW	9.00 kW
Annual energy consumption Qhe	7250 kWh	7654 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	84 %
COP	2.14
Heating up time	1:20 h:min
Standby power input	66.1 W
Reference hot water temperature	45.0 °C
Mixed water at 40°C	211 l