

Subtype THERMOR Alféa Extensa A.I. size 13

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	THERMOR Alféa Extensa A.I. size 13
Registration number	012-SC0226-19
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.5 kg
Certification Date	05.06.2019

Model THERMOR Alféa Extensa A.I. 13

Model name	THERMOR Alféa Extensa A.I. 13
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
Phase-out Date	16.04.2026

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.01 kW	7.84 kW
El input	3.50 kW	3.25 kW
COP	4.00	2.41

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	151 %	109 %
Prated	11.00 kW	8.00 kW
SCOP	3.85	2.80
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.00 kW	8.20 kW
COP Tj = -7°C	2.60	1.90
Pdh Tj = +2°C	6.10 kW	5.00 kW
COP Tj = +2°C	3.70	2.70
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.30	3.80
Pdh Tj = 12°C	7.40 kW	7.00 kW

COP Tj = 12°C	6.90	4.80
Pdh Tj = Tbiv	10.00 kW	8.20 kW
COP Tj = Tbiv	2.60	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	8.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.20	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	55 °C	55 °C
Poff	8 W	8 W
PTO	45 W	22 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.30 kW	1.30 kW
Annual energy consumption Qhe	6062 kWh	6842 kWh