

## Subtype RSJ-16/190

Certificate Holder	GD Midea Heating & Ventilating Equipment Co., Ltd.
Address	Penglai Industry Road
ZIP	528311
City	Beijiao, Shunde, Foshan
Country	CN
Certification Body	ICIM S.p.A.
Subtype title	RSJ-16/190
Registration number	ICIM-PDC-000039
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R134a
Mass of Refrigerant	1.1 kg
Certification Date	25.06.2019



## Model RSJ-16/190

-	
Model name	RSJ-16/190
Application	Heating + DHW
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
General data	
Power supply	1x230V 50Hz
Off-peak product	No
Heat Pump for Domestic Hot Water (DHV EN 12102-2   Average Climate	N)
Sound power level indoor	51 dB(A)
EN 16147   Average Climate	
Declared load profile	L
Efficiency nDHW	115 %
COP	2.76
Heating up time	7:01 h:min
Standby power input	26.3 W
Reference hot water temperature	53.8 °C
Mixed water at 40°C	234