

Subtype WWK 300 electronic	
Certificate Holder	STIEBEL ELTRON GmbH & Co KG
Address	Dr. Stiebel Straße 33
ZIP	37603
City	Holzminden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	WWK 300 electronic
Registration number	011-1W0114
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R134a
Mass of Refrigerant	0.85 kg
Certification Date	04.05.2017



Model WWK 300 electronic	
Model name	WWK 300 electronic
Application	Heating + DHW
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
General data	
Power supply	1x230V 50Hz
Off-peak product	No
Heat Pump for Domestic Hot Water (DHW)	
EN 12102-2 Average Climate	
Sound power level indoor	60 dB(A)
EN 16147 Average Climate	
Declared load profile	XL
Efficiency ηDHW	144 %
COP	3.51
Heating up time	9:03 h:min
Standby power input	60.0 W
Reference hot water temperature	54.4 °C
Mixed water at 40°C	395 I



Model WWK 300 electronic SOL	
Model name	WWK 300 electronic SOL
Application	Heating + DHW
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a
General data	
Power supply	1x230V 50Hz
Off-peak product	No
Heat Dump for Demostic Het Water (DUW)	
Heat Pump for Domestic Hot Water (DHW)	
EN 12102-2 Average Climate	
Sound power level indoor	60 dB(A)
EN 16147 Average Climate	
Declared load profile	XL
Efficiency ηDHW	144 %
COP	3.51
Heating up time	9:03 h:min
Standby power input	60.0 W
Reference hot water temperature	54.4 °C
Mixed water at 40°C	371