

Subtype ATLANTIC GEOLIA 10

Certificate Holder	Groupe Atlantic
Address	44 boulevard des Etats-Unis
ZIP	85000
City	La Roche Sur Yon
Country	FR
Certification Body	RISE CERT
Subtype title	ATLANTIC GEOLIA 10
Registration number	012-C700081
Heat Pump Type	Brine/Water and Water/Water
Refrigerant	R410A
Mass of Refrigerant	1.45 kg
Certification Date	16.10.2020
Testing basis	HP Keymark Scheme Rules rev 8

Model ATLANTIC GEOLIA 10

Model name	ATLANTIC GEOLIA 10
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.08 kW	kW
El input	2.48 kW	kW
COP	4.06	

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	56 dB(A)	56 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	%
Prated	12.00 kW	kW
SCOP	4.30	
Tbiv	-7 °C	°C
TOL	-10 °C	°C
Pdh Tj = -7°C	10.20 kW	kW
COP Tj = -7°C	4.08	
Cdh Tj = -7 °C	0.990	
Pdh Tj = +2°C	10.30 kW	kW
COP Tj = +2°C	4.33	
Cdh Tj = +2 °C	0.990	
Pdh Tj = +7°C	10.40 kW	kW
COP Tj = +7°C	4.56	

Cdh Tj = +7 °C	0.990	
Pdh Tj = 12°C	10.60 kW	kW
COP Tj = 12°C	4.80	
Cdh Tj = +12 °C	0.990	
Pdh Tj = Tbiv	10.20 kW	kW
COP Tj = Tbiv	4.08	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.10 kW	kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.98	
WTOL	50 °C	°C
Poff	2 W	W
PTO	24 W	W
PSB	4 W	W
PCK	0 W	W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	kW
Annual energy consumption Qhe	5644 kWh	kWh

Water/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	13.38 kW	11.75 kW
El input	2.48 kW	3.52 kW
COP	5.38	3.34

EN 14825 | Average Climate

	Low temperature	Medium temperature
ηs	231 %	177 %
Prated	15.00 kW	14.00 kW
SCOP	5.98	4.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.40 kW	12.40 kW
COP Tj = -7°C	5.71	3.74
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	13.50 kW	12.80 kW
COP Tj = +2°C	6.03	4.67
Cdh Tj = +2 °C	0.990	0.990

Pdh Tj = +7°C	13.60 kW	13.00 kW
COP Tj = +7°C	6.48	5.29
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	13.70 kW	13.30 kW
COP Tj = 12°C	6.68	5.91
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	13.40 kW	12.40 kW
COP Tj = Tbiv	5.71	3.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.30 kW	11.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.27	3.27
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	24 W	24 W
PSB	4 W	4 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.80 kW	1.80 kW
Annual energy consumption Qhe	5525 kWh	6442 kWh