

Subtype TTF 4.6, TTF 6.6, TTF 8.6

Certificate Holder	tecalor GmbH
Address	Fürstenbergerstr. 77
ZIP	37603
City	Holzminden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	TTF 4.6, TTF 6.6, TTF 8.6
Registration number	011-1W0396
Heat Pump Type	Brine/Water
Refrigerant	R454C
Mass of Refrigerant	2.2 kg
Certification Date	08.09.2020

Model TTF 4.6 (cool) / TTC 4.6 (cool)

Model name	TTF 4.6 (cool) / TTC 4.6 (cool)
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	1.96 kW	1.26 kW
El input	0.43 kW	0.47 kW
COP	4.60	2.73

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	153 %
Prated	4.23 kW	3.76 kW
SCOP	5.07	4.02
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.73 kW	3.32 kW
COP Tj = -7°C	5.01	3.58
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.26 kW	2.02 kW
COP Tj = +2°C	5.38	4.22
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.45 kW	1.30 kW
COP Tj = +7°C	5.34	4.47

Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.13 kW	1.08 kW
COP Tj = 12°C	5.32	4.49
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.23 kW	3.76 kW
COP Tj = Tbiv	4.86	3.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.23 kW	3.76 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.86	3.43
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1723 kWh	1934 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	201 %	157 %
Prated	4.23 kW	3.76 kW
SCOP	5.21	4.12
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	2.55 kW	2.27 kW
COP Tj = -7°C	5.37	4.10
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	1.55 kW	1.38 kW
COP Tj = +2°C	5.45	4.37
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.13 kW	1.09 kW
COP Tj = +7°C	5.31	4.51
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.12 kW	1.09 kW
COP Tj = 12°C	5.21	4.52
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.23 kW	3.76 kW
COP Tj = Tbiv	4.86	3.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.23 kW	3.76 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.86	3.43
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2000 kWh	2252 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	38 dB(A)	38 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	187 %	147 %
Prated	4.23 kW	3.76 kW
SCOP	4.87	3.87
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.23 kW	3.76 kW
COP Tj = +2°C	4.86	3.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.71 kW	2.41 kW
COP Tj = +7°C	5.24	3.95
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.20 kW	1.08 kW
COP Tj = 12°C	5.31	4.39
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.23 kW	3.76 kW
COP Tj = Tbiv	4.86	3.43
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.23 kW	3.76 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.86	3.43
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1159 kWh	1300 kWh

Model TTF 6.6 (cool) / TTC 6.6 (cool)

Model name	TTF 6.6 (cool) / TTC 6.6 (cool)
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.37 kW	2.01 kW
El input	0.52 kW	0.69 kW
COP	4.60	2.91

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	200 %	160 %
Prated	6.70 kW	6.05 kW
SCOP	5.20	4.18
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.91 kW	5.34 kW
COP Tj = -7°C	4.71	3.55
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.59 kW	3.25 kW
COP Tj = +2°C	5.39	4.27
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.30 kW	2.09 kW
COP Tj = +7°C	5.60	4.76

Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.14 kW	1.08 kW
COP Tj = 12°C	5.47	4.61
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.70 kW	6.05 kW
COP Tj = Tbiv	4.52	3.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.70 kW	6.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.52	3.34
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2662 kWh	2988 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	207 %	166 %
Prated	6.70 kW	6.05 kW
SCOP	5.38	4.34
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.04 kW	3.65 kW
COP Tj = -7°C	5.36	4.15
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.45 kW	2.22 kW
COP Tj = +2°C	5.64	4.68
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.57 kW	1.42 kW
COP Tj = +7°C	5.76	4.80
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.13 kW	1.10 kW
COP Tj = 12°C	5.32	4.73
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.70 kW	6.05 kW
COP Tj = Tbiv	4.52	3.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.70 kW	6.05 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.52	3.34
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3069 kWh	3439 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	198 %	158 %
Prated	6.70 kW	6.05 kW
SCOP	5.14	4.14
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.70 kW	6.05 kW
COP Tj = +2°C	4.52	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.29 kW	3.88 kW
COP Tj = +7°C	5.19	3.97
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.90 kW	1.72 kW
COP Tj = 12°C	5.71	4.81
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.70 kW	6.05 kW
COP Tj = Tbiv	4.52	3.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.70 kW	6.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.52	3.34
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1741 kWh	1954 kWh

Model TTF 8.6 (cool) / TTC 8.6 (cool)

Model name	TTF 8.6 (cool) / TTC 8.6 (cool)
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.78 kW	2.42 kW
El input	0.60 kW	0.79 kW
COP	4.67	3.07

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	197 %	158 %
Prated	7.66 kW	6.93 kW
SCOP	5.12	4.14
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.76 kW	6.12 kW
COP Tj = -7°C	4.53	3.44
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.11 kW	3.72 kW
COP Tj = +2°C	5.25	4.21
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.64 kW	2.39 kW
COP Tj = +7°C	5.59	4.69

Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.16 kW	1.08 kW
COP Tj = 12°C	5.52	4.61
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.66 kW	6.93 kW
COP Tj = Tbiv	4.29	3.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.66 kW	6.93 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.29	3.22
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3094 kWh	3461 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	204 %	163 %
Prated	7.66 kW	6.93 kW
SCOP	5.29	4.29
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.62 kW	4.18 kW
COP Tj = -7°C	5.17	4.07
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.81 kW	2.54 kW
COP Tj = +2°C	5.60	4.60
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.80 kW	1.63 kW
COP Tj = +7°C	5.76	4.90
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.13 kW	1.09 kW
COP Tj = 12°C	5.34	4.75
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.66 kW	6.93 kW
COP Tj = Tbiv	4.29	3.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.66 kW	6.93 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.29	3.22
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3570 kWh	3985 kWh

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	197 %	157 %
Prated	7.66 kW	6.93 kW
SCOP	5.13	4.13
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.66 kW	6.93 kW
COP Tj = +2°C	4.29	3.22
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.91 kW	4.45 kW
COP Tj = +7°C	5.09	3.88
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.17 kW	1.97 kW
COP Tj = 12°C	5.75	4.85
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.66 kW	6.93 kW
COP Tj = Tbiv	4.29	3.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.66 kW	6.93 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.29	3.22
WTOL	75 °C	75 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1997 kWh	2243 kWh